

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom Februar 2023
gedruckt am: 14.03.2023, 15:16 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
Analysen 2022	11,31	1.520	134,34	10:13	200,97	13,30	23:58	194,30	19,97
02.02.23	4,65	609	131,02	21:00	200,90	13,37	0:32	194,27	20,00
03.02.23	0,00	0	---	8:31	201,03	13,24	---	---	---
04.02.23	2,73	379	138,94	5:47	200,98	13,29	18:25	194,82	19,45
05.02.23	5,16	688	133,23	23:51	201,19	13,08	0:52	194,72	19,56
06.02.23	3,55	483	135,98	11:37	201,71	12,56	15:28	194,95	19,32
07.02.23	7,69	1.041	135,33	9:40	201,43	12,85	20:09	194,59	19,68
08.02.23	10,35	1.385	133,84	7:40	201,05	13,23	0:45	194,53	19,75
09.02.23	13,23	1.750	132,30	5:36	200,92	13,35	16:15	194,29	19,98
10.02.23	10,31	1.390	134,81	6:36	200,91	13,36	20:43	194,36	19,91
11.02.23	16,37	2.200	134,41	9:23	200,95	13,32	23:15	194,07	20,21
12.02.23	19,85	2.718	136,93	6:37	200,97	13,30	19:37	194,09	20,18
13.02.23	24,00	3.256	135,67	---	---	---	23:27	193,98	20,29
14.02.23	22,50	3.050	135,58	9:41	200,43	13,84	8:07	193,78	20,49
15.02.23	24,00	3.256	135,67	---	---	---	11:43	193,99	20,28
16.02.23	24,00	3.253	135,54	---	---	---	1:55	193,99	20,28
17.02.23	24,00	3.249	135,38	---	---	---	22:44	194,01	20,26
18.02.23	7,87	1.065	135,35	22:16	201,11	13,16	3:47	194,01	20,26
19.02.23	0,00	0	---	10:40	201,34	12,93	---	---	---
20.02.23	0,00	0	---	7:58	201,49	12,78	---	---	---
21.02.23	0,83	111	134,14	12:53	201,61	12,66	---	---	---
22.02.23	0,00	0	---	7:51	201,74	12,53	---	---	---
23.02.23	0,00	0	---	9:17	201,59	12,69	---	---	---
24.02.23	0,00	0	---	8:33	201,28	12,99	---	---	---
25.02.23	0,00	0	---	8:37	201,33	12,94	---	---	---
26.02.23	0,00	0	---	8:01	201,24	13,03	---	---	---
27.02.23	0,00	0	---	6:32	201,38	12,89	---	---	---
28.02.23	3,86	522	135,11	9:01	201,35	12,92	11:24	194,63	19,65
Σ	236,26	31.925							
Mittelwert	8,44	1.140	135,13		201,20	13,07		194,30	19,97
Minimum	0,00	0	131,02		200,43	12,53		193,78	19,32
Maximum	24,00	3.256	138,94		201,74	13,84		194,95	20,49

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom Februar 2023
gedruckt am: 14.03.2023, 15:16 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.02.23	24,00	3.356	139,83	---	---	---	21:38	192,00	22,22
02.02.23	24,00	3.363	140,13	---	---	---	0:00	192,01	22,21
03.02.23	24,00	3.389	141,21	---	---	---	14:30	192,00	22,22
04.02.23	24,00	3.387	141,13	---	---	---	10:48	192,00	22,22
05.02.23	15,36	2.161	140,68	20:34	192,02	22,21	1:03	192,00	22,22
06.02.23	6,76	924	136,60	0:41	192,02	22,21	15:30	192,01	22,21
07.02.23	18,55	2.617	141,09	0:44	192,02	22,21	4:48	192,01	22,21
08.02.23	24,00	3.367	140,29	---	---	---	0:00	192,01	22,21
09.02.23	24,00	3.341	139,21	---	---	---	22:35	192,00	22,22
10.02.23	24,00	3.360	140,00	---	---	---	6:00	192,00	22,22
11.02.23	12,49	1.740	139,26	14:39	192,02	22,21	0:00	192,01	22,21
12.02.23	0,00	0	---	0:23	192,02	22,21	---	---	---
13.02.23	0,00	0	---	0:01	192,02	22,21	---	---	---
14.02.23	1,63	229	140,54	1:18	192,02	22,21	---	---	---
15.02.23	0,00	0	---	1:03	192,02	22,21	---	---	---
16.02.23	0,00	0	---	0:09	192,02	22,21	---	---	---
17.02.23	0,00	0	---	0:32	192,02	22,21	---	---	---
18.02.23	14,19	2.036	143,48	0:09	192,02	22,21	16:05	192,00	22,22
19.02.23	22,18	3.194	143,99	---	---	---	5:37	192,00	22,22
20.02.23	21,70	3.103	142,98	7:53	192,02	22,21	0:00	192,01	22,21
21.02.23	18,89	2.705	143,21	9:46	192,02	22,21	18:14	192,00	22,22
22.02.23	18,12	2.598	143,35	3:53	192,02	22,21	0:00	192,01	22,21
23.02.23	21,94	3.131	142,71	9:12	192,02	22,21	14:12	192,00	22,22
24.02.23	24,00	3.400	141,67	---	---	---	21:07	192,00	22,22
25.02.23	23,60	3.353	142,06	---	---	---	3:49	192,00	22,22
26.02.23	23,63	3.365	142,42	---	---	---	10:25	192,00	22,22
27.02.23	21,86	3.090	141,35	6:17	192,02	22,21	0:00	192,01	22,21
28.02.23	21,22	2.985	140,70	8:33	192,02	22,21	0:13	192,00	22,22
Σ	454,13	64.194							
Mittelwert	16,22	2.293	141,36		192,02	22,21		192,00	22,22
Minimum	0,00	0	136,60		192,02	22,21		192,00	22,21
Maximum	24,00	3.400	143,99		192,02	22,21		192,01	22,22

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom Februar 2023
gedruckt am: 14.03.2023, 15:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.02.23	0,56	50	89,02	0:32	193,01	27,11	---	---	---
02.02.23	6,87	645	93,95	2:45	193,01	27,11	10:10	193,01	27,12
03.02.23	9,50	874	92,02	2:56	193,01	27,11	0:10	193,01	27,12
04.02.23	4,90	455	92,85	11:07	193,01	27,11	7:55	193,01	27,12
05.02.23	8,55	831	97,16	2:22	193,01	27,11	16:21	193,01	27,12
06.02.23	20,42	1.934	94,71	9:56	193,01	27,11	0:00	193,01	27,12
07.02.23	5,38	501	93,11	5:23	193,01	27,11	0:00	193,01	27,12
08.02.23	0,00	0	---	0:45	193,01	27,11	---	---	---
09.02.23	0,00	0	---	1:45	193,01	27,11	---	---	---
10.02.23	0,00	0	---	2:10	193,01	27,11	---	---	---
11.02.23	11,42	1.099	96,25	1:53	193,01	27,11	13:30	193,01	27,12
12.02.23	23,48	2.257	96,14	---	---	---	0:00	193,01	27,12
13.02.23	24,00	2.297	95,71	---	---	---	0:00	193,01	27,12
14.02.23	20,70	1.976	95,44	9:03	193,01	27,11	0:00	193,01	27,12
15.02.23	24,00	2.298	95,75	---	---	---	0:00	193,01	27,12
16.02.23	24,00	2.297	95,71	---	---	---	0:00	193,01	27,12
17.02.23	24,00	2.294	95,58	---	---	---	0:00	193,01	27,12
18.02.23	13,42	1.275	94,97	17:53	193,01	27,11	0:00	193,01	27,12
19.02.23	2,08	194	93,31	0:26	193,01	27,11	---	---	---
20.02.23	5,94	553	93,14	1:11	193,01	27,11	12:53	193,01	27,12
21.02.23	4,73	440	93,06	1:32	193,01	27,11	15:25	193,01	27,12
22.02.23	5,91	551	93,21	0:53	193,01	27,11	11:37	193,01	27,12
23.02.23	7,65	713	93,18	5:50	193,01	27,11	11:38	193,01	27,12
24.02.23	10,05	942	93,73	0:14	193,01	27,11	10:01	193,01	27,12
25.02.23	7,97	734	92,14	2:04	193,01	27,11	10:39	193,01	27,12
26.02.23	5,16	480	93,00	1:16	193,01	27,11	11:22	193,01	27,12
27.02.23	10,17	952	93,62	0:48	193,01	27,11	9:00	193,01	27,12
28.02.23	9,94	916	92,13	5:04	193,01	27,11	0:00	193,01	27,12
Σ	290,80	27.558							
Mittelwert	10,39	984	94,77		193,01	27,11		193,01	27,12
Minimum	0,00	0	89,02		193,01	27,11		193,01	27,12
Maximum	24,00	2.298	97,16		193,01	27,11		193,01	27,12

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom Februar 2023
gedruckt am: 14.03.2023, 15:16 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.02.23	24,00	2.400	100,00	---	---	---	18:51	197,58	23,80
02.02.23	24,00	2.412	100,50	---	---	---	8:54	197,34	24,05
03.02.23	22,92	2.364	103,16	---	---	---	1:14	197,63	23,75
04.02.23	23,03	2.357	102,35	---	---	---	19:37	197,51	23,87
05.02.23	23,56	2.483	105,37	---	---	---	15:36	197,15	24,23
06.02.23	19,88	2.134	107,37	11:37	203,67	17,71	0:00	197,98	23,41
07.02.23	21,76	2.214	101,74	10:37	202,77	18,62	21:22	197,73	23,65
08.02.23	24,00	2.398	99,92	---	---	---	20:19	197,36	24,02
09.02.23	23,64	2.304	97,47	---	---	---	23:42	197,05	24,34
10.02.23	24,00	2.359	98,29	---	---	---	21:40	196,95	24,44
11.02.23	16,16	1.616	99,99	23:59	202,58	18,81	2:56	196,95	24,43
12.02.23	5,77	654	113,33	7:33	203,34	18,04	17:01	199,29	22,09
13.02.23	9,87	1.095	110,90	9:54	203,46	17,92	19:05	199,38	22,00
14.02.23	10,92	1.227	112,40	7:06	203,49	17,90	19:36	199,51	21,88
15.02.23	11,30	1.273	112,62	16:51	203,65	17,73	1:29	199,51	21,88
16.02.23	11,46	1.290	112,52	8:27	203,62	17,76	0:22	199,65	21,73
17.02.23	12,79	1.445	112,99	9:10	203,73	17,65	21:14	199,68	21,70
18.02.23	15,78	1.730	109,61	6:41	204,00	17,38	21:54	198,89	22,49
19.02.23	24,00	2.611	108,79	---	---	---	10:04	198,59	22,79
20.02.23	24,00	2.569	107,04	---	---	---	5:09	198,07	23,31
21.02.23	21,45	2.289	106,70	11:06	202,92	18,46	5:32	197,89	23,50
22.02.23	23,20	2.523	108,75	---	---	---	2:49	197,92	23,47
23.02.23	24,00	2.549	106,21	---	---	---	5:25	197,92	23,47
24.02.23	24,00	2.497	104,04	---	---	---	20:27	198,13	23,25
25.02.23	24,00	2.503	104,29	---	---	---	8:13	197,59	23,79
26.02.23	24,00	2.506	104,42	---	---	---	7:46	197,43	23,95
27.02.23	24,00	2.496	104,00	---	---	---	0:44	197,35	24,03
28.02.23	21,77	2.247	103,20	9:29	202,71	18,68	6:25	197,36	24,02
Σ	559,27	58.545							
Mittelwert	19,97	2.091	104,68		203,33	18,05		198,05	23,33
Minimum	5,77	654	97,47		202,58	17,38		196,95	21,70
Maximum	24,00	2.611	113,33		204,00	18,81		199,68	24,44

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom Februar 2023
gedruckt am: 14.03.2023, 15:16 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.02.23	24,00	2.265	94,38	---	---	---	11:58	199,01	26,83
02.02.23	24,00	2.283	95,13	---	---	---	0:18	199,01	26,83
03.02.23	24,00	2.319	96,63	---	---	---	2:54	199,01	26,83
04.02.23	24,00	2.307	96,13	---	---	---	18:47	199,01	26,83
05.02.23	15,38	1.464	95,21	23:55	204,23	21,61	0:43	199,01	26,83
06.02.23	6,84	630	92,14	11:41	205,72	20,12	23:13	199,40	26,44
07.02.23	18,14	1.717	94,65	10:34	204,26	21,58	20:20	199,01	26,83
08.02.23	24,00	2.268	94,50	---	---	---	0:10	199,01	26,83
09.02.23	24,00	2.245	93,54	---	---	---	0:09	199,01	26,83
10.02.23	24,00	2.257	94,04	---	---	---	0:00	199,01	26,83
11.02.23	12,51	1.171	93,60	23:59	203,82	22,02	0:00	199,01	26,83
12.02.23	0,00	0	---	6:49	204,99	20,86	---	---	---
13.02.23	0,00	0	---	9:53	204,91	20,93	---	---	---
14.02.23	3,76	372	98,86	6:55	204,97	20,87	9:31	200,79	25,06
15.02.23	0,00	0	---	16:53	205,17	20,67	---	---	---
16.02.23	0,00	0	---	8:35	205,16	20,68	---	---	---
17.02.23	0,03	4	128,57	11:51	205,27	20,57	---	---	---
18.02.23	14,31	1.407	98,33	5:57	205,77	20,07	21:48	200,27	25,57
19.02.23	22,31	2.182	97,79	---	---	---	23:53	199,94	25,90
20.02.23	21,84	2.124	97,24	7:59	204,43	21,41	4:59	199,72	26,13
21.02.23	19,37	1.878	96,93	11:39	204,19	21,66	5:23	199,60	26,25
22.02.23	18,26	1.778	97,39	7:58	204,87	20,98	2:38	199,60	26,25
23.02.23	22,04	2.140	97,11	9:14	204,26	21,58	5:17	199,69	26,16
24.02.23	24,00	2.320	96,67	---	---	---	23:15	199,60	26,25
25.02.23	23,64	2.286	96,72	---	---	---	8:04	199,39	26,45
26.02.23	23,66	2.292	96,87	---	---	---	7:35	199,25	26,59
27.02.23	21,96	2.119	96,51	6:27	203,73	22,12	0:35	199,19	26,65
28.02.23	20,86	2.006	96,16	9:29	204,22	21,63	6:16	199,18	26,67
Σ	456,91	43.834							
Mittelwert	16,32	1.566	95,94		204,70	21,14		199,38	26,46
Minimum	0,00	0	92,14		203,73	20,07		199,01	25,06
Maximum	24,00	2.320	128,57		205,77	22,12		200,79	26,83

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom Februar 2023
gedruckt am: 14.03.2023, 15:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.02.23	11,31	1.124	99,34	10:18	200,46	30,95	23:57	195,72	35,69
02.02.23	4,66	451	96,82	22:54	200,42	30,99	0:32	195,68	35,73
03.02.23	0,00	0	---	12:48	200,57	30,84	---	---	---
04.02.23	2,72	280	102,76	7:04	200,56	30,85	18:26	196,15	35,26
05.02.23	5,18	524	101,19	23:56	201,08	30,33	20:00	196,01	35,40
06.02.23	11,89	1.247	104,86	11:37	201,80	29,61	23:44	195,65	35,76
07.02.23	14,93	1.525	102,14	10:38	200,80	30,61	0:00	195,66	35,75
08.02.23	10,36	1.025	98,96	7:31	200,40	31,01	23:59	195,78	35,63
09.02.23	13,24	1.295	97,79	5:42	200,21	31,20	16:22	195,59	35,82
10.02.23	10,32	1.026	99,46	6:47	200,18	31,23	20:49	195,62	35,79
11.02.23	16,38	1.731	105,71	9:28	200,20	31,21	13:44	195,27	36,14
12.02.23	19,85	2.220	111,86	6:41	201,30	30,11	2:47	195,88	35,54
13.02.23	24,00	2.666	111,08	---	---	---	22:26	196,04	35,38
14.02.23	20,29	2.245	110,64	11:02	201,25	30,17	0:00	196,06	35,35
15.02.23	24,00	2.666	111,08	---	---	---	2:24	196,08	35,33
16.02.23	24,00	2.665	111,04	---	---	---	1:28	196,11	35,30
17.02.23	24,00	2.659	110,79	---	---	---	21:55	196,11	35,30
18.02.23	7,87	873	110,86	5:45	201,43	29,98	0:44	196,15	35,26
19.02.23	0,00	0	---	10:40	201,13	30,28	---	---	---
20.02.23	0,00	0	---	8:12	201,13	30,28	---	---	---
21.02.23	3,90	409	104,89	6:40	200,93	30,48	11:17	195,83	35,58
22.02.23	0,00	0	---	8:03	201,38	30,03	---	---	---
23.02.23	0,00	0	---	9:23	201,07	30,34	---	---	---
24.02.23	0,00	0	---	0:00	200,78	30,63	---	---	---
25.02.23	0,00	0	---	8:43	200,74	30,68	---	---	---
26.02.23	0,00	0	---	8:12	200,66	30,75	---	---	---
27.02.23	0,00	0	---	6:44	200,82	30,59	---	---	---
28.02.23	2,33	234	100,49	9:32	200,90	30,52	11:26	195,88	35,54
Σ	251,23	26.865							
Mittelwert	8,97	959	106,93		200,84	30,57		195,86	35,55
Minimum	0,00	0	96,82		200,18	29,61		195,27	35,26
Maximum	24,00	2.666	111,86		201,80	31,23		196,15	36,14

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom Februar 2023
gedruckt am: 14.03.2023, 15:16 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.02.23	24,00	2.117	88,21	---	---	---	19:02	203,18	28,88
02.02.23	24,00	2.159	89,96	---	---	---	3:25	203,01	29,04
03.02.23	22,82	2.066	90,55	---	---	---	3:02	203,18	28,88
04.02.23	24,00	2.178	90,75	---	---	---	21:13	203,13	28,92
05.02.23	15,35	1.375	89,56	23:57	212,45	19,60	3:40	203,01	29,04
06.02.23	6,69	586	87,60	11:37	213,57	18,48	23:11	205,03	27,03
07.02.23	18,50	1.658	89,60	3:40	212,12	19,93	21:45	203,34	28,72
08.02.23	24,00	2.139	89,13	---	---	---	20:06	203,01	29,04
09.02.23	24,00	2.118	88,25	---	---	---	1:22	203,00	29,05
10.02.23	24,00	2.129	88,71	---	---	---	0:06	203,01	29,04
11.02.23	12,49	1.100	88,10	23:59	212,20	19,85	2:44	203,01	29,04
12.02.23	0,00	0	---	22:56	213,08	18,97	---	---	---
13.02.23	0,00	0	---	15:40	213,19	18,87	---	---	---
14.02.23	2,79	260	93,28	6:30	213,25	18,80	11:12	205,95	26,10
15.02.23	0,00	0	---	22:43	213,41	18,64	---	---	---
16.02.23	0,00	0	---	11:13	213,47	18,58	---	---	---
17.02.23	0,00	0	---	14:18	213,56	18,49	---	---	---
18.02.23	14,23	1.318	92,61	6:22	213,71	18,34	21:43	204,41	27,64
19.02.23	22,11	2.042	92,34	---	---	---	23:51	203,86	28,19
20.02.23	21,74	1.999	91,94	8:02	211,27	20,78	21:54	203,74	28,31
21.02.23	21,67	1.995	92,06	6:23	210,29	21,76	3:39	203,64	28,41
22.02.23	18,06	1.676	92,82	8:02	212,30	19,75	1:42	203,65	28,40
23.02.23	21,89	2.022	92,39	9:16	210,98	21,08	23:55	203,64	28,41
24.02.23	24,00	2.206	91,92	---	---	---	23:21	203,52	28,53
25.02.23	23,58	2.167	91,88	---	---	---	20:54	203,46	28,59
26.02.23	23,61	2.171	91,95	---	---	---	20:22	203,31	28,74
27.02.23	21,81	2.007	92,04	6:31	210,44	21,61	0:26	203,33	28,72
28.02.23	21,78	1.997	91,70	9:34	210,16	21,90	4:31	203,27	28,78
Σ	457,12	41.485							
Mittelwert	16,33	1.482	90,75		212,32	19,73		203,55	28,50
Minimum	0,00	0	87,60		210,16	18,34		203,00	26,10
Maximum	24,00	2.206	93,28		213,71	21,90		205,95	29,05

Meßpunkthöhe (MP): 232,05 m üNN