

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom Mai 2023
gedruckt am: 03.06.2023, 03:21 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.05.23	0,00	0	---	---	---	---	---	---	---
02.05.23	0,00	0	---	---	---	---	---	---	---
03.05.23	0,00	0	---	---	---	---	---	---	---
04.05.23	0,00	0	---	---	---	---	---	---	---
05.05.23	0,00	0	---	---	---	---	---	---	---
06.05.23	0,00	0	---	---	---	---	---	---	---
07.05.23	0,00	0	---	---	---	---	---	---	---
08.05.23	0,00	0	---	---	---	---	---	---	---
09.05.23	0,00	0	---	---	---	---	---	---	---
10.05.23	0,00	0	---	---	---	---	---	---	---
11.05.23	0,00	0	---	---	---	---	---	---	---
12.05.23	0,00	0	---	---	---	---	---	---	---
13.05.23	0,00	0	---	---	---	---	---	---	---
14.05.23	0,00	0	---	---	---	---	---	---	---
15.05.23	12,93	1.325	102,46	---	---	---	23:45	196,52	17,75
16.05.23	24,00	2.450	102,08	---	---	---	23:42	196,27	18,00
17.05.23	24,00	2.448	102,00	---	---	---	3:26	196,23	18,04
18.05.23	24,00	2.471	102,96	---	---	---	0:24	196,42	17,85
19.05.23	24,00	2.472	103,00	---	---	---	21:17	196,66	17,62
20.05.23	24,00	2.474	103,08	---	---	---	2:39	196,72	17,56
21.05.23	24,00	2.476	103,17	---	---	---	12:13	196,77	17,50
22.05.23	24,00	2.470	102,92	---	---	---	22:56	196,76	17,52
23.05.23	24,00	2.464	102,67	---	---	---	14:40	196,54	17,73
24.05.23	22,65	2.329	102,80	---	---	---	17:51	196,64	17,63
25.05.23	23,40	2.408	102,89	---	---	---	14:58	196,73	17,54
26.05.23	24,00	2.473	103,04	---	---	---	21:00	196,69	17,59
27.05.23	24,00	2.468	102,83	---	---	---	1:56	196,69	17,59
28.05.23	24,00	2.478	103,25	---	---	---	20:51	196,79	17,49
29.05.23	24,00	2.471	102,96	---	---	---	22:24	196,75	17,52
30.05.23	11,41	1.177	103,16	11:39	201,88	12,40	8:29	196,82	17,46
31.05.23	11,14	1.135	101,89	7:00	201,33	12,94	11:31	196,61	17,66
Σ	369,54	37.989							
Mittelwert	11,92	1.225	102,80		201,60	12,67		196,62	17,65
Minimum	0,00	0	101,89		201,33	12,40		196,23	17,46
Maximum	24,00	2.478	103,25		201,88	12,94		196,82	18,04

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom Mai 2023
gedruckt am: 03.06.2023, 03:21 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.23	13,24	1.870	141,28	7:48	203,35	10,87	0:44	198,95	15,27
02.05.23	17,78	2.536	142,61	5:40	203,08	11,14	11:10	198,89	15,33
03.05.23	19,36	2.708	139,89	19:07	202,87	11,35	12:32	198,83	15,39
04.05.23	19,51	2.743	140,62	15:06	202,85	11,37	12:57	198,82	15,40
05.05.23	13,33	1.887	141,56	15:09	203,11	11,11	1:54	198,88	15,34
06.05.23	20,20	2.827	139,92	4:51	203,01	11,21	23:29	198,83	15,39
07.05.23	15,66	2.223	141,97	8:53	203,23	10,99	21:00	198,92	15,30
08.05.23	15,87	2.233	140,72	7:30	203,16	11,06	2:16	198,89	15,33
09.05.23	12,40	1.778	143,42	19:29	203,65	10,57	8:32	198,89	15,33
10.05.23	21,56	3.021	140,10	9:19	202,92	11,30	13:30	198,91	15,31
11.05.23	17,86	2.511	140,57	9:42	202,95	11,27	4:34	198,86	15,36
12.05.23	21,77	3.052	140,19	7:48	202,87	11,35	5:35	198,84	15,38
13.05.23	22,14	3.097	139,87	5:31	202,66	11,56	4:24	198,78	15,44
14.05.23	15,07	2.118	140,55	9:56	203,07	11,15	1:16	198,74	15,48
15.05.23	19,99	2.770	138,57	3:03	202,86	11,36	23:59	198,65	15,57
16.05.23	19,51	2.676	137,19	6:57	202,72	11,50	23:52	198,62	15,60
17.05.23	18,04	2.472	137,05	20:48	202,78	11,44	3:25	198,50	15,72
18.05.23	6,30	873	138,66	18:11	203,19	11,03	0:18	198,97	15,25
19.05.23	7,77	1.088	140,05	7:14	203,32	10,90	21:08	199,31	14,91
20.05.23	6,40	906	141,57	22:47	203,42	10,80	2:31	199,41	14,81
21.05.23	7,42	1.051	141,59	6:23	203,50	10,72	12:06	199,46	14,76
22.05.23	8,80	1.237	140,52	7:54	203,50	10,72	22:50	199,41	14,81
23.05.23	10,04	1.385	137,98	8:04	203,42	10,80	14:05	199,24	14,98
24.05.23	9,49	1.333	140,50	5:42	203,41	10,81	17:03	199,33	14,89
25.05.23	8,55	1.215	142,12	8:47	203,53	10,69	14:52	199,39	14,83
26.05.23	7,79	1.097	140,89	11:33	203,49	10,73	20:57	199,38	14,84
27.05.23	10,19	1.423	139,70	7:39	203,40	10,82	1:53	199,37	14,85
28.05.23	5,49	778	141,74	9:30	203,54	10,68	20:45	199,51	14,71
29.05.23	8,42	1.189	141,17	10:46	203,55	10,67	22:20	199,47	14,75
30.05.23	11,31	1.604	141,85	11:35	203,64	10,58	16:42	199,26	14,96
31.05.23	24,00	3.297	137,38	---	---	---	17:17	198,79	15,43
Σ	435,24	60.998							
Mittelwert	14,04	1.968	140,15		203,20	11,02		199,04	15,18
Minimum	5,49	778	137,05		202,66	10,57		198,50	14,71
Maximum	24,00	3.297	143,42		203,65	11,56		199,51	15,72

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom Mai 2023
gedruckt am: 03.06.2023, 03:21 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.05.23	20,34	1.936	95,16	7:46	203,75	16,37	0:45	201,28	18,84
02.05.23	24,00	2.275	94,79	---	---	---	18:11	201,27	18,85
03.05.23	24,00	2.252	93,83	---	---	---	12:33	201,15	18,97
04.05.23	24,00	2.258	94,08	---	---	---	12:59	201,13	18,99
05.05.23	24,00	2.285	95,21	---	---	---	1:56	201,19	18,93
06.05.23	24,00	2.254	93,92	---	---	---	23:30	201,15	18,97
07.05.23	22,02	2.083	94,60	8:50	203,61	16,51	3:00	201,23	18,89
08.05.23	21,58	2.036	94,33	7:27	203,54	16,58	2:17	201,21	18,91
09.05.23	12,10	1.142	94,40	19:35	204,08	16,04	1:48	201,24	18,88
10.05.23	24,00	2.244	93,50	---	---	---	13:31	201,30	18,82
11.05.23	24,00	2.263	94,29	---	---	---	4:35	201,18	18,94
12.05.23	20,75	1.942	93,60	10:06	213,99	6,13	5:36	201,16	18,96
13.05.23	24,00	2.243	93,46	---	---	---	4:26	201,07	19,05
14.05.23	22,01	2.080	94,49	7:19	203,40	16,72	1:17	201,03	19,09
15.05.23	23,30	2.177	93,42	---	---	---	23:59	201,01	19,11
16.05.23	18,36	1.701	92,66	6:57	203,17	16,95	23:47	200,92	19,20
17.05.23	4,27	384	90,02	20:51	203,29	16,83	3:22	200,87	19,25
18.05.23	0,00	0	---	18:15	203,67	16,45	---	---	---
19.05.23	0,43	40	92,19	6:35	203,80	16,32	---	---	---
20.05.23	0,00	0	---	22:39	203,90	16,22	---	---	---
21.05.23	0,00	0	---	6:37	203,98	16,14	---	---	---
22.05.23	1,53	140	91,24	7:59	203,99	16,13	---	---	---
23.05.23	5,82	532	91,37	8:12	203,92	16,20	14:09	201,45	18,67
24.05.23	1,47	136	92,60	5:49	203,89	16,23	---	---	---
25.05.23	0,51	47	92,06	8:49	203,98	16,14	---	---	---
26.05.23	0,00	0	---	12:04	203,98	16,14	---	---	---
27.05.23	0,00	0	---	7:40	203,89	16,23	---	---	---
28.05.23	0,00	0	---	9:16	204,03	16,09	---	---	---
29.05.23	0,00	0	---	10:56	204,04	16,08	---	---	---
30.05.23	13,05	1.231	94,32	11:37	204,06	16,06	22:20	201,54	18,58
31.05.23	24,00	2.211	92,13	---	---	---	22:29	201,10	19,02
Σ	403,56	37.892							
Mittelwert	13,02	1.222	93,89		204,28	15,84		201,17	18,95
Minimum	0,00	0	90,02		203,17	6,13		200,87	18,58
Maximum	24,00	2.285	95,21		213,99	16,95		201,54	19,25

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom Mai 2023

gedruckt am: 03.06.2023, 03:21 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.23	0,00	0	---	9:37	203,64	17,74	---	---	---
02.05.23	3,94	431	109,48	12:24	203,67	17,71	11:07	199,79	21,59
03.05.23	3,73	366	98,20	19:01	203,26	18,12	---	---	---
04.05.23	0,51	50	98,36	15:06	203,23	18,15	---	---	---
05.05.23	0,00	0	---	15:03	203,61	17,78	---	---	---
06.05.23	2,80	275	98,30	4:49	203,52	17,87	11:59	199,99	21,40
07.05.23	1,29	128	99,01	9:16	203,53	17,85	---	---	---
08.05.23	3,02	297	98,19	8:37	203,52	17,87	23:51	199,86	21,52
09.05.23	10,63	1.191	112,05	10:45	203,65	17,73	8:23	199,30	22,08
10.05.23	5,21	514	98,69	9:15	203,25	18,13	20:21	199,62	21,76
11.05.23	2,45	231	94,30	17:42	203,26	18,12	21:39	199,83	21,55
12.05.23	4,64	468	100,80	7:45	203,19	18,19	13:05	199,40	21,98
13.05.23	1,89	177	93,50	5:37	202,87	18,52	---	---	---
14.05.23	2,26	222	98,24	9:59	203,35	18,03	---	---	---
15.05.23	4,13	415	100,55	3:03	203,16	18,23	12:59	199,34	22,04
16.05.23	2,45	238	97,29	6:54	203,25	18,13	13:58	199,83	21,55
17.05.23	19,73	1.996	101,17	0:00	202,81	18,57	19:18	197,87	23,51
18.05.23	23,12	2.472	106,91	---	---	---	0:41	197,68	23,70
19.05.23	23,17	2.463	106,28	---	---	---	21:34	197,79	23,60
20.05.23	23,08	2.475	107,24	---	---	---	2:59	197,85	23,54
21.05.23	21,51	2.301	106,98	3:51	202,64	18,75	14:41	198,09	23,29
22.05.23	22,94	2.426	105,75	3:18	202,56	18,82	23:22	197,93	23,45
23.05.23	23,01	2.378	103,37	---	---	---	14:59	197,63	23,75
24.05.23	22,40	2.333	104,13	---	---	---	12:03	197,96	23,42
25.05.23	23,30	2.444	104,87	---	---	---	18:18	197,83	23,55
26.05.23	23,04	2.448	106,23	---	---	---	0:50	197,73	23,66
27.05.23	24,00	2.506	104,42	---	---	---	2:14	197,68	23,70
28.05.23	21,26	2.296	107,98	---	---	---	0:00	197,82	23,57
29.05.23	22,95	2.441	106,36	3:49	202,58	18,81	22:45	197,91	23,47
30.05.23	21,83	2.313	105,96	11:37	202,89	18,49	0:00	198,03	23,35
31.05.23	24,00	2.333	97,21	---	---	---	17:45	198,05	23,34
Σ	388,30	40.628							
Mittelwert	12,53	1.311	104,63		203,21	18,17		198,53	22,85
Minimum	0,00	0	93,50		202,56	17,71		197,63	21,40
Maximum	24,00	2.506	112,05		203,67	18,82		199,99	23,75

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom Mai 2023
gedruckt am: 03.06.2023, 03:21 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.23	13,39	1.261	94,19	9:51	204,52	21,32	0:44	199,51	26,33
02.05.23	14,85	1.414	95,20	11:06	204,93	20,92	23:58	199,78	26,06
03.05.23	19,46	1.826	93,85	19:05	203,93	21,92	12:32	199,31	26,53
04.05.23	19,61	1.846	94,15	15:08	203,83	22,01	12:58	199,25	26,59
05.05.23	13,49	1.279	94,78	15:10	204,45	21,39	1:55	199,36	26,48
06.05.23	20,29	1.901	93,69	4:52	204,24	21,60	23:29	199,23	26,61
07.05.23	15,81	1.499	94,83	9:12	204,33	21,51	2:59	199,42	26,42
08.05.23	16,00	1.505	94,04	16:44	204,25	21,59	2:16	199,38	26,46
09.05.23	9,28	873	94,05	12:38	205,09	20,75	1:47	199,37	26,48
10.05.23	21,63	2.024	93,58	9:18	203,86	21,99	22:19	199,27	26,57
11.05.23	18,00	1.690	93,91	9:40	203,91	21,93	4:35	199,14	26,71
12.05.23	21,80	2.041	93,62	7:44	203,80	22,04	19:18	199,08	26,77
13.05.23	22,21	2.081	93,70	5:30	203,30	22,54	4:25	199,02	26,82
14.05.23	15,20	1.428	93,92	10:02	204,15	21,70	1:16	199,03	26,81
15.05.23	20,16	1.898	94,17	3:02	203,77	22,08	1:24	199,29	26,55
16.05.23	19,57	1.834	93,72	6:54	203,99	21,86	0:00	199,32	26,52
17.05.23	18,14	1.669	92,02	9:15	203,15	22,70	6:58	199,02	26,83
18.05.23	6,48	591	91,22	18:10	203,42	22,42	8:54	199,02	26,82
19.05.23	7,87	725	92,12	7:09	203,79	22,05	21:08	199,03	26,81
20.05.23	6,57	608	92,60	17:05	203,64	22,20	2:31	199,05	26,80
21.05.23	7,58	703	92,70	4:03	203,90	21,95	12:07	199,27	26,57
22.05.23	9,00	830	92,19	7:42	203,80	22,04	22:51	199,12	26,72
23.05.23	10,13	924	91,24	8:19	203,55	22,29	14:13	199,03	26,81
24.05.23	9,69	895	92,41	5:47	203,64	22,20	15:59	199,03	26,81
25.05.23	8,67	807	93,09	8:48	203,86	21,98	18:04	199,03	26,81
26.05.23	7,89	728	92,29	12:10	203,76	22,08	0:36	199,03	26,81
27.05.23	10,30	941	91,35	7:51	203,44	22,40	1:48	199,03	26,81
28.05.23	5,59	518	92,66	9:46	203,90	21,95	20:47	199,24	26,60
29.05.23	8,52	787	92,35	10:25	203,85	21,99	22:21	199,11	26,74
30.05.23	11,36	1.083	95,35	18:33	204,32	21,53	16:43	199,68	26,16
31.05.23	24,00	2.246	93,58	---	---	---	12:18	199,03	26,81
Σ	432,53	40.455							
Mittelwert	13,95	1.305	93,53		203,94	21,90		199,21	26,63
Minimum	5,59	518	91,22		203,15	20,75		199,02	26,06
Maximum	24,00	2.246	95,35		205,09	22,70		199,78	26,83

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom Mai 2023
gedruckt am: 03.06.2023, 03:21 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.05.23	24,00	2.531	105,46	---	---	---	0:54	195,22	36,19
02.05.23	20,27	2.106	103,87	11:17	201,28	30,13	3:31	195,36	36,06
03.05.23	24,00	2.441	101,71	---	---	---	12:48	195,14	36,28
04.05.23	24,00	2.447	101,96	---	---	---	13:09	195,10	36,32
05.05.23	24,00	2.524	105,17	---	---	---	2:08	195,15	36,26
06.05.23	24,00	2.436	101,50	---	---	---	23:44	195,05	36,36
07.05.23	24,00	2.491	103,79	---	---	---	0:00	195,07	36,35
08.05.23	23,49	2.433	103,56	---	---	---	2:26	195,12	36,29
09.05.23	18,97	2.010	105,95	12:35	201,35	30,06	1:55	195,18	36,23
10.05.23	24,00	2.415	100,63	---	---	---	13:48	195,23	36,19
11.05.23	24,00	2.461	102,54	---	---	---	4:47	195,07	36,35
12.05.23	24,00	2.409	100,38	---	---	---	5:59	195,10	36,32
13.05.23	24,00	2.404	100,17	---	---	---	4:36	194,96	36,45
14.05.23	24,00	2.491	103,79	---	---	---	1:29	194,96	36,45
15.05.23	20,94	2.123	101,39	13:44	200,65	30,76	1:39	195,12	36,29
16.05.23	24,00	2.449	102,04	---	---	---	11:57	195,26	36,15
17.05.23	24,00	2.416	100,67	---	---	---	19:16	194,99	36,42
18.05.23	24,00	2.554	106,42	---	---	---	0:35	194,97	36,45
19.05.23	24,00	2.542	105,92	---	---	---	21:29	195,14	36,27
20.05.23	24,00	2.559	106,63	---	---	---	2:59	195,21	36,20
21.05.23	24,00	2.552	106,33	---	---	---	14:50	195,21	36,20
22.05.23	24,00	2.530	105,42	---	---	---	23:11	195,20	36,21
23.05.23	24,00	2.502	104,25	---	---	---	14:49	195,04	36,37
24.05.23	22,64	2.341	103,39	---	---	---	8:05	195,26	36,16
25.05.23	23,40	2.442	104,34	---	---	---	18:17	195,22	36,19
26.05.23	24,00	2.542	105,92	---	---	---	0:52	195,14	36,27
27.05.23	24,00	2.507	104,46	---	---	---	2:11	195,12	36,29
28.05.23	24,00	2.574	107,25	---	---	---	0:00	195,21	36,20
29.05.23	24,00	2.535	105,63	---	---	---	22:44	195,20	36,21
30.05.23	14,26	1.527	107,10	18:43	201,01	30,40	0:00	195,27	36,14
31.05.23	9,60	936	97,52	6:47	200,62	30,79	11:32	195,91	35,51
Σ	705,58	73.230							
Mittelwert	22,76	2.362	103,79		200,98	30,43		195,17	36,24
Minimum	9,60	936	97,52		200,62	30,06		194,96	35,51
Maximum	24,00	2.574	107,25		201,35	30,79		195,91	36,45

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom Mai 2023

gedruckt am: 03.06.2023, 03:21 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.23	13,16	1.174	89,22	9:52	212,14	19,91	0:42	203,83	28,22
02.05.23	14,20	1.284	90,42	12:12	212,63	19,42	23:42	203,88	28,17
03.05.23	19,31	1.715	88,83	19:07	210,68	21,38	12:27	203,46	28,59
04.05.23	19,46	1.734	89,11	15:09	210,56	21,49	12:33	203,34	28,71
05.05.23	12,94	1.161	89,75	15:14	211,97	20,08	1:50	203,49	28,56
06.05.23	20,16	1.786	88,58	4:55	211,26	20,79	23:20	203,27	28,79
07.05.23	15,58	1.396	89,62	9:17	211,79	20,26	20:59	203,70	28,35
08.05.23	15,80	1.414	89,48	7:56	211,43	20,62	2:09	203,57	28,49
09.05.23	9,27	836	90,21	19:29	212,97	19,08	1:39	203,58	28,47
10.05.23	21,53	1.915	88,95	14:54	210,39	21,67	23:24	203,40	28,65
11.05.23	17,80	1.588	89,23	9:46	210,95	21,11	4:14	203,27	28,79
12.05.23	21,75	1.928	88,63	7:49	210,59	21,47	23:21	203,11	28,95
13.05.23	22,11	1.959	88,62	5:32	209,55	22,51	23:52	203,05	29,01
14.05.23	15,00	1.338	89,19	10:06	211,73	20,32	0:49	203,03	29,02
15.05.23	17,58	1.558	88,64	13:45	211,36	20,69	1:20	203,66	28,40
16.05.23	17,28	1.539	89,08	7:16	211,29	20,76	23:42	203,37	28,68
17.05.23	17,98	1.581	87,91	20:51	210,39	21,66	6:39	203,21	28,85
18.05.23	6,20	547	88,19	18:17	212,08	19,98	0:17	203,73	28,33
19.05.23	7,72	687	89,03	7:11	212,45	19,60	21:05	204,43	27,62
20.05.23	6,31	566	89,63	17:06	212,35	19,71	2:29	205,09	26,96
21.05.23	7,33	657	89,62	6:54	212,63	19,42	12:05	204,90	27,15
22.05.23	8,70	780	89,65	8:03	212,49	19,56	22:48	204,70	27,36
23.05.23	9,97	885	88,75	8:21	212,16	19,89	14:35	204,01	28,04
24.05.23	15,44	1.402	90,79	5:58	212,41	19,65	18:27	203,16	28,89
25.05.23	12,17	1.090	89,57	8:50	211,67	20,38	3:26	203,14	28,92
26.05.23	7,74	690	89,18	12:15	212,54	19,52	20:53	204,25	27,80
27.05.23	10,12	896	88,50	7:52	212,03	20,02	1:53	204,32	27,73
28.05.23	5,44	488	89,71	9:46	212,60	19,46	20:44	204,88	27,17
29.05.23	8,37	749	89,48	10:44	212,61	19,44	22:18	204,67	27,39
30.05.23	11,02	1.022	92,73	11:35	212,52	19,53	23:26	204,16	27,89
31.05.23	24,00	2.158	89,92	---	---	---	20:37	203,18	28,88
Σ	431,43	38.523							
Mittelwert	13,92	1.243	89,29		211,74	20,31		203,77	28,28
Minimum	5,44	488	87,91		209,55	19,08		203,03	26,96
Maximum	24,00	2.158	92,73		212,97	22,51		205,09	29,02

Meßpunkthöhe (MP): 232,05 m üNN