

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB02
Monatsbericht vom Juli 2023
gedruckt am: 03.08.2023, 22:20 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.07.23	24,00	1.749	72,88	---	---	---	5:48	194,88	20,22
02.07.23	24,00	1.747	72,79	---	---	---	4:14	194,87	20,22
03.07.23	24,00	1.727	71,96	---	---	---	3:31	194,89	20,20
04.07.23	23,30	1.674	71,86	---	---	---	13:10	194,86	20,23
05.07.23	24,00	1.731	72,13	---	---	---	15:18	194,88	20,22
06.07.23	24,00	1.726	71,92	---	---	---	6:43	194,85	20,25
07.07.23	22,06	1.586	71,88	---	---	---	3:59	194,73	20,36
08.07.23	24,00	1.737	72,38	---	---	---	20:54	194,80	20,29
09.07.23	24,00	1.754	73,08	---	---	---	6:19	194,75	20,35
10.07.23	24,00	1.753	73,04	---	---	---	6:00	194,78	20,31
11.07.23	22,51	1.637	72,72	11:28	196,74	18,35	3:06	194,76	20,33
12.07.23	24,00	1.732	72,17	---	---	---	8:57	194,75	20,35
13.07.23	22,02	1.594	72,40	12:24	196,73	18,36	1:39	194,75	20,35
14.07.23	24,00	1.737	72,38	---	---	---	6:26	194,75	20,35
15.07.23	22,46	1.639	72,99	23:50	196,71	18,38	21:28	194,69	20,41
16.07.23	22,29	1.680	75,36	1:30	196,83	18,26	8:35	194,81	20,28
17.07.23	23,38	1.710	73,13	---	---	---	13:43	194,76	20,33
18.07.23	21,21	1.553	73,23	12:39	196,82	18,27	8:14	194,75	20,35
19.07.23	24,00	1.753	73,04	---	---	---	5:44	194,79	20,30
20.07.23	24,00	1.742	72,58	---	---	---	13:53	194,74	20,35
21.07.23	24,00	1.746	72,75	---	---	---	2:47	194,75	20,35
22.07.23	24,00	1.738	72,42	---	---	---	7:03	194,72	20,38
23.07.23	24,00	1.747	72,79	---	---	---	9:22	194,73	20,36
24.07.23	24,00	1.740	72,50	---	---	---	15:08	194,73	20,36
25.07.23	24,00	1.751	72,96	---	---	---	20:58	194,70	20,39
26.07.23	24,00	1.750	72,92	---	---	---	5:51	194,67	20,42
27.07.23	24,00	1.728	72,00	---	---	---	0:00	194,69	20,41
28.07.23	24,00	1.735	72,29	---	---	---	21:16	194,66	20,44
29.07.23	24,00	1.743	72,63	---	---	---	22:38	194,64	20,45
30.07.23	24,00	1.738	72,42	---	---	---	0:00	194,64	20,45
31.07.23	24,00	1.729	72,04	---	---	---	16:53	194,64	20,45
Σ	731,23	53.106							
Mittelwert	23,59	1.713	72,63		196,77	18,32		194,75	20,34
Minimum	21,21	1.553	71,86		196,71	18,26		194,64	20,20
Maximum	24,00	1.754	75,36		196,83	18,38		194,89	20,45

Meßpunkthöhe (MP): 215,09 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB05
Monatsbericht vom Juli 2023
gedruckt am: 03.08.2023, 22:20 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.07.23	24,00	521	21,71	---	---	---	5:25	195,38	14,20
02.07.23	24,00	521	21,71	---	---	---	3:58	195,38	14,20
03.07.23	24,00	515	21,46	---	---	---	3:33	195,40	14,18
04.07.23	23,28	498	21,39	---	---	---	13:09	195,38	14,20
05.07.23	24,00	511	21,29	---	---	---	15:47	195,45	14,14
06.07.23	24,00	508	21,17	---	---	---	6:19	195,42	14,17
07.07.23	22,16	466	21,03	---	---	---	3:58	195,38	14,20
08.07.23	24,00	503	20,96	---	---	---	11:21	195,45	14,14
09.07.23	24,00	507	21,13	---	---	---	5:15	195,42	14,16
10.07.23	24,00	505	21,04	---	---	---	1:18	195,51	14,08
11.07.23	22,50	481	21,38	11:28	196,50	13,08	19:57	195,50	14,08
12.07.23	24,00	515	21,46	---	---	---	8:57	195,42	14,17
13.07.23	22,00	472	21,45	12:26	196,43	13,15	9:56	195,35	14,23
14.07.23	24,00	512	21,33	---	---	---	6:27	195,37	14,21
15.07.23	22,45	483	21,52	23:56	196,42	13,16	22:20	195,34	14,25
16.07.23	22,28	495	22,21	1:36	196,55	13,03	23:24	195,43	14,15
17.07.23	23,37	501	21,44	---	---	---	13:43	195,37	14,21
18.07.23	21,20	451	21,28	12:39	196,47	13,11	8:09	195,37	14,21
19.07.23	24,00	507	21,13	---	---	---	15:22	195,38	14,20
20.07.23	24,00	503	20,96	---	---	---	13:41	195,37	14,21
21.07.23	24,00	503	20,96	---	---	---	23:25	195,38	14,20
22.07.23	24,00	503	20,96	---	---	---	8:01	195,35	14,24
23.07.23	24,00	504	21,00	---	---	---	12:23	195,34	14,25
24.07.23	24,00	503	20,96	---	---	---	0:24	195,37	14,21
25.07.23	24,00	504	21,00	---	---	---	17:17	195,31	14,27
26.07.23	24,00	506	21,08	---	---	---	18:13	195,28	14,30
27.07.23	24,00	500	20,83	---	---	---	5:00	195,30	14,28
28.07.23	24,00	502	20,92	---	---	---	8:16	195,30	14,28
29.07.23	24,00	503	20,96	---	---	---	22:50	195,28	14,30
30.07.23	24,00	503	20,96	---	---	---	8:26	195,25	14,33
31.07.23	24,00	501	20,88	---	---	---	1:18	195,29	14,29
Σ	731,24	15.507							
Mittelwert	23,59	500	21,21		196,47	13,11		195,37	14,21
Minimum	21,20	451	20,83		196,42	13,03		195,25	14,08
Maximum	24,00	521	22,21		196,55	13,16		195,51	14,33

Meßpunkthöhe (MP): 209,58 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB06
Monatsbericht vom Juli 2023
gedruckt am: 03.08.2023, 22:20 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m ³	m ³ /h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.07.23	24,00	692	28,83	---	---	---	5:25	195,18	11,81
02.07.23	24,00	691	28,79	---	---	---	3:58	195,18	11,81
03.07.23	24,00	674	28,08	---	---	---	13:52	195,24	11,75
04.07.23	23,26	652	28,03	---	---	---	13:09	195,09	11,90
05.07.23	24,00	678	28,25	---	---	---	15:25	195,22	11,77
06.07.23	24,00	668	27,83	---	---	---	6:26	195,20	11,79
07.07.23	22,00	613	27,86	0:00	196,74	10,25	3:58	195,04	11,95
08.07.23	24,00	676	28,17	---	---	---	21:02	195,15	11,84
09.07.23	24,00	686	28,58	---	---	---	6:20	195,03	11,96
10.07.23	24,00	683	28,46	---	---	---	3:17	195,11	11,89
11.07.23	22,50	635	28,23	11:29	196,69	10,30	5:38	195,08	11,92
12.07.23	24,00	669	27,88	---	---	---	8:59	195,04	11,95
13.07.23	21,99	615	27,97	12:25	196,72	10,27	10:25	195,00	11,99
14.07.23	24,00	669	27,88	---	---	---	4:59	195,08	11,92
15.07.23	22,44	641	28,57	23:55	196,69	10,30	22:20	194,91	12,08
16.07.23	22,28	682	30,62	1:24	196,84	10,16	8:46	195,08	11,92
17.07.23	23,35	668	28,61	---	---	---	13:45	194,94	12,05
18.07.23	21,17	605	28,58	12:32	196,76	10,23	7:53	195,03	11,96
19.07.23	24,00	682	28,42	---	---	---	17:57	195,08	11,92
20.07.23	24,00	672	28,00	---	---	---	13:21	195,04	11,95
21.07.23	24,00	673	28,04	---	---	---	16:40	195,04	11,95
22.07.23	24,00	670	27,92	---	---	---	3:41	195,04	11,96
23.07.23	24,00	679	28,29	---	---	---	12:23	195,03	11,96
24.07.23	24,00	672	28,00	---	---	---	0:11	195,04	11,95
25.07.23	24,00	678	28,25	---	---	---	10:58	195,01	11,98
26.07.23	24,00	682	28,42	---	---	---	7:09	194,99	12,00
27.07.23	24,00	667	27,79	---	---	---	5:00	195,00	11,99
28.07.23	24,00	671	27,96	---	---	---	13:17	195,00	11,99
29.07.23	24,00	678	28,25	---	---	---	23:42	195,00	11,99
30.07.23	24,00	678	28,25	---	---	---	7:50	194,99	12,00
31.07.23	24,00	674	28,08	---	---	---	16:53	194,98	12,01
Σ	730,98	20.673							
Mittelwert	23,58	667	28,28		196,74	10,25		195,06	11,93
Minimum	21,17	605	27,79		196,69	10,16		194,91	11,75
Maximum	24,00	692	30,62		196,84	10,30		195,24	12,08

Meßpunkthöhe (MP): 206,99 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB07
Monatsbericht vom Juli 2023
gedruckt am: 03.08.2023, 22:20 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.07.23	24,00	1.345	56,04	---	---	---	5:24	194,22	8,45
02.07.23	24,00	1.345	56,04	---	---	---	12:32	194,22	8,45
03.07.23	24,00	1.337	55,71	---	---	---	8:13	194,20	8,47
04.07.23	23,24	1.296	55,76	---	---	---	13:09	194,17	8,50
05.07.23	24,00	1.339	55,79	---	---	---	23:55	194,19	8,48
06.07.23	24,00	1.337	55,71	---	---	---	5:58	194,19	8,48
07.07.23	21,96	1.221	55,60	---	---	---	3:38	194,11	8,56
08.07.23	24,00	1.336	55,67	---	---	---	20:53	194,16	8,51
09.07.23	24,00	1.339	55,79	---	---	---	6:26	194,10	8,57
10.07.23	24,00	1.338	55,75	---	---	---	3:26	194,10	8,57
11.07.23	22,48	1.254	55,77	11:25	196,19	6,48	3:42	194,11	8,56
12.07.23	24,00	1.336	55,67	---	---	---	8:59	194,09	8,58
13.07.23	21,97	1.222	55,62	12:27	196,24	6,43	10:25	194,05	8,62
14.07.23	24,00	1.332	55,50	---	---	---	7:07	194,07	8,60
15.07.23	22,43	1.246	55,55	23:58	196,22	6,45	21:36	194,04	8,63
16.07.23	22,27	1.264	56,75	1:35	196,35	6,32	23:54	194,11	8,56
17.07.23	23,33	1.301	55,77	---	---	---	13:45	194,04	8,63
18.07.23	21,16	1.182	55,86	12:36	196,27	6,40	7:43	194,05	8,62
19.07.23	24,00	1.340	55,83	---	---	---	16:07	194,07	8,60
20.07.23	24,00	1.335	55,63	---	---	---	5:45	194,04	8,63
21.07.23	24,00	1.337	55,71	---	---	---	16:37	194,05	8,62
22.07.23	24,00	1.334	55,58	---	---	---	3:14	194,04	8,63
23.07.23	24,00	1.336	55,67	---	---	---	0:00	194,04	8,63
24.07.23	24,00	1.334	55,58	---	---	---	0:53	194,02	8,65
25.07.23	24,00	1.338	55,75	---	---	---	2:06	194,01	8,66
26.07.23	24,00	1.339	55,79	---	---	---	3:41	193,99	8,68
27.07.23	24,00	1.332	55,50	---	---	---	0:58	194,01	8,66
28.07.23	24,00	1.333	55,54	---	---	---	6:00	194,02	8,65
29.07.23	24,00	1.337	55,71	---	---	---	12:44	193,99	8,68
30.07.23	24,00	1.336	55,67	---	---	---	9:08	194,01	8,66
31.07.23	24,00	1.335	55,63	---	---	---	0:46	194,02	8,65
Σ	730,84	40.736							
Mittelwert	23,58	1.314	55,74		196,26	6,41		194,08	8,59
Minimum	21,16	1.182	55,50		196,19	6,32		193,99	8,45
Maximum	24,00	1.345	56,75		196,35	6,48		194,22	8,68

Meßpunkthöhe (MP): 202,67 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB08
Monatsbericht vom Juli 2023
gedruckt am: 03.08.2023, 22:20 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.07.23	24,00	1.177	49,04	---	---	---	5:47	194,96	10,33
02.07.23	24,00	1.174	48,92	---	---	---	4:18	194,95	10,34
03.07.23	24,00	1.166	48,58	---	---	---	13:54	194,95	10,34
04.07.23	23,22	1.130	48,66	---	---	---	13:08	194,93	10,36
05.07.23	24,00	1.168	48,67	---	---	---	15:28	194,94	10,35
06.07.23	24,00	1.166	48,58	---	---	---	6:19	194,92	10,37
07.07.23	21,93	1.066	48,61	5:29	196,84	8,45	3:33	194,84	10,45
08.07.23	24,00	1.168	48,67	---	---	---	20:59	194,88	10,42
09.07.23	24,00	1.175	48,96	---	---	---	6:19	194,82	10,47
10.07.23	24,00	1.172	48,83	---	---	---	8:52	194,82	10,47
11.07.23	22,48	1.096	48,76	11:24	196,84	8,45	6:36	194,82	10,48
12.07.23	24,00	1.163	48,46	---	---	---	8:59	194,81	10,48
13.07.23	21,95	1.067	48,60	12:22	196,85	8,44	3:59	194,79	10,50
14.07.23	24,00	1.165	48,54	---	---	---	7:12	194,79	10,50
15.07.23	22,42	1.092	48,70	23:58	196,82	8,47	22:20	194,72	10,57
16.07.23	22,26	1.112	49,96	1:31	196,96	8,33	23:52	194,82	10,47
17.07.23	23,32	1.139	48,84	---	---	---	13:43	194,76	10,53
18.07.23	21,16	1.035	48,92	12:32	196,89	8,40	8:08	194,76	10,53
19.07.23	24,00	1.172	48,83	---	---	---	9:23	194,81	10,48
20.07.23	24,00	1.168	48,67	---	---	---	13:30	194,76	10,53
21.07.23	24,00	1.168	48,67	---	---	---	2:43	194,76	10,53
22.07.23	24,00	1.164	48,50	---	---	---	2:49	194,75	10,55
23.07.23	24,00	1.166	48,58	---	---	---	0:17	194,75	10,55
24.07.23	24,00	1.164	48,50	---	---	---	0:23	194,74	10,55
25.07.23	24,00	1.170	48,75	---	---	---	12:49	194,71	10,58
26.07.23	24,00	1.171	48,79	---	---	---	19:35	194,69	10,61
27.07.23	24,00	1.161	48,38	---	---	---	0:00	194,71	10,58
28.07.23	24,00	1.164	48,50	---	---	---	6:56	194,71	10,58
29.07.23	24,00	1.167	48,63	---	---	---	19:00	194,69	10,60
30.07.23	24,00	1.168	48,67	---	---	---	0:00	194,69	10,60
31.07.23	24,00	1.165	48,54	---	---	---	0:34	194,72	10,57
Σ	730,74	35.599							
Mittelwert	23,57	1.148	48,72		196,87	8,42		194,80	10,49
Minimum	21,16	1.035	48,38		196,82	8,33		194,69	10,33
Maximum	24,00	1.177	49,96		196,96	8,47		194,96	10,61

Meßpunkthöhe (MP): 205,29 m üNN