

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB20**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.23	24,00	1.202	50,08	---	---	---	0:30	192,82	16,94
02.10.23	24,00	1.185	49,38	---	---	---	14:31	192,91	16,85
03.10.23	24,00	1.196	49,83	---	---	---	0:58	192,97	16,79
04.10.23	24,00	1.179	49,13	---	---	---	23:17	192,77	17,00
05.10.23	24,00	1.179	49,13	---	---	---	0:00	192,78	16,98
06.10.23	24,00	1.174	48,92	---	---	---	15:31	192,72	17,04
07.10.23	24,00	1.186	49,42	---	---	---	0:27	192,71	17,06
08.10.23	24,00	1.192	49,67	---	---	---	0:29	192,93	16,84
09.10.23	24,00	1.184	49,33	---	---	---	23:06	192,84	16,92
10.10.23	24,00	1.172	48,83	---	---	---	22:44	192,68	17,09
11.10.23	24,00	1.170	48,75	---	---	---	2:57	192,58	17,18
12.10.23	24,00	1.166	48,58	---	---	---	22:18	192,52	17,24
13.10.23	20,98	1.018	48,53	5:19	194,33	15,43	0:12	192,52	17,24
14.10.23	24,00	1.168	48,67	---	---	---	23:58	192,42	17,35
15.10.23	24,00	1.181	49,21	---	---	---	0:00	192,42	17,34
16.10.23	24,00	1.182	49,25	---	---	---	0:59	192,57	17,19
17.10.23	24,00	1.187	49,46	---	---	---	11:25	193,08	16,68
18.10.23	24,00	1.233	51,38	---	---	---	3:40	193,35	16,42
19.10.23	24,00	1.204	50,17	---	---	---	3:33	193,80	15,97
20.10.23	24,00	1.198	49,92	---	---	---	18:01	193,75	16,01
21.10.23	24,00	1.206	50,25	---	---	---	12:17	193,64	16,12
22.10.23	24,00	1.208	50,33	---	---	---	8:48	193,61	16,15
23.10.23	24,00	1.200	50,00	---	---	---	0:00	193,64	16,12
24.10.23	24,00	1.192	49,67	---	---	---	13:01	193,35	16,42
25.10.23	22,83	1.140	49,94	13:16	195,33	14,43	0:22	193,61	16,15
26.10.23	24,00	1.202	50,08	---	---	---	5:13	193,74	16,03
27.10.23	24,00	1.212	50,50	---	---	---	0:00	193,75	16,01
28.10.23	24,00	1.225	51,04	---	---	---	0:00	194,03	15,73
29.10.23	20,19	1.022	50,63	4:34	196,23	13,53	23:05	194,06	15,70
30.10.23	24,00	1.219	50,79	---	---	---	0:10	194,09	15,68
31.10.23	24,00	1.206	50,25	---	---	---	12:05	193,93	15,84
<b>Σ</b>	<b>735,99</b>	<b>36.588</b>							
<b>Mittelwert</b>	<b>23,74</b>	<b>1.180</b>	<b>49,71</b>		<b>195,30</b>	<b>14,46</b>		<b>193,18</b>	<b>16,58</b>
<b>Minimum</b>	<b>20,19</b>	<b>1.018</b>	<b>48,53</b>		<b>194,33</b>	<b>13,53</b>		<b>192,42</b>	<b>15,68</b>
<b>Maximum</b>	<b>24,00</b>	<b>1.233</b>	<b>51,38</b>		<b>196,23</b>	<b>15,43</b>		<b>194,09</b>	<b>17,35</b>

Meßpunkthöhe (MP): 209,76 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB22**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.23	6,44	1.478	229,66	9:41	199,18	8,64	13:13	192,52	15,30
02.10.23	13,25	3.033	228,91	8:14	199,28	8,54	13:20	191,43	16,39
03.10.23	9,26	2.130	230,08	8:16	199,12	8,70	0:37	191,93	15,90
04.10.23	14,68	3.327	226,59	8:49	199,10	8,72	22:24	191,17	16,65
05.10.23	15,34	3.537	230,50	6:02	198,72	9,10	23:59	191,43	16,39
06.10.23	17,41	3.988	229,05	5:39	198,30	9,53	15:17	191,42	16,41
07.10.23	11,87	2.723	229,44	5:12	198,59	9,23	0:17	191,41	16,41
08.10.23	10,33	2.376	229,99	9:50	199,01	8,81	22:29	191,80	16,02
09.10.23	13,57	3.110	229,24	7:17	198,78	9,04	22:43	191,64	16,19
10.10.23	16,07	3.671	228,42	11:31	198,73	9,09	20:40	191,07	16,75
11.10.23	20,60	4.718	229,03	6:44	198,59	9,23	2:54	191,05	16,77
12.10.23	24,00	5.520	230,00	---	---	---	21:37	191,06	16,77
13.10.23	24,00	5.517	229,88	---	---	---	2:32	191,03	16,79
14.10.23	22,80	5.233	229,54	---	---	---	3:15	190,99	16,84
15.10.23	19,06	4.430	232,37	---	---	---	4:02	191,22	16,60
16.10.23	9,19	2.106	229,18	23:47	199,25	8,57	8:25	191,33	16,49
17.10.23	2,24	501	224,05	7:24	199,33	8,49	10:23	191,87	15,96
18.10.23	0,00	0	---	13:43	200,63	7,19	---	---	---
19.10.23	0,00	0	---	11:07	200,90	6,92	---	---	---
20.10.23	0,00	0	---	0:00	199,81	8,01	---	---	---
21.10.23	0,00	0	---	0:00	199,66	8,16	---	---	---
22.10.23	0,00	0	---	12:02	199,59	8,23	---	---	---
23.10.23	0,00	0	---	17:14	199,59	8,23	---	---	---
24.10.23	3,17	715	225,43	0:00	199,56	8,26	11:20	191,87	15,95
25.10.23	0,00	0	---	13:29	199,86	7,97	---	---	---
26.10.23	0,00	0	---	23:58	199,73	8,09	---	---	---
27.10.23	0,00	0	---	11:15	200,87	6,95	---	---	---
28.10.23	0,00	0	---	22:36	201,15	6,67	---	---	---
29.10.23	0,00	0	---	0:28	201,15	6,67	---	---	---
30.10.23	0,00	0	---	9:51	201,05	6,77	---	---	---
31.10.23	2,83	661	233,39	7:13	201,10	6,72	10:43	193,04	14,78
<b>Σ</b>	<b>256,11</b>	<b>58.774</b>							
<b>Mittelwert</b>	<b>8,26</b>	<b>1.896</b>	<b>229,49</b>		<b>199,65</b>	<b>8,17</b>		<b>191,54</b>	<b>16,28</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>224,05</b>		<b>198,30</b>	<b>6,67</b>		<b>190,99</b>	<b>14,78</b>
<b>Maximum</b>	<b>24,00</b>	<b>5.520</b>	<b>233,39</b>		<b>201,15</b>	<b>9,53</b>		<b>193,04</b>	<b>16,84</b>

Meßpunkthöhe (MP): 207,82 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB23**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.23	0,00	0	---	9:42	193,76	19,08	---	---	---
02.10.23	4,54	621	136,76	8:14	194,07	18,77	11:38	188,28	24,56
03.10.23	0,00	0	---	8:08	193,68	19,15	---	---	---
04.10.23	2,53	335	132,47	8:46	193,67	19,17	---	---	---
05.10.23	0,00	0	---	5:59	193,27	19,56	---	---	---
06.10.23	0,00	0	---	5:38	192,90	19,93	---	---	---
07.10.23	0,00	0	---	5:14	193,16	19,67	---	---	---
08.10.23	0,00	0	---	9:40	193,58	19,26	---	---	---
09.10.23	0,00	0	---	7:17	193,36	19,47	---	---	---
10.10.23	7,00	980	140,05	11:28	193,30	19,53	19:01	188,33	24,51
11.10.23	24,00	3.360	140,00	---	---	---	2:57	188,31	24,52
12.10.23	24,00	3.351	139,63	---	---	---	21:09	188,50	24,34
13.10.23	24,00	3.350	139,58	---	---	---	4:59	188,50	24,34
14.10.23	24,00	3.366	140,25	---	---	---	3:18	188,34	24,49
15.10.23	24,00	3.403	141,79	---	---	---	0:00	188,53	24,31
16.10.23	8,50	1.189	139,88	21:40	193,87	18,97	0:51	188,74	24,10
17.10.23	2,57	348	135,60	7:03	193,90	18,94	10:25	188,50	24,34
18.10.23	0,00	0	---	13:37	195,63	17,21	---	---	---
19.10.23	0,00	0	---	0:00	194,86	17,97	---	---	---
20.10.23	0,00	0	---	0:00	194,37	18,46	---	---	---
21.10.23	0,00	0	---	0:00	194,19	18,65	---	---	---
22.10.23	0,00	0	---	12:30	194,13	18,71	---	---	---
23.10.23	0,00	0	---	14:07	194,11	18,72	---	---	---
24.10.23	2,57	351	136,41	0:00	194,08	18,75	11:22	188,82	24,02
25.10.23	0,00	0	---	13:17	194,56	18,28	---	---	---
26.10.23	0,00	0	---	23:58	194,43	18,40	---	---	---
27.10.23	0,00	0	---	10:57	195,81	17,02	---	---	---
28.10.23	0,00	0	---	22:14	196,12	16,72	---	---	---
29.10.23	0,00	0	---	0:00	196,12	16,72	---	---	---
30.10.23	0,00	0	---	10:07	196,01	16,83	---	---	---
31.10.23	2,36	329	139,59	7:11	196,04	16,79	10:41	190,10	22,73
<b>Σ</b>	<b>150,06</b>	<b>20.983</b>							
<b>Mittelwert</b>	<b>4,84</b>	<b>677</b>	<b>139,83</b>		<b>194,34</b>	<b>18,49</b>		<b>188,63</b>	<b>24,20</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>132,47</b>		<b>192,90</b>	<b>16,72</b>		<b>188,28</b>	<b>22,73</b>
<b>Maximum</b>	<b>24,00</b>	<b>3.403</b>	<b>141,79</b>		<b>196,12</b>	<b>19,93</b>		<b>190,10</b>	<b>24,56</b>

Meßpunkthöhe (MP): 212,83 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB24**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.10.23	24,00	4.586	191,08	---	---	---	0:11	176,04	34,07
02.10.23	22,52	4.229	187,81	8:32	192,61	17,50	14:07	176,18	33,93
03.10.23	24,00	4.562	190,08	---	---	---	0:46	176,28	33,83
04.10.23	24,00	4.486	186,92	---	---	---	23:19	175,74	34,37
05.10.23	24,00	4.491	187,13	---	---	---	0:00	175,88	34,23
06.10.23	24,00	4.464	186,00	---	---	---	15:32	175,76	34,35
07.10.23	24,00	4.517	188,21	---	---	---	0:25	175,74	34,37
08.10.23	24,00	4.541	189,21	---	---	---	22:52	176,01	34,10
09.10.23	24,00	4.500	187,50	---	---	---	22:57	175,78	34,33
10.10.23	17,31	3.203	185,03	23:04	191,80	18,31	0:44	175,88	34,23
11.10.23	0,00	0	---	6:47	192,85	17,26	---	---	---
12.10.23	0,00	0	---	9:05	192,17	17,94	---	---	---
13.10.23	0,00	0	---	2:21	192,09	18,02	---	---	---
14.10.23	0,00	0	---	9:02	192,42	17,69	---	---	---
15.10.23	0,00	0	---	7:48	192,78	17,33	---	---	---
16.10.23	14,89	2.834	190,35	2:21	192,68	17,43	15:02	176,68	33,43
17.10.23	24,00	4.520	188,33	---	---	---	11:56	176,30	33,81
18.10.23	17,20	3.374	196,17	13:33	194,68	15,43	3:37	176,20	33,91
19.10.23	24,00	4.609	192,04	---	---	---	2:24	177,47	32,64
20.10.23	24,00	4.562	190,08	---	---	---	18:01	177,05	33,06
21.10.23	24,00	4.589	191,21	---	---	---	22:21	176,88	33,23
22.10.23	24,00	4.597	191,54	---	---	---	8:45	176,61	33,50
23.10.23	24,00	4.561	190,04	---	---	---	6:01	176,80	33,31
24.10.23	22,85	4.311	188,70	11:34	191,60	18,51	13:59	176,47	33,64
25.10.23	22,95	4.361	190,01	13:15	192,91	17,20	12:12	176,45	33,66
26.10.23	23,27	4.408	189,45	---	---	---	18:08	176,83	33,28
27.10.23	5,36	1.011	188,76	9:33	194,60	15,51	13:19	178,74	31,37
28.10.23	0,00	0	---	10:41	194,92	15,19	---	---	---
29.10.23	22,69	4.403	194,01	0:00	194,80	15,31	6:58	177,96	32,15
30.10.23	3,75	712	189,77	10:02	194,64	15,47	21:14	179,10	31,01
31.10.23	6,86	1.284	187,06	8:00	194,67	15,44	12:03	177,90	32,21
<b>Σ</b>	<b>515,65</b>	<b>97.715</b>							
<b>Mittelwert</b>	<b>16,63</b>	<b>3.152</b>	<b>189,50</b>		<b>193,26</b>	<b>16,85</b>		<b>176,67</b>	<b>33,44</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>185,03</b>		<b>191,60</b>	<b>15,19</b>		<b>175,74</b>	<b>31,01</b>
<b>Maximum</b>	<b>24,00</b>	<b>4.609</b>	<b>196,17</b>		<b>194,92</b>	<b>18,51</b>		<b>179,10</b>	<b>34,37</b>

Meßpunkthöhe (MP): 210,11 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB25**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.10.23	22,08	2.615	118,43	6:26	193,14	21,63	0:23	182,76	32,01
02.10.23	22,79	2.669	117,11	8:41	193,57	21,20	22:36	183,07	31,71
03.10.23	24,00	2.835	118,13	---	---	---	1:23	183,07	31,71
04.10.23	23,59	2.750	116,55	---	---	---	23:33	182,73	32,04
05.10.23	24,00	2.801	116,71	---	---	---	0:00	182,75	32,03
06.10.23	24,00	2.790	116,25	---	---	---	15:59	182,72	32,06
07.10.23	24,00	2.816	117,33	---	---	---	0:45	182,68	32,09
08.10.23	23,63	2.779	117,61	---	---	---	0:41	183,01	31,77
09.10.23	24,00	2.807	116,96	---	---	---	23:15	182,75	32,03
10.10.23	19,28	2.230	115,64	22:54	193,36	21,42	13:23	182,73	32,04
11.10.23	8,59	979	113,92	7:17	194,40	20,38	21:26	183,91	30,87
12.10.23	4,71	543	115,18	9:56	193,89	20,88	20:46	184,50	30,27
13.10.23	7,91	923	116,73	2:41	193,78	20,99	7:13	184,27	30,50
14.10.23	4,06	460	113,40	9:34	194,07	20,70	0:28	184,29	30,49
15.10.23	0,00	0	---	15:02	194,43	20,35	---	---	---
16.10.23	14,86	1.752	117,92	2:37	194,35	20,43	22:41	183,17	31,60
17.10.23	24,00	2.799	116,63	---	---	---	20:44	182,81	31,97
18.10.23	10,23	1.225	119,77	13:44	195,80	18,98	1:15	182,97	31,80
19.10.23	20,37	2.397	117,69	6:45	194,84	19,94	21:48	183,80	30,98
20.10.23	24,00	2.810	117,08	---	---	---	18:01	183,25	31,53
21.10.23	24,00	2.830	117,92	---	---	---	0:50	183,13	31,65
22.10.23	23,74	2.804	118,09	---	---	---	1:42	183,11	31,66
23.10.23	24,00	2.814	117,25	---	---	---	11:41	183,19	31,59
24.10.23	23,90	2.783	116,44	---	---	---	13:55	182,93	31,85
25.10.23	22,56	2.638	116,95	13:17	193,22	21,56	0:29	182,82	31,95
26.10.23	24,00	2.813	117,21	---	---	---	18:03	182,96	31,82
27.10.23	20,59	2.435	118,26	9:23	194,49	20,29	0:00	183,26	31,51
28.10.23	17,69	2.117	119,67	10:36	194,75	20,03	0:00	183,97	30,81
29.10.23	6,83	813	119,06	17:09	194,53	20,24	2:02	184,09	30,69
30.10.23	24,00	2.864	119,33	---	---	---	21:26	184,12	30,66
31.10.23	22,45	2.655	118,27	9:15	194,40	20,38	21:34	183,81	30,96
<b>Σ</b>	<b>583,87</b>	<b>68.546</b>							
<b>Mittelwert</b>	<b>18,83</b>	<b>2.211</b>	<b>117,40</b>		<b>194,19</b>	<b>20,58</b>		<b>183,28</b>	<b>31,49</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>113,40</b>		<b>193,14</b>	<b>18,98</b>		<b>182,68</b>	<b>30,27</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.864</b>	<b>119,77</b>		<b>195,80</b>	<b>21,63</b>		<b>184,50</b>	<b>32,09</b>

Meßpunkthöhe (MP): 214,77 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB26**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.10.23	22,10	1.322	59,81	6:25	194,08	19,20	0:18	187,76	25,52
02.10.23	23,57	1.383	58,68	---	---	---	22:06	188,14	25,14
03.10.23	24,00	1.427	59,46	---	---	---	0:55	188,11	25,17
04.10.23	23,60	1.364	57,79	---	---	---	23:23	187,78	25,50
05.10.23	24,00	1.389	57,88	---	---	---	0:00	187,83	25,45
06.10.23	24,00	1.374	57,25	---	---	---	15:30	187,71	25,57
07.10.23	24,00	1.402	58,42	---	---	---	0:28	187,69	25,59
08.10.23	23,64	1.394	58,98	---	---	---	0:23	187,99	25,29
09.10.23	24,00	1.394	58,08	---	---	---	22:52	187,44	25,84
10.10.23	19,29	1.087	56,34	22:54	193,60	19,68	13:17	187,26	26,02
11.10.23	8,64	480	55,54	6:48	195,30	17,98	21:27	188,57	24,71
12.10.23	4,87	275	56,50	9:59	194,48	18,80	17:27	189,00	24,28
13.10.23	7,98	459	57,49	2:27	194,38	18,90	4:37	188,94	24,34
14.10.23	4,10	227	55,42	9:01	194,82	18,46	0:29	189,02	24,26
15.10.23	0,00	0	---	7:48	195,27	18,01	---	---	---
16.10.23	14,87	866	58,22	2:23	195,18	18,10	22:11	187,59	25,69
17.10.23	24,00	1.366	56,92	---	---	---	20:18	187,03	26,25
18.10.23	10,26	627	61,14	13:51	196,64	16,64	0:43	187,30	25,98
19.10.23	20,41	1.191	58,35	6:43	195,91	17,37	21:44	188,09	25,19
20.10.23	24,00	1.375	57,29	---	---	---	17:36	187,44	25,84
21.10.23	24,00	1.400	58,33	---	---	---	0:35	187,30	25,98
22.10.23	23,76	1.395	58,72	---	---	---	1:16	187,37	25,91
23.10.23	24,00	1.380	57,50	---	---	---	23:41	187,34	25,94
24.10.23	23,91	1.354	56,63	---	---	---	0:13	187,05	26,23
25.10.23	22,59	1.292	57,20	13:16	193,11	20,17	0:22	186,90	26,38
26.10.23	24,00	1.376	57,33	---	---	---	17:58	187,03	26,25
27.10.23	20,62	1.196	57,99	9:17	193,88	19,40	0:00	187,18	26,10
28.10.23	17,73	1.059	59,72	10:36	194,18	19,10	0:02	187,80	25,48
29.10.23	6,85	408	59,55	9:05	194,88	18,40	2:41	188,27	25,01
30.10.23	24,00	1.419	59,13	---	---	---	13:44	188,12	25,16
31.10.23	24,00	1.405	58,54	---	---	---	22:53	187,92	25,36
<b>Σ</b>	<b>586,79</b>	<b>34.086</b>							
<b>Mittelwert</b>	<b>18,93</b>	<b>1.100</b>	<b>58,09</b>		<b>194,69</b>	<b>18,59</b>		<b>187,77</b>	<b>25,51</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>55,42</b>		<b>193,11</b>	<b>16,64</b>		<b>186,90</b>	<b>24,26</b>
<b>Maximum</b>	<b>24,00</b>	<b>1.427</b>	<b>61,14</b>		<b>196,64</b>	<b>20,17</b>		<b>189,02</b>	<b>26,38</b>

Meßpunkthöhe (MP): 213,28 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB27**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.23	0,00	0	---	0:00	181,01	35,79	---	---	---
02.10.23	0,00	0	---	6:41	181,02	35,78	---	---	---
03.10.23	0,00	0	---	0:00	181,01	35,79	---	---	---
04.10.23	0,00	0	---	15:15	181,02	35,78	---	---	---
05.10.23	0,00	0	---	7:37	181,02	35,78	---	---	---
06.10.23	0,00	0	---	18:52	181,02	35,78	---	---	---
07.10.23	0,00	0	---	0:25	181,02	35,78	---	---	---
08.10.23	0,00	0	---	0:00	181,01	35,79	---	---	---
09.10.23	7,82	818	104,64	1:16	181,02	35,78	20:48	181,00	35,80
10.10.23	18,34	1.922	104,83	1:34	181,01	35,79	12:38	181,00	35,80
11.10.23	20,54	2.220	108,06	4:48	181,01	35,79	1:46	181,00	35,80
12.10.23	24,00	2.605	108,54	---	---	---	7:22	181,00	35,80
13.10.23	24,00	2.602	108,42	---	---	---	0:03	181,00	35,80
14.10.23	22,68	2.462	108,56	---	---	---	12:21	181,00	35,80
15.10.23	18,81	2.078	110,50	---	---	---	10:28	181,00	35,80
16.10.23	19,80	2.119	107,04	15:34	181,01	35,79	4:36	181,00	35,80
17.10.23	18,25	1.907	104,51	3:44	181,01	35,79	1:01	181,00	35,80
18.10.23	4,43	465	105,03	20:35	181,02	35,78	0:00	181,01	35,79
19.10.23	15,30	1.615	105,52	6:59	181,02	35,78	10:20	181,00	35,80
20.10.23	20,08	2.108	104,96	4:18	181,01	35,79	2:36	181,00	35,80
21.10.23	15,49	1.636	105,61	1:28	181,01	35,79	7:25	181,00	35,80
22.10.23	13,50	1.420	105,15	9:19	181,02	35,78	4:59	181,00	35,80
23.10.23	19,12	2.021	105,69	2:56	181,01	35,79	4:06	181,00	35,80
24.10.23	18,89	1.972	104,42	1:03	181,01	35,79	15:26	181,00	35,80
25.10.23	18,22	1.910	104,84	1:13	181,01	35,79	15:11	181,00	35,80
26.10.23	19,40	2.039	105,11	2:15	181,01	35,79	9:01	181,00	35,80
27.10.23	23,62	2.571	108,85	---	---	---	6:19	181,00	35,80
28.10.23	24,00	2.661	110,88	---	---	---	1:17	181,00	35,80
29.10.23	18,07	1.933	106,96	7:24	181,01	35,79	0:55	181,00	35,80
30.10.23	24,00	2.631	109,63	---	---	---	1:11	181,00	35,80
31.10.23	22,20	2.405	108,35	8:47	181,01	35,79	16:49	181,00	35,80
<b>Σ</b>	<b>430,55</b>	<b>46.120</b>							
<b>Mittelwert</b>	<b>13,89</b>	<b>1.488</b>	<b>107,12</b>		<b>181,02</b>	<b>35,78</b>		<b>181,00</b>	<b>35,80</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>104,42</b>		<b>181,01</b>	<b>35,78</b>		<b>181,00</b>	<b>35,79</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.661</b>	<b>110,88</b>		<b>181,02</b>	<b>35,79</b>		<b>181,01</b>	<b>35,80</b>

Meßpunkthöhe (MP): 216,80 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB28**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.23	7,79	1.333	171,11	9:13	196,02	25,13	2:29	181,36	39,79
02.10.23	13,71	2.368	172,75	8:50	196,40	24,75	9:54	180,77	40,38
03.10.23	10,62	1.816	170,99	8:05	196,03	25,12	0:38	181,59	39,56
04.10.23	15,60	2.599	166,57	8:41	195,96	25,19	23:09	181,20	39,95
05.10.23	16,66	2.835	170,15	5:44	195,60	25,55	12:39	181,32	39,83
06.10.23	18,44	3.111	168,75	5:31	195,20	25,95	10:15	181,13	40,02
07.10.23	13,38	2.275	170,07	5:05	195,50	25,65	0:19	181,08	40,07
08.10.23	11,87	2.025	170,64	9:39	195,84	25,31	22:30	181,36	39,79
09.10.23	12,93	2.110	163,21	11:15	195,80	25,35	22:45	180,72	40,43
10.10.23	19,13	3.182	166,30	7:58	195,27	25,88	19:01	179,41	41,74
11.10.23	20,86	3.824	183,31	6:36	196,75	24,40	2:56	178,68	42,47
12.10.23	24,00	4.440	185,00	---	---	---	18:02	180,02	41,13
13.10.23	24,00	4.431	184,63	---	---	---	5:03	179,81	41,34
14.10.23	23,20	4.309	185,72	---	---	---	3:17	178,97	42,18
15.10.23	20,44	3.895	190,55	---	---	---	4:04	179,19	41,96
16.10.23	20,56	3.574	173,80	16:27	195,48	25,67	0:50	179,41	41,74
17.10.23	18,38	2.953	160,66	22:11	194,79	26,36	20:13	180,07	41,08
18.10.23	4,66	782	167,79	13:42	197,72	23,43	0:38	180,34	40,81
19.10.23	15,68	2.543	162,13	6:59	197,04	24,11	21:51	181,39	39,76
20.10.23	20,71	3.349	161,68	---	---	---	17:32	180,34	40,81
21.10.23	16,43	2.686	163,43	6:01	195,34	25,81	18:37	180,24	40,91
22.10.23	14,52	2.367	163,06	10:16	195,39	25,76	1:11	180,29	40,86
23.10.23	19,83	3.233	163,07	6:06	195,05	26,10	1:58	180,48	40,67
24.10.23	19,28	3.076	159,54	13:57	194,79	26,36	0:04	180,07	41,08
25.10.23	18,84	3.035	161,11	14:00	195,27	25,88	12:10	178,92	42,23
26.10.23	19,85	3.226	162,49	6:37	195,00	26,15	23:35	178,54	42,61
27.10.23	23,77	4.331	182,20	---	---	---	7:32	177,92	43,23
28.10.23	24,00	4.580	190,83	---	---	---	3:52	178,46	42,69
29.10.23	19,00	3.200	168,39	8:52	195,70	25,45	1:06	179,24	41,91
30.10.23	24,00	4.450	185,42	---	---	---	13:34	178,75	42,40
31.10.23	22,40	4.029	179,84	9:15	195,98	25,17	1:56	178,68	42,47
<b>Σ</b>	<b>554,56</b>	<b>95.967</b>							
<b>Mittelwert</b>	<b>17,89</b>	<b>3.096</b>	<b>173,05</b>		<b>195,73</b>	<b>25,42</b>		<b>179,99</b>	<b>41,16</b>
<b>Minimum</b>	<b>4,66</b>	<b>782</b>	<b>159,54</b>		<b>194,79</b>	<b>23,43</b>		<b>177,92</b>	<b>39,56</b>
<b>Maximum</b>	<b>24,00</b>	<b>4.580</b>	<b>190,83</b>		<b>197,72</b>	<b>26,36</b>		<b>181,59</b>	<b>43,23</b>

Meßpunkthöhe (MP): 221,15 m üNN



**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB29**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.10.23	24,00	2.392	99,67	---	---	---	0:04	190,73	36,79
02.10.23	20,43	1.987	97,28	8:57	197,12	30,40	21:52	191,02	36,51
03.10.23	24,00	2.367	98,63	---	---	---	0:39	191,00	36,52
04.10.23	24,00	2.305	96,04	---	---	---	23:10	190,64	36,88
05.10.23	24,00	2.305	96,04	---	---	---	18:10	190,72	36,81
06.10.23	24,00	2.284	95,17	---	---	---	15:20	190,48	37,04
07.10.23	24,00	2.333	97,21	---	---	---	0:20	190,50	37,03
08.10.23	24,00	2.355	98,13	---	---	---	22:31	190,79	36,73
09.10.23	24,00	2.304	96,00	---	---	---	22:46	190,42	37,10
10.10.23	17,26	1.589	92,07	23:55	195,92	31,60	13:11	190,20	37,32
11.10.23	0,00	0	---	6:38	197,82	29,70	---	---	---
12.10.23	0,00	0	---	9:57	196,78	30,74	---	---	---
13.10.23	0,00	0	---	22:57	196,80	30,73	---	---	---
14.10.23	0,00	0	---	7:40	197,25	30,28	---	---	---
15.10.23	0,00	0	---	7:38	197,71	29,81	---	---	---
16.10.23	14,84	1.392	93,83	2:14	197,54	29,98	22:02	190,55	36,97
17.10.23	24,00	2.220	92,50	---	---	---	20:14	189,89	37,63
18.10.23	16,67	1.678	100,64	13:38	198,61	28,91	0:39	190,19	37,33
19.10.23	24,00	2.287	95,29	---	---	---	21:58	191,13	36,39
20.10.23	24,00	2.209	92,04	---	---	---	17:33	190,15	37,37
21.10.23	24,00	2.257	94,04	---	---	---	0:31	190,02	37,51
22.10.23	24,00	2.282	95,08	---	---	---	1:12	190,09	37,43
23.10.23	24,00	2.220	92,50	---	---	---	11:10	190,24	37,29
24.10.23	24,00	2.198	91,58	---	---	---	0:06	189,79	37,74
25.10.23	22,85	2.105	92,14	13:19	195,57	31,95	0:16	189,66	37,86
26.10.23	23,22	2.131	91,79	---	---	---	17:50	189,67	37,85
27.10.23	4,93	443	89,78	10:55	195,95	31,57	22:23	191,00	36,52
28.10.23	0,00	0	---	23:10	196,33	31,19	---	---	---
29.10.23	22,59	2.141	94,79	0:27	196,34	31,19	6:27	190,66	36,87
30.10.23	3,44	310	90,14	9:16	196,22	31,31	21:13	191,36	36,16
31.10.23	6,58	586	88,99	9:16	197,23	30,29	21:19	191,17	36,35
<b>Σ</b>	<b>512,80</b>	<b>48.680</b>							
<b>Mittelwert</b>	<b>16,54</b>	<b>1.570</b>	<b>94,93</b>		<b>196,88</b>	<b>30,64</b>		<b>190,48</b>	<b>37,04</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>88,99</b>		<b>195,57</b>	<b>28,91</b>		<b>189,66</b>	<b>36,16</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.392</b>	<b>100,64</b>		<b>198,61</b>	<b>31,95</b>		<b>191,36</b>	<b>37,86</b>

Meßpunkthöhe (MP): 227,52 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB31**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.10.23	24,00	1.669	69,54	---	---	---	0:29	188,17	47,30
02.10.23	20,46	1.404	68,63	10:37	199,76	35,70	7:35	188,45	47,01
03.10.23	24,00	1.659	69,13	---	---	---	1:26	188,57	46,90
04.10.23	24,00	1.630	67,92	---	---	---	23:35	188,30	47,17
05.10.23	24,00	1.631	67,96	---	---	---	1:47	188,31	47,16
06.10.23	24,00	1.622	67,58	---	---	---	15:42	188,18	47,28
07.10.23	24,00	1.643	68,46	---	---	---	0:45	188,15	47,31
08.10.23	24,00	1.652	68,83	---	---	---	0:41	188,32	47,14
09.10.23	24,00	1.629	67,88	---	---	---	23:16	188,24	47,22
10.10.23	17,24	1.135	65,82	23:59	199,20	36,27	13:28	188,11	47,36
11.10.23	0,00	0	---	7:28	200,28	35,18	---	---	---
12.10.23	0,00	0	---	16:27	200,25	35,22	---	---	---
13.10.23	0,00	0	---	23:25	200,47	34,99	---	---	---
14.10.23	0,00	0	---	9:47	200,68	34,78	---	---	---
15.10.23	0,00	0	---	14:48	200,99	34,47	---	---	---
16.10.23	14,82	989	66,74	2:43	200,96	34,51	22:05	188,32	47,14
17.10.23	24,00	1.580	65,83	---	---	---	20:18	187,61	47,85
18.10.23	16,50	1.149	69,65	13:39	200,67	34,79	0:42	187,73	47,73
19.10.23	24,00	1.612	67,17	---	---	---	12:50	188,87	46,59
20.10.23	24,00	1.578	65,75	---	---	---	17:59	187,98	47,48
21.10.23	24,00	1.598	66,58	---	---	---	18:59	187,79	47,67
22.10.23	24,00	1.609	67,04	---	---	---	1:15	187,84	47,63
23.10.23	24,00	1.580	65,83	---	---	---	11:29	187,87	47,59
24.10.23	24,00	1.572	65,50	---	---	---	0:36	187,55	47,92
25.10.23	22,81	1.499	65,70	13:19	198,05	37,42	0:38	187,49	47,97
26.10.23	23,20	1.520	65,53	---	---	---	18:17	187,52	47,94
27.10.23	4,80	313	65,27	11:15	199,28	36,18	13:16	189,78	45,68
28.10.23	0,00	0	---	23:59	199,81	35,65	---	---	---
29.10.23	22,55	1.502	66,61	0:53	199,82	35,64	20:57	187,96	47,50
30.10.23	3,33	218	65,46	9:37	199,64	35,82	21:10	189,81	45,65
31.10.23	6,49	417	64,22	9:19	200,00	35,46	21:18	189,48	45,98
<b>Σ</b>	<b>512,20</b>	<b>34.410</b>							
<b>Mittelwert</b>	<b>16,52</b>	<b>1.110</b>	<b>67,18</b>		<b>199,99</b>	<b>35,47</b>		<b>188,26</b>	<b>47,20</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>64,22</b>		<b>198,05</b>	<b>34,47</b>		<b>187,49</b>	<b>45,65</b>
<b>Maximum</b>	<b>24,00</b>	<b>1.669</b>	<b>69,65</b>		<b>200,99</b>	<b>37,42</b>		<b>189,81</b>	<b>47,97</b>

Meßpunkthöhe (MP): 235,46 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB32**  
**Monatsbericht vom Oktober 2023**  
gedruckt am: 02.11.2023, 07:34 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.23	0,00	0	---	9:54	196,79	48,03	---	---	---
02.10.23	3,39	564	166,30	9:52	196,88	47,94	13:18	193,05	51,77
03.10.23	0,00	0	---	13:42	196,88	47,94	---	---	---
04.10.23	2,89	486	167,88	8:26	196,81	48,02	15:24	193,50	51,32
05.10.23	0,00	0	---	10:21	196,68	48,14	---	---	---
06.10.23	0,00	0	---	5:27	196,64	48,19	---	---	---
07.10.23	0,00	0	---	13:23	196,71	48,11	---	---	---
08.10.23	0,00	0	---	11:07	196,81	48,02	---	---	---
09.10.23	0,00	0	---	12:29	196,85	47,97	---	---	---
10.10.23	8,71	1.446	165,92	7:35	196,67	48,15	23:58	192,58	52,24
11.10.23	24,00	3.886	161,92	---	---	---	21:47	192,49	52,33
12.10.23	24,00	3.886	161,92	---	---	---	21:48	192,43	52,39
13.10.23	24,00	3.903	162,63	---	---	---	7:58	192,35	52,47
14.10.23	24,00	3.884	161,83	---	---	---	23:55	192,37	52,45
15.10.23	24,00	3.899	162,46	---	---	---	0:34	192,39	52,43
16.10.23	12,50	2.022	161,71	18:33	196,26	48,56	0:31	192,49	52,33
17.10.23	5,98	969	162,08	8:49	196,29	48,53	14:12	192,54	52,29
18.10.23	0,00	0	---	19:42	197,27	47,55	---	---	---
19.10.23	7,61	1.278	168,00	7:14	197,26	47,57	23:54	192,94	51,88
20.10.23	4,67	752	161,06	11:57	196,64	48,19	1:09	192,74	52,08
21.10.23	1,23	217	176,78	6:23	196,57	48,25	17:11	193,33	51,49
22.10.23	0,78	116	148,72	10:39	196,55	48,27	---	---	---
23.10.23	1,90	316	166,07	6:26	196,51	48,32	---	---	---
24.10.23	6,16	1.009	163,83	9:34	196,43	48,39	12:55	192,69	52,13
25.10.23	4,34	735	169,47	14:41	196,41	48,41	16:29	193,06	51,76
26.10.23	3,41	565	165,64	7:50	196,46	48,36	0:36	192,99	51,83
27.10.23	24,00	3.857	160,71	---	---	---	23:54	192,28	52,54
28.10.23	24,00	3.868	161,17	---	---	---	0:42	192,27	52,55
29.10.23	20,92	3.376	161,34	3:34	196,16	48,67	0:25	192,40	52,42
30.10.23	19,67	3.164	160,86	6:24	196,12	48,71	23:47	192,37	52,45
31.10.23	19,65	3.163	160,99	4:52	195,86	48,96	23:37	192,22	52,60
<b>Σ</b>	<b>291,82</b>	<b>47.361</b>							
<b>Mittelwert</b>	<b>9,41</b>	<b>1.528</b>	<b>162,30</b>		<b>196,60</b>	<b>48,22</b>		<b>192,64</b>	<b>52,18</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>148,72</b>		<b>195,86</b>	<b>47,55</b>		<b>192,22</b>	<b>51,32</b>
<b>Maximum</b>	<b>24,00</b>	<b>3.903</b>	<b>176,78</b>		<b>197,27</b>	<b>48,96</b>		<b>193,50</b>	<b>52,60</b>

Meßpunkthöhe (MP): 244,82 m üNN