

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB12**  
**Monatsbericht vom November 2023**  
gedruckt am: 18.12.2023, 10:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.11.23	19,90	2.011	101,07	8:08	198,56	15,71	22:29	193,73	20,54
02.11.23	20,40	2.079	101,93	4:48	198,26	16,01	17:27	193,82	20,46
03.11.23	20,86	2.118	101,51	4:27	198,59	15,68	22:46	193,71	20,56
04.11.23	24,00	2.454	102,25	---	---	---	0:00	193,80	20,47
05.11.23	22,02	2.256	102,46	9:47	198,78	15,49	22:09	193,96	20,31
06.11.23	24,00	2.440	101,67	---	---	---	13:17	193,82	20,46
07.11.23	11,43	1.165	101,89	19:24	198,81	15,46	0:47	193,72	20,56
08.11.23	23,36	2.377	101,74	---	---	---	4:20	193,77	20,50
09.11.23	22,38	2.287	102,18	---	---	---	1:03	193,88	20,40
10.11.23	22,96	2.347	102,21	6:35	198,45	15,82	1:49	193,91	20,36
11.11.23	24,00	2.458	102,42	---	---	---	9:41	194,02	20,25
12.11.23	22,69	2.323	102,39	5:05	198,34	15,93	0:12	193,95	20,32
13.11.23	23,69	2.419	102,13	---	---	---	10:54	193,91	20,36
14.11.23	20,11	2.054	102,13	11:03	198,95	15,32	20:12	193,96	20,31
15.11.23	24,00	2.449	102,04	---	---	---	21:20	193,86	20,41
16.11.23	24,00	2.447	101,96	---	---	---	21:13	193,87	20,40
17.11.23	24,00	2.451	102,13	---	---	---	19:00	193,80	20,47
18.11.23	24,00	2.458	102,42	---	---	---	1:22	193,77	20,50
19.11.23	24,00	2.461	102,54	---	---	---	10:57	193,97	20,30
20.11.23	22,68	2.322	102,40	14:45	198,64	15,63	23:43	194,03	20,24
21.11.23	22,25	2.280	102,45	10:02	198,74	15,53	20:58	193,94	20,33
22.11.23	24,00	2.458	102,42	---	---	---	18:59	193,82	20,46
23.11.23	24,00	2.446	101,92	---	---	---	4:06	193,82	20,46
24.11.23	23,53	2.402	102,08	---	---	---	22:19	193,82	20,45
25.11.23	23,40	2.388	102,05	---	---	---	22:48	193,75	20,52
26.11.23	12,44	1.266	101,74	23:59	199,27	15,01	9:32	193,72	20,55
27.11.23	9,31	963	103,46	19:53	199,40	14,88	9:59	194,69	19,59
28.11.23	8,50	890	104,65	6:32	199,50	14,77	18:46	194,70	19,57
29.11.23	7,12	726	102,02	21:13	199,52	14,75	0:46	194,77	19,50
30.11.23	7,91	820	103,71	4:46	199,53	14,74	9:44	194,98	19,29
<b>Σ</b>	<b>606,94</b>	<b>62.015</b>							
<b>Mittelwert</b>	<b>20,23</b>	<b>2.067</b>	<b>102,18</b>		<b>198,89</b>	<b>15,38</b>		<b>193,97</b>	<b>20,30</b>
<b>Minimum</b>	<b>7,12</b>	<b>726</b>	<b>101,07</b>		<b>198,26</b>	<b>14,74</b>		<b>193,71</b>	<b>19,29</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.461</b>	<b>104,65</b>		<b>199,53</b>	<b>16,01</b>		<b>194,98</b>	<b>20,56</b>

Meßpunkthöhe (MP): 214,27 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB13**  
**Monatsbericht vom November 2023**  
gedruckt am: 18.12.2023, 10:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.11.23	24,00	3.247	135,29	---	---	---	23:52	194,95	19,28
02.11.23	24,00	3.255	135,63	---	---	---	0:00	194,96	19,26
03.11.23	20,66	2.781	134,61	19:25	199,65	14,57	1:29	195,09	19,13
04.11.23	1,16	154	132,32	21:36	200,05	14,18	23:46	195,77	18,45
05.11.23	1,02	135	132,97	9:52	200,26	13,96	22:02	195,82	18,40
06.11.23	5,07	681	134,23	4:24	200,00	14,22	23:26	195,41	18,81
07.11.23	13,50	1.828	135,36	12:37	200,05	14,17	0:42	195,06	19,16
08.11.23	7,58	994	131,12	23:33	199,87	14,35	5:00	194,89	19,33
09.11.23	3,44	449	130,47	20:47	200,02	14,20	12:56	195,60	18,62
10.11.23	3,61	477	132,27	6:38	200,11	14,11	1:43	195,68	18,54
11.11.23	0,73	107	147,53	3:47	200,08	14,15	---	---	---
12.11.23	1,62	214	132,33	15:58	200,11	14,12	5:37	195,92	18,31
13.11.23	4,87	653	134,16	8:45	200,10	14,12	10:51	195,73	18,50
14.11.23	5,52	736	133,36	10:42	200,50	13,72	20:08	195,69	18,54
15.11.23	2,99	398	133,00	10:49	200,04	14,18	21:13	195,71	18,51
16.11.23	4,69	623	132,91	7:31	200,02	14,20	11:49	195,70	18,52
17.11.23	3,44	468	135,94	6:01	199,98	14,24	18:54	195,58	18,64
18.11.23	1,41	175	124,41	23:58	200,10	14,12	1:19	195,54	18,68
19.11.23	1,20	161	133,67	8:39	200,15	14,07	10:44	195,84	18,38
20.11.23	4,81	644	133,97	14:18	200,43	13,80	18:00	195,68	18,54
21.11.23	3,96	530	133,71	10:01	200,37	13,86	20:44	195,76	18,47
22.11.23	9,81	1.371	139,69	13:58	200,09	14,13	20:58	195,29	18,93
23.11.23	24,00	3.305	137,71	---	---	---	11:13	195,32	18,90
24.11.23	24,00	3.316	138,17	---	---	---	5:44	195,14	19,09
25.11.23	24,00	3.323	138,46	---	---	---	5:25	195,08	19,14
26.11.23	9,62	1.324	137,67	23:51	200,42	13,80	9:31	195,12	19,10
27.11.23	0,00	0	---	20:03	200,68	13,54	---	---	---
28.11.23	0,38	54	140,36	6:04	200,74	13,48	---	---	---
29.11.23	1,47	201	136,35	21:23	200,77	13,45	9:03	195,68	18,54
30.11.23	0,00	0	---	18:25	200,83	13,39	---	---	---
<b>Σ</b>	<b>232,57</b>	<b>31.604</b>							
<b>Mittelwert</b>	<b>7,75</b>	<b>1.053</b>	<b>135,89</b>		<b>200,22</b>	<b>14,00</b>		<b>195,46</b>	<b>18,76</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>124,41</b>		<b>199,65</b>	<b>13,39</b>		<b>194,89</b>	<b>18,31</b>
<b>Maximum</b>	<b>24,00</b>	<b>3.323</b>	<b>147,53</b>		<b>200,83</b>	<b>14,57</b>		<b>195,92</b>	<b>19,33</b>

Meßpunkthöhe (MP): 214,22 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB14**  
**Monatsbericht vom November 2023**  
gedruckt am: 18.12.2023, 10:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.11.23	5,32	478	89,84	8:14	199,86	20,26	21:54	197,39	22,74
02.11.23	3,47	313	90,19	11:43	199,83	20,30	16:34	197,52	22,61
03.11.23	9,04	831	91,97	4:35	199,86	20,27	22:32	197,28	22,84
04.11.23	24,00	2.247	93,63	---	---	---	0:00	197,40	22,72
05.11.23	24,00	2.263	94,29	---	---	---	0:00	197,74	22,39
06.11.23	24,00	2.230	92,92	---	---	---	13:12	197,55	22,57
07.11.23	22,75	2.112	92,84	1:54	199,92	20,21	18:42	197,39	22,73
08.11.23	22,26	2.055	92,33	5:28	199,60	20,52	3:58	197,29	22,83
09.11.23	23,57	2.202	93,42	---	---	---	1:01	197,60	22,52
10.11.23	24,00	2.249	93,71	---	---	---	1:45	197,66	22,46
11.11.23	24,00	2.261	94,21	---	---	---	3:40	197,90	22,22
12.11.23	23,16	2.178	94,03	---	---	---	0:08	197,82	22,30
13.11.23	23,45	2.186	93,24	---	---	---	10:52	197,75	22,37
14.11.23	20,76	1.940	93,46	10:42	200,46	19,66	20:11	197,70	22,42
15.11.23	24,00	2.238	93,25	---	---	---	21:14	197,67	22,45
16.11.23	24,00	2.232	93,00	---	---	---	11:54	197,67	22,45
17.11.23	24,00	2.236	93,17	---	---	---	18:56	197,55	22,57
18.11.23	24,00	2.253	93,88	---	---	---	1:20	197,52	22,61
19.11.23	24,00	2.262	94,25	---	---	---	10:47	197,82	22,30
20.11.23	22,67	2.121	93,57	14:22	200,38	19,75	18:39	197,70	22,42
21.11.23	22,59	2.116	93,68	10:02	200,32	19,80	20:47	197,74	22,39
22.11.23	14,19	1.337	94,23	15:06	200,05	20,08	4:06	197,87	22,25
23.11.23	0,00	0	---	22:25	200,01	20,11	---	---	---
24.11.23	0,00	0	---	0:07	200,02	20,11	---	---	---
25.11.23	0,00	0	---	0:00	199,96	20,17	---	---	---
26.11.23	14,34	1.389	96,84	0:26	199,89	20,23	10:34	197,80	22,32
27.11.23	24,00	2.308	96,17	---	---	---	23:55	198,13	22,00
28.11.23	24,00	2.308	96,17	---	---	---	18:48	198,31	21,81
29.11.23	23,74	2.287	96,32	---	---	---	9:01	198,16	21,97
30.11.23	24,00	2.318	96,58	---	---	---	0:00	198,46	21,66
<b>Σ</b>	<b>563,30</b>	<b>52.950</b>							
<b>Mittelwert</b>	<b>18,78</b>	<b>1.765</b>	<b>94,00</b>		<b>200,01</b>	<b>20,11</b>		<b>197,72</b>	<b>22,40</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>89,84</b>		<b>199,60</b>	<b>19,66</b>		<b>197,28</b>	<b>21,66</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.318</b>	<b>96,84</b>		<b>200,46</b>	<b>20,52</b>		<b>198,46</b>	<b>22,84</b>

Meßpunkthöhe (MP): 220,12 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB15**  
**Monatsbericht vom November 2023**  
gedruckt am: 18.12.2023, 10:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.11.23	24,00	2.217	92,38	---	---	---	23:56	196,60	24,78
02.11.23	24,00	2.205	91,88	---	---	---	19:04	196,50	24,89
03.11.23	23,38	2.146	91,79	---	---	---	2:08	196,51	24,87
04.11.23	20,02	2.004	100,12	---	---	---	2:17	197,24	24,14
05.11.23	16,76	1.706	101,79	10:30	202,67	18,71	0:14	197,72	23,66
06.11.23	20,57	2.034	98,87	4:44	202,48	18,91	13:29	197,86	23,53
07.11.23	18,84	1.872	99,36	12:26	202,53	18,85	0:42	197,71	23,67
08.11.23	22,35	2.174	97,27	6:06	201,84	19,54	5:00	197,38	24,00
09.11.23	18,54	1.852	99,90	8:06	202,22	19,17	13:04	197,63	23,75
10.11.23	17,25	1.734	100,51	8:50	202,76	18,62	2:08	197,97	23,41
11.11.23	16,58	1.708	103,03	21:52	202,59	18,79	3:39	198,28	23,11
12.11.23	18,76	1.939	103,36	3:47	202,62	18,76	23:44	198,34	23,05
13.11.23	21,30	2.130	100,02	6:14	202,53	18,85	23:50	198,01	23,37
14.11.23	18,22	1.809	99,30	10:47	202,52	18,87	0:00	198,02	23,36
15.11.23	22,16	2.225	100,43	7:13	202,26	19,12	21:39	197,81	23,57
16.11.23	22,43	2.219	98,95	---	---	---	12:15	197,71	23,67
17.11.23	22,28	2.218	99,56	4:43	202,23	19,15	19:10	197,63	23,75
18.11.23	19,95	2.009	100,68	19:41	202,39	18,99	1:36	197,54	23,84
19.11.23	18,18	1.871	102,92	5:25	202,42	18,96	11:37	198,18	23,21
20.11.23	18,94	1.906	100,63	14:29	202,52	18,86	18:30	198,12	23,27
21.11.23	17,63	1.771	100,43	14:51	202,52	18,87	21:14	198,15	23,24
22.11.23	13,40	1.346	100,43	13:22	202,70	18,68	1:50	198,15	23,24
23.11.23	10,04	956	95,23	4:24	202,07	19,31	10:04	198,18	23,21
24.11.23	8,16	790	96,79	7:39	202,04	19,34	19:24	198,07	23,31
25.11.23	6,61	627	94,92	7:23	201,90	19,48	2:25	198,08	23,30
26.11.23	15,44	1.704	110,35	6:14	201,92	19,46	13:13	197,57	23,81
27.11.23	23,65	2.651	112,09	---	---	---	0:00	198,34	23,05
28.11.23	22,78	2.576	113,06	---	---	---	0:00	198,67	22,72
29.11.23	22,77	2.573	112,99	13:00	203,23	18,15	1:32	198,79	22,59
30.11.23	24,00	2.742	114,25	---	---	---	0:00	199,19	22,19
<b>Σ</b>	<b>568,99</b>	<b>57.714</b>							
<b>Mittelwert</b>	<b>18,97</b>	<b>1.924</b>	<b>101,43</b>		<b>202,41</b>	<b>18,97</b>		<b>197,86</b>	<b>23,52</b>
<b>Minimum</b>	<b>6,61</b>	<b>627</b>	<b>91,79</b>		<b>201,84</b>	<b>18,15</b>		<b>196,50</b>	<b>22,19</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.742</b>	<b>114,25</b>		<b>203,23</b>	<b>19,54</b>		<b>199,19</b>	<b>24,89</b>

Meßpunkthöhe (MP): 221,38 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB16**  
**Monatsbericht vom November 2023**  
gedruckt am: 18.12.2023, 10:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.11.23	24,00	2.196	91,50	---	---	---	3:02	199,02	26,83
02.11.23	24,00	2.192	91,33	---	---	---	0:00	199,02	26,83
03.11.23	20,71	1.881	90,82	19:24	201,71	24,13	0:00	199,02	26,83
04.11.23	1,20	109	91,00	22:06	203,10	22,74	23:45	199,03	26,81
05.11.23	1,05	95	90,50	10:18	204,08	21,76	22:04	199,39	26,45
06.11.23	5,13	474	92,31	4:46	203,71	22,13	23:24	199,02	26,83
07.11.23	13,01	1.224	94,09	12:41	204,18	21,66	0:07	199,02	26,83
08.11.23	7,68	698	90,88	15:12	203,09	22,75	0:49	199,02	26,83
09.11.23	4,27	384	89,96	8:20	203,41	22,44	1:00	199,02	26,83
10.11.23	3,71	337	90,88	8:53	204,06	21,78	1:44	199,17	26,67
11.11.23	0,74	75	101,05	21:54	203,88	21,96	---	---	---
12.11.23	1,67	152	91,11	11:01	203,93	21,92	5:39	199,98	25,86
13.11.23	5,14	470	91,38	6:24	203,76	22,08	10:52	199,39	26,45
14.11.23	6,53	605	92,58	11:16	204,03	21,81	8:51	199,08	26,77
15.11.23	3,19	283	88,84	7:21	203,49	22,35	21:13	199,08	26,77
16.11.23	4,85	441	90,86	19:37	203,18	22,67	11:50	199,02	26,83
17.11.23	3,56	331	92,91	4:49	203,40	22,44	18:38	199,01	26,83
18.11.23	1,42	122	85,73	19:44	203,59	22,25	0:42	199,02	26,83
19.11.23	1,24	113	91,37	7:30	203,74	22,10	10:46	199,43	26,41
20.11.23	4,87	449	92,12	14:16	203,93	21,91	18:12	199,22	26,62
21.11.23	5,33	492	92,28	4:53	203,67	22,17	9:09	199,08	26,76
22.11.23	9,83	938	95,40	13:22	203,98	21,86	23:20	199,01	26,83
23.11.23	24,00	2.237	93,21	---	---	---	0:20	199,01	26,83
24.11.23	24,00	2.239	93,29	---	---	---	0:17	199,01	26,83
25.11.23	24,00	2.242	93,42	---	---	---	0:17	199,01	26,83
26.11.23	9,63	896	93,00	23:56	204,52	21,32	0:27	199,01	26,83
27.11.23	0,00	0	---	20:07	205,06	20,78	---	---	---
28.11.23	0,20	19	94,48	6:46	205,52	20,32	---	---	---
29.11.23	1,48	138	93,45	21:23	205,69	20,15	8:59	201,02	24,83
30.11.23	0,00	0	---	7:55	205,80	20,05	---	---	---
<b>Σ</b>	<b>236,46</b>	<b>21.832</b>							
<b>Mittelwert</b>	<b>7,88</b>	<b>728</b>	<b>92,33</b>		<b>203,94</b>	<b>21,90</b>		<b>199,19</b>	<b>26,65</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>85,73</b>		<b>201,71</b>	<b>20,05</b>		<b>199,01</b>	<b>24,83</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.242</b>	<b>101,05</b>		<b>205,80</b>	<b>24,13</b>		<b>201,02</b>	<b>26,83</b>

Meßpunkthöhe (MP): 225,84 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB17**  
**Monatsbericht vom November 2023**  
gedruckt am: 18.12.2023, 10:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.11.23	19,91	1.924	96,65	8:07	202,69	28,73	23:46	193,51	37,90
02.11.23	20,35	1.983	97,46	4:48	202,00	29,41	18:22	193,47	37,95
03.11.23	20,87	2.040	97,76	4:26	202,47	28,94	18:44	192,52	38,89
04.11.23	24,00	2.464	102,67	---	---	---	0:00	192,71	38,71
05.11.23	22,02	2.290	104,00	9:51	204,23	27,19	2:54	193,48	37,93
06.11.23	23,73	2.423	102,10	---	---	---	0:33	193,70	37,72
07.11.23	10,65	1.087	102,06	12:56	204,58	26,84	5:48	193,88	37,53
08.11.23	23,37	2.350	100,54	---	---	---	13:58	193,50	37,92
09.11.23	23,47	2.408	102,62	---	---	---	5:26	193,42	37,99
10.11.23	22,96	2.375	103,43	6:36	203,77	27,64	2:56	193,51	37,90
11.11.23	24,00	2.511	104,63	---	---	---	4:08	193,71	37,70
12.11.23	23,17	2.407	103,88	---	---	---	2:12	193,79	37,63
13.11.23	23,69	2.412	101,83	---	---	---	4:13	193,61	37,81
14.11.23	21,16	2.159	102,05	11:03	204,09	27,32	1:23	193,58	37,84
15.11.23	24,00	2.444	101,83	---	---	---	2:27	193,51	37,90
16.11.23	24,00	2.429	101,21	---	---	---	15:20	193,22	38,19
17.11.23	24,00	2.439	101,63	---	---	---	3:20	193,38	38,04
18.11.23	24,00	2.470	102,92	---	---	---	3:11	193,07	38,34
19.11.23	24,00	2.489	103,71	---	---	---	13:57	193,62	37,79
20.11.23	22,68	2.327	102,62	14:47	204,00	27,42	19:09	193,65	37,76
21.11.23	23,51	2.422	103,01	---	---	---	12:27	193,59	37,82
22.11.23	24,00	2.502	104,25	---	---	---	4:36	193,61	37,81
23.11.23	24,00	2.370	98,75	---	---	---	22:40	193,64	37,78
24.11.23	23,53	2.327	98,88	---	---	---	20:25	193,56	37,86
25.11.23	23,40	2.319	99,09	---	---	---	3:28	193,50	37,92
26.11.23	12,45	1.256	100,87	23:55	205,52	25,89	9:33	193,03	38,39
27.11.23	9,32	1.032	110,74	6:24	205,97	25,45	10:05	195,64	35,78
28.11.23	8,50	950	111,72	15:45	206,41	25,01	18:41	195,88	35,54
29.11.23	7,08	761	107,50	21:21	206,59	24,82	0:48	195,91	35,51
30.11.23	7,91	883	111,63	7:49	206,67	24,75	9:45	196,46	34,96
<b>Σ</b>	<b>609,73</b>	<b>62.253</b>							
<b>Mittelwert</b>	<b>20,32</b>	<b>2.075</b>	<b>102,10</b>		<b>204,54</b>	<b>26,88</b>		<b>193,79</b>	<b>37,62</b>
<b>Minimum</b>	<b>7,08</b>	<b>761</b>	<b>96,65</b>		<b>202,00</b>	<b>24,75</b>		<b>192,52</b>	<b>34,96</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.511</b>	<b>111,72</b>		<b>206,67</b>	<b>29,41</b>		<b>196,46</b>	<b>38,89</b>

Meßpunkthöhe (MP): 231,41 m üNN

**ZMW Gießen**  
**Wasserwerk Stadtallendorf**  
**Brunnenbericht WAB18**  
**Monatsbericht vom November 2023**  
gedruckt am: 18.12.2023, 10:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.11.23	24,00	2.063	85,96	---	---	---	18:40	203,00	29,05
02.11.23	24,00	2.053	85,54	---	---	---	17:01	203,00	29,05
03.11.23	23,40	2.004	85,62	---	---	---	16:16	203,00	29,05
04.11.23	20,08	1.768	88,03	---	---	---	1:37	203,01	29,04
05.11.23	16,82	1.482	88,09	10:36	210,77	21,28	1:13	203,01	29,04
06.11.23	20,61	1.799	87,31	4:43	210,31	21,74	13:17	203,01	29,04
07.11.23	18,87	1.681	89,11	12:27	210,03	22,02	0:00	203,01	29,04
08.11.23	22,37	1.936	86,54	6:06	209,12	22,93	4:20	203,01	29,04
09.11.23	19,29	1.685	87,37	8:05	209,49	22,56	0:00	203,01	29,04
10.11.23	17,32	1.518	87,66	8:53	211,12	20,93	21:27	203,01	29,04
11.11.23	16,68	1.480	88,75	10:00	210,38	21,67	3:40	203,01	29,04
12.11.23	18,98	1.687	88,89	3:54	210,69	21,36	19:52	203,01	29,04
13.11.23	21,33	1.863	87,36	6:13	210,05	22,00	22:08	203,00	29,05
14.11.23	18,75	1.632	87,06	10:49	209,82	22,23	0:00	203,01	29,04
15.11.23	22,19	1.939	87,39	7:14	209,28	22,77	1:30	203,00	29,05
16.11.23	22,46	1.961	87,31	---	---	---	0:00	203,01	29,04
17.11.23	22,29	1.955	87,70	4:44	209,47	22,58	0:00	203,01	29,04
18.11.23	20,01	1.756	87,74	19:42	209,91	22,14	0:00	203,01	29,04
19.11.23	18,25	1.616	88,53	5:28	209,75	22,30	20:16	203,04	29,01
20.11.23	19,01	1.667	87,70	20:09	209,84	22,21	10:52	203,01	29,04
21.11.23	19,07	1.681	88,15	14:54	210,34	21,71	9:33	203,01	29,04
22.11.23	13,53	1.193	88,14	19:19	210,94	21,11	0:00	203,01	29,04
23.11.23	24,00	2.062	85,92	---	---	---	5:34	203,01	29,04
24.11.23	24,00	2.068	86,17	---	---	---	0:05	203,01	29,04
25.11.23	24,00	2.075	86,46	---	---	---	0:00	203,01	29,04
26.11.23	9,60	826	86,04	23:59	212,36	19,69	0:06	203,01	29,04
27.11.23	0,00	0	---	22:13	213,03	19,02	---	---	---
28.11.23	0,37	34	92,24	15:38	213,28	18,77	---	---	---
29.11.23	1,47	129	87,61	21:34	213,43	18,62	---	---	---
30.11.23	0,00	0	---	7:39	213,56	18,49	---	---	---
<b>Σ</b>	<b>522,75</b>	<b>45.613</b>							
<b>Mittelwert</b>	<b>17,42</b>	<b>1.520</b>	<b>87,26</b>		<b>210,77</b>	<b>21,28</b>		<b>203,01</b>	<b>29,04</b>
<b>Minimum</b>	<b>0,00</b>	<b>0</b>	<b>85,54</b>		<b>209,12</b>	<b>18,49</b>		<b>203,00</b>	<b>29,01</b>
<b>Maximum</b>	<b>24,00</b>	<b>2.075</b>	<b>92,24</b>		<b>213,56</b>	<b>22,93</b>		<b>203,04</b>	<b>29,05</b>

Meßpunkthöhe (MP): 232,05 m üNN