

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom März 2024
gedruckt am: 05.04.2024, 07:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.24	13,86	1.432	103,35	6:41	199,63	14,64	23:58	194,79	19,49
02.03.24	9,27	947	102,11	21:38	199,56	14,71	0:37	194,76	19,51
03.03.24	9,32	960	103,03	7:06	199,63	14,64	22:43	194,92	19,35
04.03.24	14,32	1.468	102,52	6:19	199,56	14,71	23:47	194,69	19,59
05.03.24	11,14	1.162	104,28	12:17	199,82	14,46	2:14	194,83	19,44
06.03.24	10,88	1.132	104,03	7:38	200,13	14,14	0:03	195,18	19,10
07.03.24	10,89	1.120	102,86	7:12	200,46	13,82	20:45	195,35	18,92
08.03.24	9,62	1.001	104,02	10:04	200,07	14,20	2:36	195,30	18,97
09.03.24	11,70	1.198	102,39	8:14	199,97	14,30	13:47	195,25	19,02
10.03.24	2,83	293	103,65	11:47	200,41	13,86	16:56	196,02	18,25
11.03.24	3,09	319	103,34	7:43	200,51	13,76	10:27	195,92	18,35
12.03.24	10,20	1.060	103,87	10:57	200,49	13,79	23:48	195,14	19,13
13.03.24	13,77	1.410	102,36	5:56	199,79	14,49	0:47	195,07	19,20
14.03.24	14,13	1.453	102,81	6:46	199,91	14,36	22:43	195,04	19,23
15.03.24	10,70	1.103	103,09	7:38	199,92	14,35	22:11	195,05	19,22
16.03.24	10,48	1.080	103,08	20:27	199,73	14,54	12:29	195,08	19,19
17.03.24	5,00	517	103,50	12:08	199,97	14,30	---	---	---
18.03.24	11,48	1.191	103,73	5:38	199,92	14,35	18:31	195,05	19,22
19.03.24	9,96	1.027	103,09	4:20	199,94	14,33	18:32	195,13	19,14
20.03.24	12,66	1.303	102,94	5:32	199,98	14,29	16:37	194,97	19,30
21.03.24	18,83	1.940	103,00	4:42	199,60	14,67	23:53	194,63	19,65
22.03.24	24,00	2.466	102,75	---	---	---	17:45	194,56	19,71
23.03.24	22,00	2.275	103,42	---	---	---	0:25	194,54	19,73
24.03.24	22,77	2.354	103,37	---	---	---	2:39	194,63	19,65
25.03.24	23,06	2.377	103,10	---	---	---	23:03	194,60	19,68
26.03.24	20,93	2.154	102,93	11:58	199,63	14,64	1:44	194,64	19,63
27.03.24	23,01	2.367	102,87	---	---	---	21:46	194,60	19,68
28.03.24	19,60	2.018	102,94	12:17	200,08	14,20	0:39	194,63	19,65
29.03.24	22,29	2.310	103,63	6:27	199,44	14,83	0:02	194,76	19,52
30.03.24	24,00	2.482	103,42	---	---	---	13:17	194,71	19,56
31.03.24	14,31	1.474	103,04	23:45	199,85	14,42	14:36	194,77	19,50
Σ	440,10	45.393							
Mittelwert	14,20	1.464	103,14		199,92	14,35		194,95	19,32
Minimum	2,83	293	102,11		199,44	13,76		194,54	18,25
Maximum	24,00	2.482	104,28		200,51	14,83		196,02	19,73

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom März 2024
gedruckt am: 05.04.2024, 07:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.24	24,00	3.349	139,54	---	---	---	19:44	195,59	18,64
02.03.24	24,00	3.379	140,79	---	---	---	0:50	195,56	18,67
03.03.24	24,00	3.382	140,92	---	---	---	22:58	195,56	18,66
04.03.24	24,00	3.336	139,00	---	---	---	23:57	195,43	18,79
05.03.24	9,99	1.393	139,50	20:28	201,00	13,22	4:55	195,39	18,83
06.03.24	0,00	0	---	6:40	201,33	12,90	---	---	---
07.03.24	7,32	1.057	144,33	7:11	201,79	12,43	23:14	196,45	17,77
08.03.24	23,35	3.349	143,43	---	---	---	6:22	196,36	17,86
09.03.24	24,00	3.425	142,71	---	---	---	13:59	196,33	17,89
10.03.24	20,00	2.908	145,42	4:29	201,40	12,82	3:19	196,32	17,90
11.03.24	20,73	3.006	145,00	2:16	201,70	12,52	0:22	196,50	17,72
12.03.24	19,88	2.836	142,69	11:01	201,76	12,46	18:54	196,40	17,82
13.03.24	23,68	3.354	141,65	---	---	---	4:26	196,16	18,06
14.03.24	24,00	3.398	141,58	---	---	---	12:07	196,16	18,06
15.03.24	23,57	3.356	142,40	---	---	---	22:39	196,14	18,08
16.03.24	24,00	3.415	142,29	---	---	---	12:46	196,09	18,13
17.03.24	23,52	3.385	143,89	---	---	---	11:28	196,14	18,08
18.03.24	24,00	3.413	142,21	---	---	---	18:43	196,13	18,09
19.03.24	22,30	3.174	142,35	---	---	---	18:47	196,12	18,10
20.03.24	22,59	3.199	141,62	5:27	201,20	13,02	16:59	196,10	18,12
21.03.24	17,99	2.519	140,05	11:40	200,92	13,31	19:00	195,85	18,38
22.03.24	14,43	1.985	137,61	11:05	200,58	13,64	0:07	195,80	18,42
23.03.24	7,22	1.000	138,49	8:57	200,97	13,25	0:14	195,81	18,41
24.03.24	8,18	1.126	137,61	22:08	200,95	13,28	2:35	195,95	18,27
25.03.24	11,32	1.561	137,88	7:33	201,11	13,11	22:59	195,89	18,33
26.03.24	15,22	2.127	139,74	5:40	200,86	13,36	23:12	195,89	18,33
27.03.24	13,88	1.924	138,57	8:59	200,94	13,28	21:41	195,89	18,34
28.03.24	11,96	1.637	136,83	12:09	201,51	12,71	22:33	195,89	18,34
29.03.24	4,91	694	141,29	7:42	201,11	13,12	14:15	196,11	18,11
30.03.24	7,53	1.050	139,42	22:35	201,03	13,19	1:35	196,17	18,05
31.03.24	12,16	1.735	142,70	6:24	201,06	13,16	22:37	196,22	18,00
Σ	533,73	75.472							
Mittelwert	17,22	2.435	141,40		201,18	13,04		196,01	18,21
Minimum	0,00	0	136,83		200,58	12,43		195,39	17,72
Maximum	24,00	3.425	145,42		201,79	13,64		196,50	18,83

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom März 2024
gedruckt am: 05.04.2024, 07:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.24	24,00	2.248	93,67	---	---	---	19:55	198,10	22,03
02.03.24	24,00	2.259	94,13	---	---	---	0:43	198,06	22,06
03.03.24	24,00	2.261	94,21	---	---	---	23:10	198,06	22,07
04.03.24	23,46	2.191	93,39	---	---	---	23:52	197,94	22,19
05.03.24	22,26	2.120	95,23	11:04	200,62	19,50	0:22	197,93	22,20
06.03.24	23,19	2.242	96,70	---	---	---	0:07	198,73	21,39
07.03.24	12,69	1.223	96,39	7:08	201,72	18,41	0:12	199,00	21,13
08.03.24	0,00	0	---	7:01	201,39	18,73	---	---	---
09.03.24	0,00	0	---	7:43	201,22	18,90	---	---	---
10.03.24	0,00	0	---	11:45	201,62	18,51	---	---	---
11.03.24	0,00	0	---	7:37	201,72	18,40	---	---	---
12.03.24	2,42	231	95,33	10:55	201,74	18,38	23:58	198,86	21,26
13.03.24	0,75	62	82,73	4:50	201,14	18,98	---	---	---
14.03.24	0,00	0	---	7:08	201,08	19,04	---	---	---
15.03.24	0,00	0	---	6:18	201,15	18,98	---	---	---
16.03.24	0,00	0	---	2:48	200,99	19,14	---	---	---
17.03.24	0,00	0	---	11:57	201,10	19,02	---	---	---
18.03.24	0,00	0	---	5:30	201,05	19,08	---	---	---
19.03.24	1,65	153	92,76	12:16	201,17	18,95	---	---	---
20.03.24	0,00	0	---	5:28	201,23	18,89	---	---	---
21.03.24	15,65	1.484	94,82	4:53	200,92	19,21	19:02	198,17	21,95
22.03.24	24,00	2.261	94,21	---	---	---	0:09	198,10	22,03
23.03.24	24,00	2.300	95,83	---	---	---	0:16	198,13	22,00
24.03.24	24,00	2.298	95,75	---	---	---	2:37	198,28	21,84
25.03.24	24,00	2.283	95,13	---	---	---	23:01	198,25	21,87
26.03.24	21,29	2.010	94,40	11:07	200,99	19,14	23:14	198,25	21,87
27.03.24	24,00	2.268	94,50	---	---	---	21:43	198,22	21,90
28.03.24	20,25	1.913	94,47	12:15	201,48	18,64	22:35	198,23	21,89
29.03.24	24,00	2.314	96,42	---	---	---	0:00	198,46	21,66
30.03.24	24,00	2.302	95,92	---	---	---	1:37	198,51	21,62
31.03.24	17,52	1.680	95,92	17:48	201,07	19,05	14:29	198,64	21,49
Σ	401,13	38.103							
Mittelwert	12,94	1.229	94,99		201,23	18,89		198,31	21,81
Minimum	0,00	0	82,73		200,62	18,38		197,93	21,13
Maximum	24,00	2.314	96,70		201,74	19,50		199,00	22,20

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom März 2024
gedruckt am: 05.04.2024, 07:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.24	0,00	0	---	7:13	204,00	17,39	---	---	---
02.03.24	0,00	0	---	21:40	203,98	17,40	---	---	---
03.03.24	0,00	0	---	7:21	204,07	17,32	---	---	---
04.03.24	0,96	93	97,04	5:57	204,00	17,38	---	---	---
05.03.24	14,11	1.610	114,10	10:34	203,93	17,45	19:55	199,99	21,40
06.03.24	24,00	2.762	115,08	---	---	---	0:44	199,87	21,51
07.03.24	24,00	2.706	112,75	---	---	---	23:55	199,62	21,76
08.03.24	24,00	2.522	105,08	---	---	---	6:31	199,04	22,34
09.03.24	24,00	2.465	102,71	---	---	---	14:28	198,76	22,63
10.03.24	24,00	2.580	107,50	---	---	---	3:33	198,30	23,08
11.03.24	24,00	2.575	107,29	---	---	---	0:31	198,70	22,69
12.03.24	23,11	2.392	103,52	---	---	---	6:03	198,57	22,82
13.03.24	24,00	2.407	100,29	---	---	---	4:39	197,89	23,50
14.03.24	24,00	2.389	99,54	---	---	---	23:40	197,89	23,50
15.03.24	24,00	2.418	100,75	---	---	---	5:58	197,62	23,76
16.03.24	24,00	2.405	100,21	---	---	---	13:15	197,81	23,57
17.03.24	24,00	2.469	102,88	---	---	---	11:39	197,60	23,78
18.03.24	24,00	2.402	100,08	---	---	---	19:36	197,76	23,62
19.03.24	24,00	2.427	101,13	---	---	---	3:57	197,51	23,87
20.03.24	24,00	2.396	99,83	---	---	---	4:17	197,40	23,99
21.03.24	8,32	826	99,29	20:20	202,81	18,58	8:14	197,51	23,87
22.03.24	0,53	50	94,34	21:46	203,22	18,17	---	---	---
23.03.24	0,00	0	---	10:00	203,90	17,48	---	---	---
24.03.24	0,00	0	---	21:52	204,19	17,20	---	---	---
25.03.24	0,67	66	98,75	9:13	204,42	16,96	---	---	---
26.03.24	2,92	335	114,78	5:42	204,17	17,21	11:52	200,03	21,35
27.03.24	1,15	112	97,20	8:49	204,32	17,07	11:14	200,97	20,41
28.03.24	3,37	352	104,35	11:43	204,65	16,74	16:37	201,00	20,38
29.03.24	0,00	0	---	10:52	204,60	16,78	---	---	---
30.03.24	0,00	0	---	22:20	204,65	16,74	---	---	---
31.03.24	8,68	961	110,66	6:41	204,72	16,66	23:40	200,24	21,14
Σ	399,82	41.720							
Mittelwert	12,90	1.346	104,35		204,10	17,28		198,76	22,62
Minimum	0,00	0	94,34		202,81	16,66		197,40	20,38
Maximum	24,00	2.762	115,08		204,72	18,58		201,00	23,99

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom März 2024
gedruckt am: 05.04.2024, 07:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.24	24,00	2.316	96,50	---	---	---	19:51	200,15	25,70
02.03.24	24,00	2.339	97,46	---	---	---	0:49	200,02	25,82
03.03.24	24,00	2.344	97,67	---	---	---	22:57	200,33	25,51
04.03.24	24,00	2.317	96,54	---	---	---	23:57	200,06	25,78
05.03.24	10,01	969	96,76	20:27	205,51	20,34	0:04	200,04	25,80
06.03.24	0,00	0	---	7:53	206,03	19,81	---	---	---
07.03.24	7,34	712	97,00	7:44	206,52	19,32	23:25	200,46	25,38
08.03.24	23,38	2.242	95,88	---	---	---	20:54	199,76	26,09
09.03.24	24,00	2.279	94,96	---	---	---	14:01	199,28	26,56
10.03.24	20,17	1.957	97,04	4:26	204,01	21,83	3:19	199,31	26,53
11.03.24	20,80	2.018	97,03	7:38	204,80	21,04	0:23	199,82	26,03
12.03.24	20,86	1.982	95,00	10:58	204,76	21,08	23:49	199,34	26,50
13.03.24	23,71	2.231	94,09	---	---	---	16:13	199,01	26,83
14.03.24	24,00	2.256	94,00	---	---	---	0:22	199,01	26,83
15.03.24	23,60	2.233	94,62	---	---	---	17:13	199,01	26,83
16.03.24	24,00	2.270	94,58	---	---	---	0:22	199,01	26,83
17.03.24	23,56	2.260	95,93	---	---	---	0:00	199,02	26,83
18.03.24	24,00	2.268	94,50	---	---	---	10:26	199,01	26,83
19.03.24	21,91	2.076	94,73	---	---	---	0:08	199,01	26,83
20.03.24	22,62	2.126	93,99	5:28	203,41	22,43	13:17	199,01	26,83
21.03.24	18,09	1.703	94,15	11:36	203,71	22,13	7:52	199,01	26,83
22.03.24	14,65	1.377	93,96	11:07	204,06	21,79	0:08	199,30	26,54
23.03.24	7,35	697	94,78	9:06	205,20	20,64	0:15	199,67	26,17
24.03.24	8,33	784	94,14	22:14	205,42	20,42	2:36	200,24	25,61
25.03.24	11,42	1.083	94,81	7:37	205,81	20,03	23:00	200,25	25,59
26.03.24	15,00	1.435	95,68	9:58	205,42	20,42	23:13	200,30	25,54
27.03.24	14,06	1.338	95,14	8:57	205,46	20,38	21:42	200,34	25,50
28.03.24	12,10	1.137	94,00	11:58	206,22	19,63	22:34	200,31	25,53
29.03.24	4,99	484	96,91	7:51	205,99	19,85	14:17	201,09	24,75
30.03.24	7,69	736	95,65	22:46	205,86	19,98	13:11	201,08	24,77
31.03.24	12,29	1.200	97,65	6:53	205,94	19,90	23:50	200,88	24,96
Σ	535,95	51.169							
Mittelwert	17,29	1.651	95,47		205,23	20,61		199,77	26,07
Minimum	0,00	0	93,96		203,41	19,32		199,01	24,75
Maximum	24,00	2.344	97,67		206,52	22,43		201,09	26,83

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom März 2024

gedruckt am: 05.04.2024, 07:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.24	13,86	1.399	100,94	6:43	205,13	26,29	23:57	195,51	35,90
02.03.24	9,29	927	99,79	21:38	205,05	26,36	0:38	195,47	35,95
03.03.24	9,32	941	100,92	7:28	205,31	26,10	22:50	195,85	35,57
04.03.24	12,78	1.282	100,30	6:18	205,17	26,24	23:52	195,39	36,02
05.03.24	10,50	1.138	108,42	15:47	205,78	25,63	2:17	195,59	35,83
06.03.24	10,89	1.207	110,82	7:48	206,62	24,79	0:00	195,73	35,69
07.03.24	10,90	1.158	106,23	7:48	207,25	24,17	12:18	196,35	35,06
08.03.24	9,63	963	100,05	9:47	205,05	26,36	23:57	195,54	35,87
09.03.24	11,72	1.149	98,07	8:10	204,23	27,19	13:43	195,15	36,27
10.03.24	2,83	282	99,58	11:56	205,17	26,24	16:56	196,43	34,99
11.03.24	3,09	308	99,69	7:46	205,46	25,95	10:30	196,47	34,94
12.03.24	11,27	1.123	99,61	11:18	205,28	26,13	22:23	195,01	36,41
13.03.24	13,79	1.348	97,74	5:53	203,63	27,78	1:17	194,73	36,68
14.03.24	14,14	1.386	98,01	7:04	203,82	27,60	22:50	194,48	36,94
15.03.24	10,71	1.054	98,41	8:01	203,82	27,60	22:27	194,55	36,86
16.03.24	10,49	1.033	98,46	20:26	203,47	27,95	12:38	194,63	36,79
17.03.24	5,00	496	99,12	12:43	203,98	27,43	---	---	---
18.03.24	11,51	1.139	98,92	5:48	203,83	27,58	18:25	194,60	36,82
19.03.24	9,77	965	98,75	13:30	204,01	27,40	23:57	194,78	36,63
20.03.24	12,67	1.244	98,22	6:02	203,97	27,45	16:43	194,46	36,95
21.03.24	18,84	1.931	102,49	8:14	203,18	28,24	19:19	193,83	37,58
22.03.24	24,00	2.487	103,63	---	---	---	0:26	193,80	37,61
23.03.24	22,01	2.370	107,70	---	---	---	0:32	194,09	37,32
24.03.24	22,78	2.449	107,53	---	---	---	2:52	194,66	36,76
25.03.24	23,06	2.445	106,04	---	---	---	23:25	194,57	36,85
26.03.24	20,18	2.107	104,41	11:53	205,69	25,72	23:28	194,58	36,83
27.03.24	23,01	2.401	104,34	---	---	---	0:00	194,63	36,79
28.03.24	19,61	2.055	104,82	12:25	206,53	24,88	22:49	194,69	36,73
29.03.24	22,29	2.441	109,50	6:28	205,49	25,92	0:00	194,83	36,59
30.03.24	24,00	2.603	108,46	---	---	---	2:15	195,31	36,10
31.03.24	14,31	1.556	108,73	18:52	205,63	25,78	14:46	195,27	36,15
Σ	438,25	45.387							
Mittelwert	14,14	1.464	103,56		204,90	26,51		195,03	36,38
Minimum	2,83	282	97,74		203,18	24,17		193,80	34,94
Maximum	24,00	2.603	110,82		207,25	28,24		196,47	37,61

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom März 2024
gedruckt am: 05.04.2024, 07:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.24	24,00	2.145	89,38	---	---	---	20:19	203,42	28,64
02.03.24	24,00	2.163	90,13	---	---	---	1:23	203,34	28,72
03.03.24	24,00	2.162	90,08	---	---	---	23:44	203,54	28,52
04.03.24	24,00	2.150	89,58	---	---	---	23:59	203,40	28,65
05.03.24	10,04	903	89,93	23:02	213,05	19,00	2:48	203,32	28,73
06.03.24	0,00	0	---	23:35	213,66	18,39	---	---	---
07.03.24	7,26	666	91,68	7:44	214,03	18,03	23:58	204,62	27,43
08.03.24	23,27	2.083	89,50	---	---	---	21:12	203,71	28,35
09.03.24	24,00	2.127	88,63	---	---	---	19:50	203,35	28,70
10.03.24	19,62	1.784	90,91	11:49	210,73	21,33	0:13	203,35	28,70
11.03.24	20,58	1.870	90,87	2:20	211,18	20,87	22:41	203,63	28,43
12.03.24	20,99	1.866	88,90	11:05	211,31	20,75	19:15	203,60	28,46
13.03.24	23,60	2.080	88,12	---	---	---	21:50	203,00	29,05
14.03.24	24,00	2.104	87,67	---	---	---	3:33	203,00	29,05
15.03.24	23,49	2.074	88,29	---	---	---	2:48	203,00	29,05
16.03.24	24,00	2.114	88,08	---	---	---	1:16	203,00	29,05
17.03.24	23,45	2.111	90,03	---	---	---	0:27	203,00	29,05
18.03.24	24,00	2.119	88,29	---	---	---	19:25	203,00	29,05
19.03.24	22,26	1.979	88,91	12:19	209,63	22,43	0:13	203,00	29,05
20.03.24	22,51	1.980	87,95	5:33	209,89	22,17	1:46	203,00	29,05
21.03.24	17,76	1.564	88,06	11:44	210,80	21,25	0:48	203,00	29,05
22.03.24	13,90	1.216	87,51	11:13	211,03	21,02	0:04	203,78	28,27
23.03.24	6,97	608	87,22	10:17	212,65	19,40	0:12	204,32	27,74
24.03.24	7,81	688	88,10	22:32	212,68	19,37	2:34	205,05	27,00
25.03.24	11,10	978	88,13	9:19	213,16	18,90	22:54	204,53	27,52
26.03.24	12,40	1.095	88,28	12:24	212,82	19,23	23:09	204,44	27,61
27.03.24	13,44	1.190	88,52	9:03	212,45	19,60	17:38	204,67	27,39
28.03.24	11,79	1.027	87,08	12:14	213,17	18,88	22:22	204,39	27,66
29.03.24	4,70	425	90,40	11:02	213,20	18,85	14:13	205,89	26,16
30.03.24	7,15	640	89,48	22:55	213,11	18,94	1:33	205,95	26,10
31.03.24	11,85	1.086	91,62	6:55	213,19	18,87	23:34	204,46	27,60
Σ	527,97	46.997							
Mittelwert	17,03	1.516	89,01		212,20	19,86		203,79	28,26
Minimum	0,00	0	87,08		209,63	18,03		203,00	26,10
Maximum	24,00	2.163	91,68		214,03	22,43		205,95	29,05

Meßpunkthöhe (MP): 232,05 m üNN