

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	24,00	1.218	50,75	---	---	---	0:00	193,99	15,77
02.07.24	22,67	1.150	50,72	11:15	195,65	14,11	5:12	193,99	15,77
03.07.24	24,00	1.215	50,63	---	---	---	11:25	194,02	15,74
04.07.24	24,00	1.209	50,38	---	---	---	11:55	194,07	15,69
05.07.24	24,00	1.216	50,67	---	---	---	6:15	194,07	15,69
06.07.24	24,00	1.218	50,75	---	---	---	0:04	194,16	15,60
07.07.24	24,00	1.220	50,83	---	---	---	2:04	194,14	15,62
08.07.24	24,00	1.210	50,42	---	---	---	14:04	194,18	15,58
09.07.24	23,92	1.198	50,09	---	---	---	12:39	194,06	15,70
10.07.24	22,91	1.152	50,29	15:11	195,73	14,03	12:39	194,02	15,74
11.07.24	24,00	1.213	50,54	---	---	---	23:45	193,90	15,87
12.07.24	24,00	1.201	50,04	---	---	---	22:13	193,75	16,01
13.07.24	24,00	1.215	50,63	---	---	---	3:40	193,84	15,93
14.07.24	24,00	1.219	50,79	---	---	---	22:43	193,93	15,84
15.07.24	24,00	1.196	49,83	---	---	---	23:43	193,69	16,07
16.07.24	24,00	1.185	49,38	---	---	---	10:52	186,00	23,76
17.07.24	24,00	1.200	50,00	---	---	---	1:24	193,48	16,28
18.07.24	24,00	1.193	49,71	---	---	---	23:43	193,44	16,32
19.07.24	24,00	1.190	49,58	---	---	---	23:48	193,38	16,39
20.07.24	24,00	1.208	50,33	---	---	---	0:00	193,38	16,39
21.07.24	24,00	1.221	50,88	---	---	---	2:18	193,85	15,91
22.07.24	24,00	1.217	50,71	---	---	---	0:00	193,94	15,82
23.07.24	21,78	1.104	50,69	12:08	195,82	13,94	0:48	193,96	15,81
24.07.24	22,27	1.119	50,25	9:39	195,86	13,90	18:00	193,80	15,97
25.07.24	24,00	1.209	50,38	---	---	---	21:10	193,72	16,04
26.07.24	24,00	1.213	50,54	---	---	---	0:00	193,84	15,93
27.07.24	24,00	1.219	50,79	---	---	---	0:37	193,96	15,81
28.07.24	24,00	1.230	51,25	---	---	---	0:00	194,03	15,73
29.07.24	24,00	1.221	50,88	---	---	---	20:19	193,96	15,81
30.07.24	24,00	1.209	50,38	---	---	---	1:59	193,90	15,87
31.07.24	24,00	1.213	50,54	---	---	---	23:42	193,99	15,77
Σ	737,55	37.201							
Mittelwert	23,79	1.200	50,44		195,77	13,99		193,63	16,13
Minimum	21,78	1.104	49,38		195,65	13,90		186,00	15,58
Maximum	24,00	1.230	51,25		195,86	14,11		194,18	23,76

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	0,00	0	---	4:57	199,47	8,35	---	---	---
02.07.24	1,86	426	229,55	8:39	199,85	7,97	10:28	192,97	14,85
03.07.24	0,59	133	226,60	21:46	199,36	8,46	---	---	---
04.07.24	0,73	161	220,97	12:45	199,56	8,26	---	---	---
05.07.24	0,00	0	---	8:30	199,57	8,25	---	---	---
06.07.24	0,00	0	---	10:44	199,45	8,37	---	---	---
07.07.24	0,00	0	---	10:49	199,64	8,18	---	---	---
08.07.24	0,00	0	---	7:05	199,47	8,35	---	---	---
09.07.24	2,21	488	220,32	9:15	199,36	8,46	10:52	192,82	15,00
10.07.24	0,65	147	226,64	23:55	200,28	7,54	---	---	---
11.07.24	8,99	2.091	232,51	7:54	200,58	7,24	23:26	192,45	15,38
12.07.24	14,58	3.384	232,06	5:53	199,51	8,31	22:01	192,30	15,52
13.07.24	9,07	2.078	229,16	9:17	199,89	7,94	3:11	192,64	15,19
14.07.24	12,01	2.854	237,71	5:29	200,00	7,82	20:39	192,74	15,09
15.07.24	24,00	5.636	234,83	---	---	---	23:47	192,02	15,80
16.07.24	22,89	5.322	232,50	12:04	198,29	9,53	10:52	186,00	21,82
17.07.24	24,00	5.661	235,88	---	---	---	1:07	191,90	15,92
18.07.24	24,00	5.617	234,04	---	---	---	23:41	191,65	16,17
19.07.24	24,00	5.601	233,38	---	---	---	23:48	191,55	16,27
20.07.24	5,00	1.150	229,80	23:40	198,86	8,96	0:00	191,57	16,25
21.07.24	0,00	0	---	23:59	199,31	8,51	---	---	---
22.07.24	0,00	0	---	4:27	199,37	8,45	---	---	---
23.07.24	0,31	69	224,19	9:02	199,18	8,64	---	---	---
24.07.24	11,00	2.555	232,24	9:52	200,34	7,48	17:49	192,45	15,38
25.07.24	11,72	2.710	231,26	10:01	200,15	7,67	20:52	192,32	15,50
26.07.24	10,08	2.350	233,13	11:09	199,71	8,11	14:51	192,79	15,03
27.07.24	8,64	1.989	230,24	21:08	199,98	7,85	4:58	193,07	14,75
28.07.24	5,38	1.272	236,44	9:57	200,28	7,54	17:07	193,16	14,67
29.07.24	8,67	2.014	232,24	9:30	200,30	7,52	20:04	192,73	15,09
30.07.24	5,13	1.168	227,73	8:23	199,62	8,20	1:42	192,67	15,15
31.07.24	0,68	151	220,44	18:48	199,09	8,73	---	---	---
Σ	236,19	55.027							
Mittelwert	7,62	1.775	232,98		199,65	8,17		192,09	15,73
Minimum	0,00	0	220,32		198,29	7,24		186,00	14,67
Maximum	24,00	5.661	237,71		200,58	9,53		193,16	21,82

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.07.24	24,00	3.460	144,17	---	---	---	22:51	190,12	22,72
02.07.24	23,59	3.389	143,64	---	---	---	10:30	189,93	22,90
03.07.24	24,00	3.448	143,67	---	---	---	10:44	189,64	23,19
04.07.24	24,00	3.435	143,13	---	---	---	10:38	189,95	22,89
05.07.24	24,00	3.452	143,83	---	---	---	5:55	190,15	22,69
06.07.24	24,00	3.456	144,00	---	---	---	0:46	190,38	22,46
07.07.24	24,00	3.464	144,33	---	---	---	1:54	190,32	22,52
08.07.24	24,00	3.436	143,17	---	---	---	23:34	190,22	22,61
09.07.24	23,86	3.386	141,93	---	---	---	23:13	189,43	23,41
10.07.24	14,51	2.057	141,74	23:30	194,81	18,02	0:25	189,75	23,09
11.07.24	0,00	0	---	7:49	195,17	17,67	---	---	---
12.07.24	0,00	0	---	5:49	194,07	18,77	---	---	---
13.07.24	0,00	0	---	9:14	194,40	18,43	---	---	---
14.07.24	5,42	788	145,29	5:29	194,56	18,28	12:58	190,53	22,31
15.07.24	0,00	0	---	0:39	194,00	18,83	---	---	---
16.07.24	3,83	518	135,32	5:07	193,45	19,38	10:43	188,60	24,23
17.07.24	0,00	0	---	12:05	193,76	19,08	---	---	---
18.07.24	0,87	116	132,95	10:15	193,73	19,11	---	---	---
19.07.24	1,20	159	132,29	7:37	193,41	19,43	---	---	---
20.07.24	18,98	2.730	143,85	4:29	192,90	19,93	7:12	189,29	23,54
21.07.24	24,00	3.465	144,38	---	---	---	1:53	189,78	23,06
22.07.24	24,00	3.459	144,13	---	---	---	22:25	190,01	22,82
23.07.24	24,00	3.448	143,67	---	---	---	10:08	189,90	22,93
24.07.24	8,20	1.171	142,86	9:53	195,24	17,59	0:21	189,97	22,87
25.07.24	0,00	0	---	9:59	194,74	18,10	---	---	---
26.07.24	0,00	0	---	11:06	194,30	18,54	---	---	---
27.07.24	0,00	0	---	20:58	194,56	18,28	---	---	---
28.07.24	0,00	0	---	14:53	194,88	17,96	---	---	---
29.07.24	0,00	0	---	9:21	194,88	17,96	---	---	---
30.07.24	15,37	2.202	143,24	8:21	194,22	18,62	15:40	189,46	23,38
31.07.24	24,00	3.439	143,29	---	---	---	23:06	189,46	23,38
Σ	379,84	54.478							
Mittelwert	12,25	1.757	143,42		194,28	18,55		189,83	23,00
Minimum	0,00	0	132,29		192,90	17,59		188,60	22,31
Maximum	24,00	3.465	145,29		195,24	19,93		190,53	24,23

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	23,05	4.459	193,49	---	---	---	22:54	177,46	32,65
02.07.24	21,06	4.044	192,06	8:53	194,74	15,37	20:45	177,48	32,64
03.07.24	23,69	4.565	192,68	---	---	---	1:50	177,39	32,73
04.07.24	21,84	4.184	191,60	12:33	194,09	16,03	20:36	177,68	32,44
05.07.24	22,48	4.330	192,61	---	---	---	23:30	177,69	32,42
06.07.24	24,00	4.643	193,46	---	---	---	14:37	178,03	32,09
07.07.24	22,67	4.393	193,74	---	---	---	1:51	177,87	32,24
08.07.24	24,00	4.606	191,92	---	---	---	16:03	177,74	32,38
09.07.24	23,42	4.443	189,72	---	---	---	11:48	177,25	32,87
10.07.24	22,78	4.352	191,02	15:28	194,07	16,04	12:39	177,08	33,03
11.07.24	23,82	4.591	192,73	---	---	---	23:38	177,00	33,11
12.07.24	24,00	4.555	189,79	---	---	---	0:00	177,00	33,11
13.07.24	24,00	4.618	192,42	---	---	---	0:41	177,00	33,11
14.07.24	14,88	2.862	192,38	18:03	194,27	15,84	3:15	177,14	32,97
15.07.24	11,49	2.154	187,40	7:23	194,04	16,07	23:34	177,78	32,33
16.07.24	14,44	2.698	186,81	4:56	193,36	16,76	19:34	177,37	32,74
17.07.24	7,22	1.365	188,99	10:14	193,81	16,30	0:54	177,74	32,38
18.07.24	13,20	2.461	186,39	9:10	193,83	16,29	23:26	177,46	32,65
19.07.24	13,74	2.572	187,24	7:41	193,39	16,73	23:25	177,39	32,73
20.07.24	21,40	4.127	192,82	4:28	192,75	17,37	6:57	177,02	33,10
21.07.24	23,26	4.508	193,83	---	---	---	1:43	177,31	32,81
22.07.24	23,59	4.578	194,06	---	---	---	21:55	177,48	32,64
23.07.24	24,00	4.629	192,88	---	---	---	11:34	177,42	32,70
24.07.24	21,82	4.175	191,38	10:11	194,99	15,13	21:34	177,16	32,96
25.07.24	24,00	4.610	192,08	---	---	---	21:33	177,00	33,11
26.07.24	24,00	4.615	192,29	---	---	---	0:00	177,08	33,03
27.07.24	24,00	4.650	193,75	---	---	---	6:53	177,00	33,11
28.07.24	24,00	4.690	195,42	---	---	---	0:00	177,39	32,73
29.07.24	24,00	4.649	193,71	---	---	---	20:16	177,05	33,06
30.07.24	24,00	4.582	190,92	---	---	---	1:47	177,00	33,11
31.07.24	24,00	4.591	191,29	---	---	---	2:10	177,00	33,11
Σ	657,85	126.299							
Mittelwert	21,22	4.074	191,99		193,94	16,17		177,34	32,77
Minimum	7,22	1.365	186,39		192,75	15,13		177,00	32,09
Maximum	24,00	4.690	195,42		194,99	17,37		178,03	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.07.24	12,29	1.507	122,59	8:57	195,51	19,27	22:35	184,73	30,04
02.07.24	13,83	1.694	122,50	9:03	195,91	18,87	20:23	184,59	30,18
03.07.24	9,02	1.086	120,39	21:33	195,02	19,75	1:26	184,53	30,24
04.07.24	11,34	1.372	120,97	8:16	195,19	19,59	20:02	184,59	30,18
05.07.24	6,32	766	121,12	8:33	195,26	19,51	22:25	184,91	29,86
06.07.24	3,27	396	120,93	9:35	195,16	19,62	11:40	185,57	29,20
07.07.24	2,80	340	121,50	11:02	195,43	19,34	16:28	185,46	29,31
08.07.24	10,46	1.277	122,09	6:08	195,19	19,59	23:40	184,55	30,23
09.07.24	11,98	1.432	119,50	9:20	194,97	19,80	23:56	184,15	30,63
10.07.24	15,13	1.817	120,11	15:25	194,53	20,24	0:23	184,10	30,67
11.07.24	18,45	2.249	121,93	7:16	194,93	19,85	23:55	183,40	31,37
12.07.24	24,00	2.904	121,00	---	---	---	22:28	183,20	31,57
13.07.24	23,32	2.851	122,26	---	---	---	0:54	183,37	31,40
14.07.24	16,92	2.075	122,63	12:52	195,05	19,72	0:00	183,72	31,05
15.07.24	22,99	2.785	121,14	14:58	193,49	21,28	23:43	183,40	31,37
16.07.24	24,00	2.879	119,96	---	---	---	20:00	183,04	31,74
17.07.24	22,65	2.753	121,56	---	---	---	1:08	183,28	31,50
18.07.24	22,58	2.724	120,62	---	---	---	23:41	183,16	31,62
19.07.24	24,00	2.895	120,63	---	---	---	23:47	183,05	31,72
20.07.24	15,41	1.869	121,29	18:42	194,09	20,69	0:00	183,07	31,71
21.07.24	8,08	976	120,86	23:59	195,04	19,74	1:29	184,41	30,37
22.07.24	12,15	1.484	122,11	5:43	195,19	19,59	21:41	184,62	30,15
23.07.24	13,33	1.634	122,58	8:42	194,91	19,86	23:56	184,50	30,27
24.07.24	16,31	1.977	121,20	10:13	195,62	19,16	21:49	183,78	30,99
25.07.24	23,09	2.817	121,98	---	---	---	21:13	183,57	31,21
26.07.24	24,00	2.936	122,33	---	---	---	0:00	183,69	31,08
27.07.24	22,45	2.759	122,91	8:23	194,24	20,53	0:40	183,94	30,84
28.07.24	24,00	2.976	124,00	---	---	---	0:00	184,10	30,67
29.07.24	24,00	2.955	123,13	---	---	---	20:53	183,91	30,87
30.07.24	20,44	2.488	121,71	10:57	194,38	20,40	2:12	183,78	30,99
31.07.24	16,17	1.969	121,74	6:10	194,53	20,24	0:00	184,33	30,44
Σ	514,79	62.642							
Mittelwert	16,61	2.021	121,68		194,93	19,84		184,01	30,76
Minimum	2,80	340	119,50		193,49	18,87		183,04	29,20
Maximum	24,00	2.976	124,00		195,91	21,28		185,57	31,74

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	12,37	761	61,52	8:48	197,42	15,86	22:39	190,91	22,37
02.07.24	13,87	840	60,56	9:08	197,52	15,76	20:40	190,75	22,53
03.07.24	9,11	547	60,06	7:12	196,87	16,41	1:43	190,70	22,58
04.07.24	11,42	677	59,28	8:38	196,74	16,54	20:24	190,31	22,97
05.07.24	6,39	383	59,94	9:06	196,69	16,59	22:26	190,68	22,60
06.07.24	3,33	200	60,06	9:34	196,67	16,61	11:43	191,29	21,99
07.07.24	2,84	171	60,16	11:25	196,86	16,42	16:29	191,18	22,10
08.07.24	10,54	630	59,79	4:59	196,69	16,59	23:44	190,31	22,97
09.07.24	11,98	687	57,35	8:40	196,42	16,86	23:36	189,76	23,52
10.07.24	18,02	1.057	58,66	5:18	195,75	17,53	20:26	189,04	24,24
11.07.24	18,49	1.094	59,15	7:14	195,96	17,32	23:42	188,36	24,92
12.07.24	24,00	1.393	58,04	---	---	---	22:09	188,21	25,07
13.07.24	23,33	1.393	59,70	---	---	---	3:20	188,49	24,79
14.07.24	16,96	1.018	60,01	12:59	196,45	16,83	22:37	189,07	24,21
15.07.24	24,00	1.387	57,79	---	---	---	23:47	188,36	24,92
16.07.24	24,00	1.364	56,83	---	---	---	10:52	184,00	29,28
17.07.24	22,70	1.325	58,38	---	---	---	3:27	188,33	24,95
18.07.24	22,63	1.304	57,63	---	---	---	23:58	188,38	24,90
19.07.24	24,00	1.378	57,42	---	---	---	23:47	188,31	24,97
20.07.24	15,52	921	59,34	18:38	195,85	17,43	0:09	188,28	25,00
21.07.24	8,18	498	60,89	23:59	196,79	16,49	1:31	190,48	22,80
22.07.24	12,26	753	61,40	5:44	197,07	16,21	21:49	190,80	22,48
23.07.24	13,41	819	61,06	8:45	196,87	16,41	12:40	190,68	22,60
24.07.24	16,35	966	59,08	10:01	197,04	16,24	18:03	189,22	24,06
25.07.24	23,11	1.381	59,77	---	---	---	21:03	188,86	24,42
26.07.24	24,00	1.441	60,04	---	---	---	0:00	189,16	24,12
27.07.24	22,46	1.362	60,65	8:22	195,63	17,65	5:12	189,46	23,82
28.07.24	24,00	1.484	61,83	---	---	---	0:00	189,72	23,56
29.07.24	24,00	1.461	60,88	---	---	---	20:15	189,31	23,97
30.07.24	20,56	1.231	59,88	10:57	196,00	17,28	1:50	189,19	24,09
31.07.24	16,38	987	60,27	6:05	196,40	16,88	0:06	190,44	22,84
Σ	520,21	30.913							
Mittelwert	16,78	997	59,42		196,58	16,70		189,42	23,86
Minimum	2,84	171	56,83		195,63	15,76		184,00	21,99
Maximum	24,00	1.484	61,83		197,52	17,65		191,29	29,28

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	0,00	0	---	8:34	202,88	13,92	---	---	---
02.07.24	2,50	270	108,16	9:06	202,88	13,92	11:34	195,26	21,54
03.07.24	0,56	64	115,20	7:17	202,62	14,18	---	---	---
04.07.24	0,67	70	103,75	8:33	202,26	14,54	---	---	---
05.07.24	0,00	0	---	8:53	202,21	14,59	---	---	---
06.07.24	0,00	0	---	10:33	202,18	14,62	---	---	---
07.07.24	0,00	0	---	10:53	202,30	14,50	---	---	---
08.07.24	0,00	0	---	5:32	202,18	14,62	---	---	---
09.07.24	3,01	308	102,34	9:19	202,04	14,76	11:35	195,14	21,66
10.07.24	4,80	514	107,11	5:28	201,66	15,14	20:03	194,50	22,30
11.07.24	7,66	817	106,69	7:27	201,72	15,08	23:14	193,98	22,82
12.07.24	14,39	1.550	107,73	5:54	200,94	15,86	21:58	193,94	22,86
13.07.24	8,86	944	106,49	9:09	201,34	15,46	3:06	194,30	22,50
14.07.24	11,96	1.335	111,65	12:52	202,02	14,78	22:53	193,90	22,90
15.07.24	24,00	2.624	109,33	---	---	---	23:53	193,45	23,35
16.07.24	24,00	2.615	108,96	---	---	---	10:52	181,00	35,80
17.07.24	24,00	2.660	110,83	---	---	---	3:37	193,36	23,44
18.07.24	24,00	2.643	110,13	---	---	---	6:23	193,43	23,37
19.07.24	24,00	2.636	109,83	---	---	---	0:53	193,49	23,31
20.07.24	4,97	539	108,41	23:14	201,99	14,81	3:47	193,45	23,35
21.07.24	0,00	0	---	23:52	202,45	14,35	---	---	---
22.07.24	0,00	0	---	5:50	202,60	14,20	---	---	---
23.07.24	1,33	146	109,39	8:47	202,55	14,25	11:10	195,56	21,24
24.07.24	10,92	1.188	108,77	9:50	202,63	14,17	17:48	194,63	22,17
25.07.24	11,60	1.255	108,15	9:52	202,12	14,68	20:48	194,42	22,38
26.07.24	9,84	1.080	109,76	11:09	201,61	15,19	14:47	194,84	21,96
27.07.24	8,38	910	108,56	9:33	201,94	14,86	4:57	195,08	21,72
28.07.24	5,31	589	110,97	9:54	202,18	14,62	23:57	195,12	21,68
29.07.24	8,53	930	108,96	9:14	202,21	14,59	19:55	194,76	22,04
30.07.24	4,78	513	107,38	13:25	202,11	14,69	1:39	194,70	22,10
31.07.24	0,66	69	104,81	6:10	202,34	14,46	---	---	---
Σ	240,74	26.269							
Mittelwert	7,77	847	109,12		202,15	14,65		193,73	23,07
Minimum	0,00	0	102,34		200,94	13,92		181,00	21,24
Maximum	24,00	2.660	115,20		202,88	15,86		195,56	35,80

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	0,00	0	---	9:19	199,01	22,14	---	---	---
02.07.24	1,66	269	162,02	8:34	198,96	22,19	11:30	183,94	37,21
03.07.24	0,00	0	---	7:13	198,70	22,45	---	---	---
04.07.24	0,83	132	159,14	8:06	197,98	23,17	---	---	---
05.07.24	0,00	0	---	8:28	197,96	23,19	---	---	---
06.07.24	0,00	0	---	9:05	197,79	23,36	---	---	---
07.07.24	0,00	0	---	10:47	198,04	23,11	---	---	---
08.07.24	0,00	0	---	4:07	197,79	23,36	---	---	---
09.07.24	3,10	479	154,39	5:26	197,62	23,53	11:41	183,20	37,95
10.07.24	4,50	737	163,83	15:11	197,37	23,78	20:16	182,33	38,82
11.07.24	7,74	1.322	170,72	7:38	197,24	23,91	23:27	180,96	40,19
12.07.24	15,01	2.585	172,27	5:52	196,49	24,66	22:02	180,96	40,19
13.07.24	9,38	1.607	171,25	8:58	197,00	24,15	3:13	181,27	39,88
14.07.24	12,16	2.293	188,60	9:42	197,69	23,46	17:03	179,90	41,25
15.07.24	24,00	4.374	182,25	---	---	---	23:48	179,46	41,69
16.07.24	24,00	4.412	183,83	---	---	---	10:52	176,00	45,15
17.07.24	24,00	4.567	190,29	---	---	---	3:47	179,16	41,99
18.07.24	24,00	4.516	188,17	---	---	---	6:39	179,19	41,96
19.07.24	24,00	4.498	187,42	---	---	---	0:52	179,66	41,49
20.07.24	5,01	930	185,61	23:24	197,97	23,18	3:54	179,64	41,51
21.07.24	0,00	0	---	23:39	198,48	22,67	---	---	---
22.07.24	0,00	0	---	5:53	198,64	22,51	---	---	---
23.07.24	1,36	248	181,98	8:35	198,61	22,54	11:16	181,79	39,36
24.07.24	11,17	2.014	180,24	9:46	198,70	22,45	17:50	181,46	39,69
25.07.24	11,93	2.123	177,89	9:40	198,14	23,01	20:54	181,17	39,98
26.07.24	10,61	1.925	181,39	11:04	197,52	23,63	14:52	181,66	39,49
27.07.24	9,08	1.632	179,80	9:36	197,87	23,28	4:59	181,72	39,43
28.07.24	5,58	1.029	184,42	14:41	198,25	22,90	17:09	181,87	39,28
29.07.24	8,94	1.612	180,25	9:05	198,27	22,88	20:05	181,59	39,56
30.07.24	4,97	872	175,56	13:49	198,14	23,01	1:43	181,51	39,64
31.07.24	0,75	127	170,41	18:41	198,41	22,74	---	---	---
Σ	243,79	44.303							
Mittelwert	7,86	1.429	181,73		198,03	23,12		180,88	40,27
Minimum	0,00	0	154,39		196,49	22,14		176,00	37,21
Maximum	24,00	4.567	190,29		199,01	24,66		183,94	45,15

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	0,00	0	---	8:56	200,06	27,47	---	---	---
02.07.24	1,62	148	91,12	8:46	200,01	27,51	11:29	194,67	32,86
03.07.24	12,65	1.347	106,48	7:33	199,74	27,78	22:47	193,67	33,86
04.07.24	23,61	2.473	104,76	---	---	---	20:24	193,19	34,33
05.07.24	22,18	2.335	105,28	6:53	198,46	29,06	2:22	193,25	34,27
06.07.24	24,00	2.532	105,50	---	---	---	11:43	193,39	34,13
07.07.24	22,26	2.351	105,61	---	---	---	16:29	193,47	34,06
08.07.24	24,00	2.526	105,25	---	---	---	23:43	193,15	34,37
09.07.24	23,22	2.378	102,39	---	---	---	11:43	192,54	34,99
10.07.24	22,68	2.301	101,47	15:16	198,09	29,44	20:30	191,86	35,67
11.07.24	23,72	2.456	103,55	---	---	---	23:26	191,47	36,06
12.07.24	24,00	2.462	102,58	---	---	---	22:03	191,44	36,09
13.07.24	24,00	2.497	104,04	---	---	---	3:11	191,76	35,76
14.07.24	14,51	1.509	104,00	9:37	198,45	29,08	20:28	192,34	35,18
15.07.24	10,87	1.115	102,59	0:27	197,15	30,37	23:20	191,53	36,00
16.07.24	2,73	280	102,66	11:18	207,97	19,55	10:52	188,00	39,52
17.07.24	0,00	0	---	---	---	---	---	---	---
18.07.24	0,00	0	---	---	---	---	---	---	---
19.07.24	0,00	0	---	---	---	---	---	---	---
20.07.24	0,00	0	---	---	---	---	---	---	---
21.07.24	0,00	0	---	---	---	---	---	---	---
22.07.24	0,00	0	---	---	---	---	---	---	---
23.07.24	0,00	0	---	---	---	---	---	---	---
24.07.24	0,00	0	---	---	---	---	---	---	---
25.07.24	0,00	0	---	---	---	---	---	---	---
26.07.24	0,00	0	---	---	---	---	---	---	---
27.07.24	0,00	0	---	---	---	---	---	---	---
28.07.24	0,00	0	---	---	---	---	---	---	---
29.07.24	0,00	0	---	---	---	---	---	---	---
30.07.24	0,00	0	---	---	---	---	---	---	---
31.07.24	0,00	0	---	---	---	---	---	---	---
Σ	276,05	28.710							
Mittelwert	8,90	926	104,00		199,99	27,53		192,38	35,14
Minimum	0,00	0	91,12		197,15	19,55		188,00	32,86
Maximum	24,00	2.532	106,48		207,97	30,37		194,67	39,52

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	24,00	1.790	74,58	---	---	---	4:46	191,04	44,42
02.07.24	23,52	1.735	73,75	---	---	---	11:40	190,83	44,64
03.07.24	24,00	1.764	73,50	---	---	---	20:03	190,30	45,16
04.07.24	24,00	1.740	72,50	---	---	---	20:24	190,01	45,45
05.07.24	24,00	1.745	72,71	---	---	---	23:48	189,86	45,60
06.07.24	24,00	1.745	72,71	---	---	---	11:43	190,01	45,45
07.07.24	24,00	1.747	72,79	---	---	---	2:17	189,97	45,49
08.07.24	24,00	1.743	72,63	---	---	---	23:44	189,89	45,57
09.07.24	23,82	1.699	71,32	---	---	---	17:18	189,74	45,73
10.07.24	22,22	1.577	70,97	15:45	200,28	35,18	22:27	189,55	45,92
11.07.24	15,00	1.074	71,59	17:02	199,98	35,49	0:13	189,35	46,12
12.07.24	0,00	0	---	9:13	200,12	35,34	---	---	---
13.07.24	0,00	0	---	9:34	200,59	34,87	---	---	---
14.07.24	5,35	389	72,76	5:53	200,87	34,59	13:08	190,23	45,23
15.07.24	0,00	0	---	0:51	200,64	34,82	---	---	---
16.07.24	1,91	135	70,59	10:43	200,43	35,03	10:52	186,00	49,46
17.07.24	0,00	0	---	21:10	200,56	34,90	---	---	---
18.07.24	0,72	52	71,89	0:16	200,57	34,89	---	---	---
19.07.24	1,05	76	72,21	10:55	200,53	34,93	---	---	---
20.07.24	18,94	1.379	72,82	4:17	200,42	35,04	6:46	189,45	46,01
21.07.24	24,00	1.756	73,17	---	---	---	1:31	190,17	45,30
22.07.24	24,00	1.768	73,67	---	---	---	0:04	190,51	44,95
23.07.24	24,00	1.763	73,46	---	---	---	11:52	190,29	45,17
24.07.24	21,63	1.587	73,36	10:16	201,88	33,58	23:15	189,71	45,76
25.07.24	24,00	1.751	72,96	---	---	---	20:57	189,45	46,01
26.07.24	24,00	1.753	73,04	---	---	---	1:34	189,64	45,82
27.07.24	24,00	1.759	73,29	---	---	---	0:19	189,78	45,68
28.07.24	24,00	1.749	72,88	---	---	---	23:55	190,15	45,31
29.07.24	24,00	1.756	73,17	---	---	---	20:09	189,80	45,66
30.07.24	22,69	1.653	72,86	9:28	200,69	34,77	1:44	189,74	45,73
31.07.24	24,00	1.756	73,17	---	---	---	6:51	190,57	44,89
Σ	540,86	39.441							
Mittelwert	17,45	1.272	72,92		200,58	34,88		189,84	45,62
Minimum	0,00	0	70,59		199,98	33,58		186,00	44,42
Maximum	24,00	1.790	74,58		201,88	35,49		191,04	49,46

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom Juli 2024

gedruckt am: 04.08.2024, 01:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.07.24	24,00	3.990	166,25	---	---	---	22:59	193,28	51,54
02.07.24	23,76	3.953	166,39	---	---	---	20:50	193,22	51,60
03.07.24	24,00	3.997	166,54	---	---	---	2:11	193,19	51,64
04.07.24	24,00	3.968	165,33	---	---	---	21:59	193,06	51,76
05.07.24	24,00	3.973	165,54	---	---	---	0:35	193,06	51,76
06.07.24	24,00	3.968	165,33	---	---	---	0:28	193,11	51,71
07.07.24	24,00	3.990	166,25	---	---	---	1:12	193,18	51,65
08.07.24	24,00	3.953	164,71	---	---	---	23:28	193,03	51,79
09.07.24	24,00	3.947	164,46	---	---	---	23:09	192,83	52,00
10.07.24	18,90	3.115	164,82	12:50	196,55	48,28	22:43	192,76	52,06
11.07.24	13,18	2.162	164,02	20:28	196,72	48,10	0:03	192,78	52,04
12.07.24	0,00	0	---	9:37	196,91	47,91	---	---	---
13.07.24	0,00	0	---	20:05	197,12	47,70	---	---	---
14.07.24	5,55	941	169,58	7:22	197,26	47,57	13:22	193,48	51,34
15.07.24	0,00	0	---	0:03	197,07	47,75	---	---	---
16.07.24	2,17	361	166,59	0:16	196,97	47,85	10:52	190,00	54,82
17.07.24	0,00	0	---	11:57	196,95	47,87	---	---	---
18.07.24	1,13	192	170,50	12:17	196,97	47,86	---	---	---
19.07.24	1,45	247	170,02	10:04	196,93	47,90	---	---	---
20.07.24	19,06	3.195	167,65	4:33	196,90	47,93	11:46	193,14	51,68
21.07.24	24,00	4.019	167,46	---	---	---	2:46	193,14	51,68
22.07.24	24,00	4.006	166,92	---	---	---	22:43	193,20	51,62
23.07.24	24,00	3.998	166,58	---	---	---	12:40	193,15	51,67
24.07.24	8,32	1.375	165,30	13:29	197,08	47,74	0:55	193,09	51,73
25.07.24	0,00	0	---	9:20	197,36	47,46	---	---	---
26.07.24	0,00	0	---	13:06	197,32	47,50	---	---	---
27.07.24	0,00	0	---	20:52	197,47	47,35	---	---	---
28.07.24	0,00	0	---	14:38	197,57	47,25	---	---	---
29.07.24	0,00	0	---	8:57	197,58	47,24	---	---	---
30.07.24	15,16	2.566	169,21	0:00	197,42	47,41	20:06	193,38	51,45
31.07.24	24,00	4.018	167,42	---	---	---	23:00	193,31	51,51
Σ	396,67	65.934							
Mittelwert	12,80	2.127	166,22		197,12	47,70		192,97	51,85
Minimum	0,00	0	164,02		196,55	47,24		190,00	51,34
Maximum	24,00	4.019	170,50		197,58	48,28		193,48	54,82

Meßpunkthöhe (MP): 244,82 m üNN