

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	24,00	1.218	50,75	---	---	---	0:24	193,96	15,81
02.08.24	24,00	1.220	50,83	---	---	---	2:43	194,04	15,72
03.08.24	24,00	1.219	50,79	---	---	---	18:50	194,03	15,73
04.08.24	24,00	1.209	50,38	---	---	---	7:26	193,80	15,97
05.08.24	24,00	1.198	49,92	---	---	---	23:46	193,63	16,13
06.08.24	22,41	1.117	49,85	11:38	195,36	14,40	23:56	193,52	16,24
07.08.24	24,00	1.189	49,54	---	---	---	19:58	193,38	16,39
08.08.24	24,00	1.171	48,79	---	---	---	14:20	186,00	23,76
09.08.24	24,00	1.194	49,75	---	---	---	0:00	193,42	16,34
10.08.24	24,00	1.197	49,88	---	---	---	1:39	193,45	16,31
11.08.24	24,00	1.202	50,08	---	---	---	0:26	193,50	16,26
12.08.24	24,00	1.192	49,67	---	---	---	2:09	193,55	16,22
13.08.24	23,08	1.153	49,96	---	---	---	14:16	193,42	16,34
14.08.24	24,00	1.212	50,50	---	---	---	3:16	193,66	16,10
15.08.24	24,00	1.204	50,17	---	---	---	22:31	193,63	16,13
16.08.24	24,00	1.182	49,25	---	---	---	23:58	193,22	16,55
17.08.24	24,00	1.197	49,88	---	---	---	0:05	193,20	16,56
18.08.24	24,00	1.221	50,88	---	---	---	0:00	193,59	16,17
19.08.24	24,00	1.213	50,54	---	---	---	6:09	193,78	15,98
20.08.24	24,00	1.203	50,13	---	---	---	13:51	193,74	16,03
21.08.24	24,00	1.208	50,33	---	---	---	13:49	193,69	16,07
22.08.24	24,00	1.212	50,50	---	---	---	0:00	193,77	16,00
23.08.24	24,00	1.209	50,38	---	---	---	22:55	193,71	16,06
24.08.24	24,00	1.193	49,71	---	---	---	23:20	193,45	16,31
25.08.24	24,00	1.198	49,92	---	---	---	23:57	193,39	16,37
26.08.24	24,00	1.184	49,33	---	---	---	23:45	193,29	16,48
27.08.24	24,00	1.170	48,75	---	---	---	11:09	193,10	16,67
28.08.24	24,00	1.170	48,75	---	---	---	21:39	193,05	16,71
29.08.24	24,00	1.186	49,42	---	---	---	2:44	192,97	16,79
30.08.24	24,00	1.183	49,29	---	---	---	22:23	193,16	16,61
31.08.24	24,00	1.190	49,58	---	---	---	1:14	193,13	16,64
Σ	741,49	37.014							
Mittelwert	23,92	1.194	49,92		195,36	14,40		193,26	16,50
Minimum	22,41	1.117	48,75		195,36	14,40		186,00	15,72
Maximum	24,00	1.221	50,88		195,36	14,40		194,04	23,76

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	0,00	0	---	15:32	199,24	8,58	---	---	---
02.08.24	0,00	0	---	9:57	199,30	8,53	---	---	---
03.08.24	1,17	284	242,16	10:13	199,34	8,48	---	---	---
04.08.24	24,00	5.705	237,71	---	---	---	7:04	192,66	15,16
05.08.24	24,00	5.653	235,54	---	---	---	20:06	192,17	15,65
06.08.24	23,07	5.382	233,33	---	---	---	14:13	191,87	15,95
07.08.24	24,00	5.598	233,25	---	---	---	19:16	191,68	16,14
08.08.24	23,39	5.379	229,97	---	---	---	14:20	186,00	21,82
09.08.24	24,00	5.641	235,04	---	---	---	18:29	191,95	15,87
10.08.24	24,00	5.653	235,54	---	---	---	1:15	191,95	15,87
11.08.24	24,00	5.675	236,46	---	---	---	12:06	192,13	15,69
12.08.24	21,00	4.901	233,35	23:59	198,51	9,31	20:14	192,18	15,64
13.08.24	4,77	1.092	228,98	11:55	199,05	8,77	13:40	191,22	16,60
14.08.24	0,00	0	---	9:37	199,10	8,72	---	---	---
15.08.24	2,73	638	233,37	9:29	198,92	8,91	23:59	191,98	15,84
16.08.24	14,39	3.229	224,43	10:45	198,49	9,33	23:53	191,23	16,59
17.08.24	7,28	1.644	225,85	23:34	198,66	9,16	16:27	191,55	16,27
18.08.24	0,00	0	---	8:48	199,11	8,72	---	---	---
19.08.24	0,00	0	---	6:47	199,19	8,63	---	---	---
20.08.24	3,23	732	226,39	8:45	199,54	8,28	10:04	192,47	15,35
21.08.24	1,25	275	220,79	4:50	199,01	8,81	---	---	---
22.08.24	0,00	0	---	10:38	199,05	8,78	---	---	---
23.08.24	3,37	805	238,58	9:10	199,05	8,78	22:10	192,48	15,34
24.08.24	24,00	5.628	234,50	---	---	---	19:29	191,95	15,87
25.08.24	24,00	5.657	235,71	---	---	---	22:34	192,01	15,81
26.08.24	24,00	5.585	232,71	---	---	---	23:00	191,39	16,43
27.08.24	22,85	5.225	228,70	11:55	198,20	9,63	10:46	191,14	16,68
28.08.24	24,00	5.507	229,46	---	---	---	18:30	191,10	16,72
29.08.24	9,51	2.176	228,89	11:45	198,79	9,04	0:32	190,96	16,87
30.08.24	11,27	2.617	232,13	0:00	198,37	9,45	21:51	191,47	16,35
31.08.24	24,00	5.615	233,96	---	---	---	0:28	191,51	16,31
Σ	413,28	96.296							
Mittelwert	13,33	3.106	233,00		198,94	8,88		191,52	16,30
Minimum	0,00	0	220,79		198,20	8,28		186,00	15,16
Maximum	24,00	5.705	242,16		199,54	9,63		192,66	21,82

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.08.24	24,00	3.457	144,04	---	---	---	0:24	189,81	23,02
02.08.24	24,00	3.463	144,29	---	---	---	0:00	190,10	22,73
03.08.24	23,45	3.370	143,70	---	---	---	17:56	189,78	23,06
04.08.24	0,00	0	---	11:50	194,16	18,68	---	---	---
05.08.24	0,00	0	---	9:05	194,08	18,75	---	---	---
06.08.24	4,36	596	136,80	8:18	194,75	18,08	11:49	188,85	23,99
07.08.24	0,66	88	133,05	5:46	193,24	19,59	---	---	---
08.08.24	2,16	301	139,14	9:10	193,35	19,49	13:27	188,85	23,99
09.08.24	3,27	460	140,61	8:55	193,77	19,06	11:14	189,25	23,59
10.08.24	5,82	793	136,29	20:07	193,71	19,12	1:06	189,55	23,28
11.08.24	3,56	492	138,02	10:10	193,77	19,06	12:01	189,76	23,07
12.08.24	9,97	1.396	140,02	11:36	193,84	19,00	20:57	189,25	23,59
13.08.24	23,56	3.395	144,10	---	---	---	13:45	188,07	24,77
14.08.24	24,00	3.444	143,50	---	---	---	1:10	189,47	23,36
15.08.24	24,00	3.422	142,58	---	---	---	21:50	188,85	23,99
16.08.24	24,00	3.357	139,88	---	---	---	23:55	188,05	24,78
17.08.24	24,00	3.403	141,79	---	---	---	0:00	188,23	24,60
18.08.24	24,00	3.471	144,63	---	---	---	0:00	189,69	23,15
19.08.24	24,00	3.452	143,83	---	---	---	21:24	189,93	22,90
20.08.24	23,25	3.309	142,31	---	---	---	21:00	189,22	23,62
21.08.24	24,00	3.429	142,88	---	---	---	12:40	189,28	23,56
22.08.24	24,00	3.444	143,50	---	---	---	0:00	189,86	22,98
23.08.24	20,61	2.950	143,10	22:59	193,47	19,37	20:07	189,90	22,93
24.08.24	0,00	0	---	10:45	193,79	19,05	---	---	---
25.08.24	0,00	0	---	11:20	193,79	19,05	---	---	---
26.08.24	1,77	235	132,81	5:33	193,55	19,29	22:54	188,56	24,28
27.08.24	1,99	262	131,95	11:56	193,12	19,72	10:42	188,13	24,71
28.08.24	3,44	467	135,76	8:49	192,86	19,98	23:58	188,14	24,69
29.08.24	14,34	2.024	141,18	8:57	192,73	20,10	0:27	188,04	24,80
30.08.24	15,10	2.103	139,23	17:26	193,02	19,81	18:33	188,88	23,96
31.08.24	0,00	0	---	5:51	193,12	19,72	---	---	---
Σ	397,32	56.583							
Mittelwert	12,82	1.825	142,41		193,56	19,27		189,10	23,73
Minimum	0,00	0	131,95		192,73	18,08		188,04	22,73
Maximum	24,00	3.471	144,63		194,75	20,10		190,10	24,80

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.08.24	24,00	4.621	192,54	---	---	---	0:20	177,00	33,11
02.08.24	24,00	4.630	192,92	---	---	---	23:40	177,08	33,03
03.08.24	24,00	4.623	192,63	---	---	---	18:45	177,03	33,08
04.08.24	4,08	750	183,87	10:27	194,30	15,81	0:17	177,92	32,20
05.08.24	9,46	1.773	187,35	8:33	194,16	15,95	19:53	177,80	32,32
06.08.24	13,65	2.554	187,17	8:27	194,56	15,55	11:51	177,00	33,11
07.08.24	15,91	2.963	186,21	5:46	193,13	16,99	0:24	177,28	32,84
08.08.24	10,36	1.859	179,51	9:03	193,31	16,80	2:35	177,43	32,68
09.08.24	3,88	723	186,53	9:12	193,81	16,30	12:03	177,94	32,18
10.08.24	0,00	0	---	20:06	193,74	16,38	---	---	---
11.08.24	0,00	0	---	9:59	193,81	16,30	---	---	---
12.08.24	3,34	645	193,02	3:47	193,94	16,18	23:39	177,07	33,05
13.08.24	24,00	4.553	189,71	---	---	---	7:35	177,00	33,11
14.08.24	22,49	4.312	191,73	8:04	193,28	16,84	1:07	177,00	33,11
15.08.24	24,00	4.581	190,88	---	---	---	22:27	177,05	33,06
16.08.24	24,00	4.501	187,54	---	---	---	0:59	177,00	33,11
17.08.24	24,00	4.562	190,08	---	---	---	8:31	177,00	33,11
18.08.24	23,42	4.547	194,11	---	---	---	0:00	177,08	33,03
19.08.24	23,61	4.547	192,59	---	---	---	21:13	177,23	32,88
20.08.24	23,34	4.443	190,33	---	---	---	22:36	177,10	33,02
21.08.24	23,55	4.504	191,27	---	---	---	13:48	177,10	33,02
22.08.24	24,00	4.612	192,17	---	---	---	23:38	177,22	32,90
23.08.24	23,01	4.410	191,68	---	---	---	19:32	177,22	32,90
24.08.24	10,92	2.026	185,59	10:59	193,84	16,27	19:20	177,71	32,41
25.08.24	7,19	1.346	187,31	12:11	193,87	16,24	22:27	177,98	32,13
26.08.24	12,41	2.315	186,62	5:22	193,55	16,56	23:13	177,36	32,76
27.08.24	21,25	3.917	184,33	11:54	192,20	17,92	10:52	177,00	33,11
28.08.24	16,41	3.009	183,39	5:36	192,70	17,41	21:21	177,03	33,08
29.08.24	16,91	3.170	187,45	11:30	193,37	16,74	0:32	177,00	33,11
30.08.24	18,87	3.516	186,36	17:23	192,90	17,22	5:54	177,00	33,11
31.08.24	9,25	1.723	186,28	5:45	193,05	17,06	0:19	177,36	32,76
Σ	505,29	95.735							
Mittelwert	16,30	3.088	189,47		193,53	16,58		177,24	32,87
Minimum	0,00	0	179,51		192,20	15,55		177,00	32,13
Maximum	24,00	4.630	194,11		194,56	17,92		177,98	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	11,82	1.434	121,28	15:13	195,02	19,75	0:17	184,42	30,35
02.08.24	11,02	1.347	122,28	10:03	195,17	19,60	23:09	184,79	29,98
03.08.24	9,88	1.214	122,84	9:51	195,23	19,54	18:32	184,88	29,89
04.08.24	22,48	2.753	122,49	---	---	---	19:58	184,38	30,40
05.08.24	23,53	2.855	121,32	---	---	---	20:00	183,77	31,01
06.08.24	21,46	2.583	120,35	8:49	194,64	20,14	23:52	183,55	31,22
07.08.24	24,00	2.890	120,42	---	---	---	23:58	183,26	31,51
08.08.24	23,28	2.764	118,74	---	---	---	0:00	183,26	31,51
09.08.24	23,47	2.844	121,19	---	---	---	12:16	183,72	31,05
10.08.24	24,00	2.916	121,50	---	---	---	1:52	183,92	30,85
11.08.24	24,00	2.926	121,92	---	---	---	0:26	184,03	30,75
12.08.24	22,39	2.694	120,30	---	---	---	22:14	183,49	31,28
13.08.24	18,57	2.252	121,30	8:25	193,94	20,84	18:00	183,74	31,04
14.08.24	14,26	1.734	121,57	10:13	194,78	20,00	0:46	183,89	30,89
15.08.24	12,99	1.568	120,71	9:12	194,56	20,21	18:45	184,20	30,58
16.08.24	0,00	0	---	11:03	194,44	20,33	---	---	---
17.08.24	2,85	345	121,25	9:42	194,33	20,44	---	---	---
18.08.24	6,17	762	123,44	11:44	195,04	19,74	17:40	185,13	29,65
19.08.24	13,40	1.628	121,46	8:01	195,11	19,66	20:57	184,62	30,15
20.08.24	14,22	1.722	121,13	9:01	195,07	19,71	22:15	184,33	30,44
21.08.24	14,48	1.743	120,34	5:05	194,70	20,07	13:20	184,38	30,40
22.08.24	14,08	1.714	121,72	8:28	194,78	20,00	23:23	184,53	30,24
23.08.24	16,10	1.968	122,22	5:36	194,59	20,18	22:08	184,47	30,31
24.08.24	24,00	2.904	121,00	---	---	---	19:32	183,63	31,14
25.08.24	22,12	2.684	121,32	5:32	193,97	20,81	22:42	183,65	31,13
26.08.24	23,74	2.851	120,07	---	---	---	23:58	183,39	31,39
27.08.24	23,92	2.826	118,15	---	---	---	10:58	182,88	31,89
28.08.24	24,00	2.845	118,54	---	---	---	21:27	182,79	31,98
29.08.24	17,22	2.057	119,43	11:49	193,56	21,22	2:21	182,70	32,08
30.08.24	23,56	2.807	119,14	---	---	---	21:47	182,88	31,89
31.08.24	23,68	2.852	120,43	---	---	---	0:26	182,93	31,85
Σ	550,71	66.482							
Mittelwert	17,76	2.145	120,72		194,64	20,13		183,85	30,92
Minimum	0,00	0	118,15		193,56	19,54		182,70	29,65
Maximum	24,00	2.926	123,44		195,23	21,22		185,13	32,08

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	11,92	725	60,84	15:15	196,97	16,31	0:19	190,44	22,84
02.08.24	11,14	686	61,59	9:51	197,14	16,14	23:20	190,99	22,29
03.08.24	9,97	615	61,69	9:47	197,22	16,06	18:33	190,94	22,34
04.08.24	22,52	1.343	59,65	---	---	---	22:38	189,26	24,02
05.08.24	23,56	1.374	58,32	---	---	---	23:53	188,81	24,47
06.08.24	21,19	1.218	57,48	9:06	195,48	17,80	0:27	188,81	24,47
07.08.24	24,00	1.379	57,46	---	---	---	23:59	188,53	24,75
08.08.24	23,30	1.327	56,95	---	---	---	14:20	184,00	29,28
09.08.24	23,48	1.358	57,84	---	---	---	20:02	188,62	24,66
10.08.24	24,00	1.392	58,00	---	---	---	2:37	188,64	24,64
11.08.24	24,00	1.401	58,38	---	---	---	1:15	188,74	24,54
12.08.24	22,43	1.281	57,10	---	---	---	22:15	188,50	24,78
13.08.24	18,50	1.091	58,99	8:32	195,63	17,65	13:35	189,81	23,47
14.08.24	14,47	871	60,20	10:06	196,45	16,83	0:55	189,76	23,52
15.08.24	13,04	780	59,81	9:12	196,47	16,81	18:59	190,06	23,22
16.08.24	0,00	0	---	10:46	196,23	17,05	---	---	---
17.08.24	2,88	175	60,72	9:29	196,10	17,18	21:13	190,83	22,45
18.08.24	6,28	390	62,14	11:37	196,97	16,31	17:41	191,28	22,00
19.08.24	13,50	818	60,61	7:58	197,07	16,21	21:05	190,83	22,45
20.08.24	13,32	793	59,55	9:12	196,95	16,33	13:47	190,19	23,09
21.08.24	14,58	870	59,69	5:07	196,59	16,69	13:35	190,39	22,89
22.08.24	14,18	866	61,09	8:29	196,76	16,52	23:31	190,73	22,55
23.08.24	16,20	985	60,80	5:36	196,59	16,69	22:57	189,96	23,32
24.08.24	24,00	1.393	58,04	---	---	---	23:59	188,74	24,54
25.08.24	22,15	1.290	58,24	5:31	194,27	19,01	23:43	188,66	24,62
26.08.24	23,75	1.355	57,04	---	---	---	17:01	188,54	24,74
27.08.24	24,00	1.325	55,21	---	---	---	14:17	188,06	25,22
28.08.24	24,00	1.333	55,54	---	---	---	21:39	187,97	25,31
29.08.24	24,00	1.368	57,00	---	---	---	9:27	187,82	25,46
30.08.24	24,00	1.341	55,88	---	---	---	22:28	187,88	25,40
31.08.24	23,70	1.355	57,17	---	---	---	1:05	187,89	25,39
Σ	558,04	32.498							
Mittelwert	18,00	1.048	58,24		196,43	16,85		189,19	24,09
Minimum	0,00	0	55,21		194,27	16,06		184,00	22,00
Maximum	24,00	1.401	62,14		197,22	19,01		191,28	29,28

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	0,00	0	---	15:25	202,66	14,14	---	---	---
02.08.24	0,00	0	---	10:08	202,76	14,04	---	---	---
03.08.24	1,15	134	116,18	9:36	202,81	13,99	---	---	---
04.08.24	24,00	2.687	111,96	---	---	---	23:50	194,03	22,77
05.08.24	24,00	2.648	110,33	---	---	---	23:52	193,77	23,03
06.08.24	22,18	2.440	109,99	9:05	201,36	15,44	7:26	193,62	23,18
07.08.24	24,00	2.642	110,08	---	---	---	20:29	193,67	23,13
08.08.24	23,01	2.506	108,93	---	---	---	14:20	181,00	35,80
09.08.24	24,00	2.631	109,63	---	---	---	20:02	193,58	23,22
10.08.24	24,00	2.650	110,42	---	---	---	2:59	193,56	23,24
11.08.24	24,00	2.660	110,83	---	---	---	0:52	193,60	23,20
12.08.24	22,28	2.422	108,71	23:59	200,69	16,11	2:05	193,51	23,29
13.08.24	2,94	437	148,58	11:55	202,21	14,59	11:53	194,69	22,11
14.08.24	2,35	261	111,05	10:24	202,21	14,59	1:12	195,08	21,72
15.08.24	5,12	577	112,59	9:26	202,28	14,52	23:58	195,39	21,41
16.08.24	14,18	1.512	106,60	10:42	201,98	14,82	23:47	194,84	21,96
17.08.24	7,11	767	107,88	22:46	202,04	14,76	16:25	195,17	21,63
18.08.24	0,00	0	---	11:50	202,56	14,24	---	---	---
19.08.24	0,00	0	---	8:04	202,65	14,15	---	---	---
20.08.24	3,77	403	106,76	9:38	202,65	14,15	12:13	195,55	21,25
21.08.24	1,20	126	105,37	5:08	202,40	14,40	---	---	---
22.08.24	0,00	0	---	8:30	202,53	14,27	---	---	---
23.08.24	3,38	381	112,64	5:46	202,50	14,30	22:55	194,75	22,05
24.08.24	24,00	2.641	110,04	---	---	---	23:46	193,75	23,05
25.08.24	24,00	2.654	110,58	---	---	---	3:18	193,60	23,20
26.08.24	24,00	2.614	108,92	---	---	---	3:00	193,50	23,30
27.08.24	23,89	2.549	106,68	---	---	---	14:25	193,29	23,51
28.08.24	24,00	2.573	107,21	---	---	---	21:43	193,24	23,56
29.08.24	24,00	2.610	108,75	---	---	---	9:26	193,10	23,70
30.08.24	24,00	2.587	107,79	---	---	---	22:30	193,12	23,68
31.08.24	24,00	2.627	109,46	---	---	---	2:50	193,00	23,80
Σ	444,58	48.739							
Mittelwert	14,34	1.572	109,63		202,27	14,53		193,43	23,37
Minimum	0,00	0	105,37		200,69	13,99		181,00	21,25
Maximum	24,00	2.687	148,58		202,81	16,11		195,55	35,80

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	0,00	0	---	15:34	198,74	22,41	---	---	---
02.08.24	0,00	0	---	9:42	198,84	22,31	---	---	---
03.08.24	1,27	241	189,89	9:31	198,91	22,24	---	---	---
04.08.24	24,00	4.640	193,33	---	---	---	7:36	180,02	41,13
05.08.24	24,00	4.487	186,96	---	---	---	4:47	179,72	41,43
06.08.24	22,24	4.170	187,50	9:06	197,13	24,02	7:28	178,70	42,45
07.08.24	24,00	4.526	188,58	---	---	---	12:39	179,91	41,24
08.08.24	19,57	3.602	184,09	20:20	196,58	24,57	14:20	176,00	45,15
09.08.24	24,00	4.432	184,67	---	---	---	13:50	179,74	41,41
10.08.24	24,00	4.546	189,42	---	---	---	16:04	179,72	41,43
11.08.24	24,00	4.574	190,58	---	---	---	13:08	179,76	41,39
12.08.24	22,32	4.076	182,61	23:58	196,37	24,78	2:08	179,26	41,89
13.08.24	3,53	629	178,23	11:55	198,32	22,83	13:44	181,28	39,87
14.08.24	0,00	0	---	10:15	198,19	22,96	---	---	---
15.08.24	2,83	516	182,05	9:10	198,29	22,86	21:50	182,43	38,72
16.08.24	14,71	2.566	174,41	10:44	197,87	23,28	23:54	181,83	39,32
17.08.24	7,64	1.343	175,79	23:28	198,04	23,11	16:28	182,22	38,93
18.08.24	0,00	0	---	23:28	198,63	22,52	---	---	---
19.08.24	0,00	0	---	8:37	198,73	22,42	---	---	---
20.08.24	3,91	683	174,84	9:24	198,74	22,41	12:14	182,83	38,32
21.08.24	1,36	232	170,45	5:17	198,48	22,67	---	---	---
22.08.24	0,00	0	---	8:31	198,61	22,54	---	---	---
23.08.24	3,43	653	190,55	11:04	198,63	22,52	22:56	181,07	40,08
24.08.24	24,00	4.474	186,42	---	---	---	23:39	179,92	41,23
25.08.24	24,00	4.519	188,29	---	---	---	3:19	179,46	41,69
26.08.24	24,00	4.377	182,38	---	---	---	2:58	179,36	41,79
27.08.24	24,00	4.170	173,75	---	---	---	11:49	178,87	42,28
28.08.24	24,00	4.241	176,71	---	---	---	21:49	179,41	41,74
29.08.24	24,00	4.346	181,08	---	---	---	9:25	178,77	42,38
30.08.24	24,00	4.277	178,21	---	---	---	21:57	179,19	41,96
31.08.24	24,00	4.431	184,63	---	---	---	2:58	178,75	42,40
Σ	438,81	80.751							
Mittelwert	14,16	2.605	184,02		198,18	22,97		179,92	41,23
Minimum	0,00	0	170,45		196,37	22,24		176,00	38,32
Maximum	24,00	4.640	193,33		198,91	24,78		182,83	45,15

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	0,00	0	---	---	---	---	---	---	---
02.08.24	0,00	0	---	---	---	---	---	---	---
03.08.24	0,00	0	---	---	---	---	---	---	---
04.08.24	0,00	0	---	---	---	---	---	---	---
05.08.24	0,00	0	---	---	---	---	---	---	---
06.08.24	0,00	0	---	---	---	---	---	---	---
07.08.24	0,00	0	---	---	---	---	---	---	---
08.08.24	0,00	0	---	0:00	188,01	39,51	---	---	---
09.08.24	0,00	0	---	---	---	---	---	---	---
10.08.24	0,00	0	---	---	---	---	---	---	---
11.08.24	0,00	0	---	---	---	---	---	---	---
12.08.24	0,00	0	---	---	---	---	---	---	---
13.08.24	0,00	0	---	---	---	---	---	---	---
14.08.24	0,00	0	---	---	---	---	---	---	---
15.08.24	0,00	0	---	---	---	---	---	---	---
16.08.24	0,00	0	---	---	---	---	---	---	---
17.08.24	0,00	0	---	---	---	---	---	---	---
18.08.24	0,00	0	---	---	---	---	---	---	---
19.08.24	0,00	0	---	---	---	---	---	---	---
20.08.24	0,00	0	---	---	---	---	---	---	---
21.08.24	0,00	0	---	---	---	---	---	---	---
22.08.24	0,00	0	---	---	---	---	---	---	---
23.08.24	0,00	0	---	---	---	---	---	---	---
24.08.24	0,00	0	---	---	---	---	---	---	---
25.08.24	0,00	0	---	---	---	---	---	---	---
26.08.24	0,00	0	---	---	---	---	---	---	---
27.08.24	0,00	0	---	---	---	---	---	---	---
28.08.24	0,00	0	---	---	---	---	---	---	---
29.08.24	0,00	0	---	---	---	---	---	---	---
30.08.24	0,00	0	---	---	---	---	---	---	---
31.08.24	0,00	0	---	---	---	---	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,01	39,51		---	---
Minimum	0,00	0	---		188,01	39,51		---	---
Maximum	0,00	0	---		188,01	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.08.24	24,00	1.757	73,21	---	---	---	0:25	190,67	44,79
02.08.24	24,00	1.760	73,33	---	---	---	1:43	190,97	44,49
03.08.24	24,00	1.759	73,29	---	---	---	1:58	190,97	44,49
04.08.24	3,29	243	73,94	2:17	201,46	34,01	0:13	191,15	44,31
05.08.24	8,55	640	74,85	0:00	200,86	34,60	19:51	189,67	45,79
06.08.24	2,59	187	72,12	9:07	200,89	34,57	11:44	190,17	45,30
07.08.24	0,00	0	---	0:00	200,69	34,77	---	---	---
08.08.24	8,53	552	64,68	11:33	200,68	34,78	14:20	186,00	49,46
09.08.24	12,01	846	70,46	23:13	200,25	35,21	3:39	189,25	46,22
10.08.24	0,00	0	---	23:36	200,51	34,95	---	---	---
11.08.24	0,00	0	---	23:37	200,71	34,76	---	---	---
12.08.24	12,07	849	70,33	11:38	200,84	34,62	23:34	189,18	46,28
13.08.24	24,00	1.711	71,29	---	---	---	0:27	189,09	46,37
14.08.24	22,13	1.580	71,38	8:12	201,00	34,46	3:45	189,91	45,56
15.08.24	24,00	1.725	71,88	---	---	---	22:19	190,23	45,23
16.08.24	24,00	1.693	70,54	---	---	---	23:57	189,75	45,71
17.08.24	24,00	1.712	71,33	---	---	---	0:00	189,77	45,70
18.08.24	23,25	1.665	71,63	---	---	---	0:48	190,27	45,20
19.08.24	23,43	1.685	71,92	---	---	---	22:07	190,72	44,75
20.08.24	22,89	1.642	71,72	---	---	---	22:30	190,63	44,84
21.08.24	23,37	1.652	70,69	---	---	---	22:51	190,70	44,76
22.08.24	24,00	1.729	72,04	---	---	---	10:49	190,83	44,64
23.08.24	22,82	1.650	72,30	23:00	201,11	34,35	21:50	190,73	44,73
24.08.24	10,30	750	72,81	8:46	200,81	34,65	19:16	189,81	45,65
25.08.24	6,28	466	74,21	11:42	200,54	34,92	22:23	189,80	45,66
26.08.24	11,38	831	73,00	5:29	200,30	35,16	23:55	189,33	46,13
27.08.24	21,72	1.526	70,27	17:17	199,20	36,26	23:15	188,87	46,59
28.08.24	15,33	1.082	70,59	5:43	199,55	35,91	20:26	189,08	46,38
29.08.24	15,31	1.075	70,20	21:21	199,53	35,93	1:37	189,05	46,41
30.08.24	16,83	1.187	70,53	8:20	199,72	35,75	20:55	188,90	46,56
31.08.24	8,22	587	71,44	8:58	199,65	35,81	12:53	189,37	46,09
Σ	482,30	34.541							
Mittelwert	15,56	1.114	71,62		200,44	35,02		189,82	45,64
Minimum	0,00	0	64,68		199,20	34,01		186,00	44,31
Maximum	24,00	1.760	74,85		201,46	36,26		191,15	49,46

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:48 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	24,00	4.016	167,33	---	---	---	0:58	193,28	51,54
02.08.24	24,00	4.026	167,75	---	---	---	0:00	193,35	51,48
03.08.24	23,50	3.927	167,12	---	---	---	0:00	193,35	51,48
04.08.24	0,00	0	---	12:46	197,13	47,69	---	---	---
05.08.24	0,00	0	---	9:02	197,13	47,69	---	---	---
06.08.24	3,69	621	168,17	9:00	197,22	47,60	11:44	193,57	51,25
07.08.24	0,78	134	171,31	6:58	197,06	47,77	---	---	---
08.08.24	0,00	0	---	21:10	197,15	47,67	---	---	---
09.08.24	2,51	425	169,59	0:00	197,10	47,72	22:17	193,64	51,19
10.08.24	6,49	1.081	166,49	11:16	196,93	47,89	23:34	193,47	51,36
11.08.24	4,06	688	169,37	9:56	196,98	47,84	12:04	193,57	51,25
12.08.24	9,34	1.581	169,29	11:25	197,00	47,83	20:55	193,11	51,71
13.08.24	21,88	3.635	166,10	9:40	196,73	48,09	1:46	193,03	51,79
14.08.24	24,00	3.975	165,63	---	---	---	1:51	192,91	51,91
15.08.24	24,00	3.974	165,58	---	---	---	19:39	193,02	51,81
16.08.24	24,00	3.959	164,96	---	---	---	23:18	192,83	51,99
17.08.24	24,00	3.960	165,00	---	---	---	1:11	192,84	51,98
18.08.24	24,00	4.000	166,67	---	---	---	0:14	193,05	51,78
19.08.24	24,00	3.988	166,17	---	---	---	21:51	193,14	51,68
20.08.24	23,58	3.897	165,26	---	---	---	22:54	193,06	51,76
21.08.24	24,00	3.956	164,83	---	---	---	12:38	193,05	51,78
22.08.24	24,00	3.957	164,88	---	---	---	0:00	193,11	51,71
23.08.24	20,66	3.397	164,39	23:54	196,76	48,06	0:27	193,14	51,68
24.08.24	0,00	0	---	14:02	196,91	47,91	---	---	---
25.08.24	0,00	0	---	7:01	196,90	47,93	---	---	---
26.08.24	1,89	317	167,36	8:49	196,85	47,97	22:57	193,30	51,52
27.08.24	3,20	531	165,76	5:30	196,67	48,15	11:50	192,95	51,87
28.08.24	3,65	615	168,70	14:36	196,73	48,09	18:27	193,17	51,65
29.08.24	0,89	133	149,72	17:07	196,81	48,02	---	---	---
30.08.24	2,53	424	167,39	0:00	196,73	48,09	18:35	193,38	51,45
31.08.24	0,00	0	---	18:32	196,74	48,09	---	---	---
Σ	368,67	61.217							
Mittelwert	11,89	1.975	166,05		196,92	47,90		193,19	51,63
Minimum	0,00	0	149,72		196,67	47,60		192,83	51,19
Maximum	24,00	4.026	171,31		197,22	48,15		193,64	51,99

Meßpunkthöhe (MP): 244,82 m üNN