

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB02
Monatsbericht vom September 2024
gedruckt am: 03.10.2024, 14:42 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.09.24	20,65	1.520	73,59	12:30	197,12	17,97	4:55	195,04	20,06
02.09.24	24,00	1.751	72,96	---	---	---	6:51	195,10	19,99
03.09.24	21,84	1.589	72,76	10:50	197,06	18,03	7:49	195,02	20,07
04.09.24	24,00	1.745	72,71	---	---	---	17:37	195,04	20,06
05.09.24	24,00	1.727	71,96	---	---	---	2:40	194,99	20,10
06.09.24	24,00	1.739	72,46	---	---	---	23:19	194,93	20,16
07.09.24	24,00	1.752	73,00	---	---	---	8:21	194,87	20,22
08.09.24	24,00	1.769	73,71	---	---	---	11:31	194,92	20,17
09.09.24	24,00	1.769	73,71	---	---	---	4:34	194,92	20,17
10.09.24	22,30	1.639	73,50	10:31	196,94	18,15	6:50	194,88	20,22
11.09.24	24,00	1.770	73,75	---	---	---	5:02	194,95	20,14
12.09.24	24,00	1.755	73,13	---	---	---	1:26	194,92	20,17
13.09.24	24,00	1.748	72,83	---	---	---	3:51	194,87	20,22
14.09.24	24,00	1.769	73,71	---	---	---	8:07	194,82	20,27
15.09.24	24,00	1.771	73,79	---	---	---	3:31	194,85	20,24
16.09.24	24,00	1.761	73,38	---	---	---	3:21	194,85	20,24
17.09.24	24,00	1.764	73,50	---	---	---	3:14	194,89	20,20
18.09.24	24,00	1.762	73,42	---	---	---	4:18	194,91	20,18
19.09.24	21,31	1.568	73,58	11:33	197,02	18,07	8:55	194,88	20,22
20.09.24	24,00	1.760	73,33	---	---	---	23:58	194,98	20,12
21.09.24	24,00	1.775	73,96	---	---	---	9:50	194,94	20,15
22.09.24	21,82	1.605	73,57	8:49	197,02	18,07	4:51	194,94	20,15
23.09.24	24,00	1.753	73,04	---	---	---	0:56	195,02	20,07
24.09.24	24,00	1.721	71,71	---	---	---	11:52	191,01	24,08
25.09.24	24,00	1.750	72,92	---	---	---	7:54	194,88	20,21
26.09.24	24,00	1.750	72,92	---	---	---	4:23	194,96	20,13
27.09.24	24,00	1.747	72,79	---	---	---	23:41	194,92	20,17
28.09.24	24,00	1.747	72,79	---	---	---	7:22	194,83	20,26
29.09.24	24,00	1.766	73,58	---	---	---	6:45	194,80	20,29
30.09.24	24,00	1.741	72,54	---	---	---	0:53	194,91	20,18
Σ	707,92	51.783							
Mittelwert	23,60	1.726	73,15		197,03	18,06		194,79	20,30
Minimum	20,65	1.520	71,71		196,94	17,97		191,01	19,99
Maximum	24,00	1.775	73,96		197,12	18,15		195,10	24,08

Meßpunkthöhe (MP): 215,09 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB05
Monatsbericht vom September 2024
gedruckt am: 03.10.2024, 14:42 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.09.24	20,64	454	22,00	12:46	196,88	12,71	0:53	195,74	13,84
02.09.24	24,00	526	21,92	---	---	---	7:27	195,81	13,78
03.09.24	21,83	479	21,94	10:49	196,80	12,78	7:45	195,76	13,82
04.09.24	24,00	528	22,00	---	---	---	22:12	195,71	13,87
05.09.24	24,00	522	21,75	---	---	---	2:08	195,68	13,90
06.09.24	24,00	526	21,92	---	---	---	10:07	195,65	13,93
07.09.24	24,00	529	22,04	---	---	---	8:21	195,61	13,98
08.09.24	24,00	532	22,17	---	---	---	11:11	195,62	13,96
09.09.24	24,00	532	22,17	---	---	---	4:09	195,62	13,96
10.09.24	22,29	494	22,16	10:32	196,75	12,84	3:21	195,60	13,98
11.09.24	24,00	531	22,13	---	---	---	16:04	195,64	13,95
12.09.24	24,00	525	21,88	---	---	---	6:37	195,62	13,96
13.09.24	24,00	524	21,83	---	---	---	3:51	195,60	13,98
14.09.24	24,00	529	22,04	---	---	---	8:04	195,55	14,03
15.09.24	24,00	529	22,04	---	---	---	3:31	195,57	14,01
16.09.24	24,00	526	21,92	---	---	---	3:21	195,57	14,01
17.09.24	24,00	526	21,92	---	---	---	6:19	195,54	14,05
18.09.24	24,00	525	21,88	---	---	---	4:05	195,55	14,03
19.09.24	21,29	468	21,98	11:36	196,77	12,81	8:59	195,56	14,02
20.09.24	24,00	523	21,79	---	---	---	10:10	195,59	13,99
21.09.24	24,00	527	21,96	---	---	---	4:43	195,57	14,01
22.09.24	21,80	476	21,83	8:42	196,65	12,93	3:32	195,55	14,03
23.09.24	24,00	519	21,63	---	---	---	2:27	195,62	13,96
24.09.24	24,00	516	21,50	---	---	---	6:15	195,64	13,95
25.09.24	24,00	518	21,58	---	---	---	7:54	195,55	14,03
26.09.24	24,00	520	21,67	---	---	---	4:20	195,65	13,93
27.09.24	24,00	518	21,58	---	---	---	8:48	195,65	13,93
28.09.24	24,00	519	21,63	---	---	---	7:01	195,62	13,96
29.09.24	24,00	522	21,75	---	---	---	6:42	195,61	13,98
30.09.24	24,00	517	21,54	---	---	---	0:00	195,65	13,93
Σ	707,85	15.480							
Mittelwert	23,60	516	21,87		196,77	12,81		195,62	13,96
Minimum	20,64	454	21,50		196,65	12,71		195,54	13,78
Maximum	24,00	532	22,17		196,88	12,93		195,81	14,05

Meßpunkthöhe (MP): 209,58 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB06
Monatsbericht vom September 2024
gedruckt am: 03.10.2024, 14:42 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.09.24	20,62	610	29,58	12:46	197,21	9,78	4:56	195,37	11,62
02.09.24	24,00	696	29,00	---	---	---	6:52	195,43	11,56
03.09.24	21,51	622	28,92	10:52	197,12	9,87	7:49	195,33	11,66
04.09.24	24,00	689	28,71	---	---	---	22:09	195,40	11,60
05.09.24	24,00	678	28,25	---	---	---	2:09	195,35	11,64
06.09.24	24,00	686	28,58	---	---	---	10:53	195,33	11,67
07.09.24	24,00	696	29,00	---	---	---	8:21	195,23	11,76
08.09.24	24,00	708	29,50	---	---	---	11:12	195,30	11,69
09.09.24	24,00	709	29,54	---	---	---	4:12	195,23	11,76
10.09.24	22,26	656	29,47	10:33	197,02	9,97	6:44	195,18	11,81
11.09.24	24,00	711	29,63	---	---	---	5:02	195,27	11,72
12.09.24	24,00	696	29,00	---	---	---	1:26	195,24	11,75
13.09.24	24,00	691	28,79	---	---	---	3:51	195,20	11,79
14.09.24	24,00	706	29,42	---	---	---	8:08	195,18	11,81
15.09.24	24,00	708	29,50	---	---	---	3:31	195,18	11,81
16.09.24	24,00	696	29,00	---	---	---	3:03	195,21	11,78
17.09.24	23,85	693	29,05	---	---	---	3:17	195,18	11,81
18.09.24	24,00	696	29,00	---	---	---	4:09	195,17	11,83
19.09.24	21,27	622	29,24	11:36	197,02	9,97	8:59	195,09	11,90
20.09.24	24,00	695	28,96	---	---	---	12:01	195,26	11,73
21.09.24	24,00	704	29,33	---	---	---	9:50	195,17	11,83
22.09.24	21,78	637	29,24	8:43	196,96	10,04	3:35	195,17	11,83
23.09.24	24,00	693	28,88	---	---	---	2:49	195,30	11,69
24.09.24	24,00	680	28,33	---	---	---	8:47	195,28	11,71
25.09.24	24,00	692	28,83	---	---	---	7:54	195,08	11,92
26.09.24	24,00	695	28,96	---	---	---	4:23	195,29	11,70
27.09.24	24,00	695	28,96	---	---	---	5:06	195,37	11,63
28.09.24	24,00	696	29,00	---	---	---	7:04	195,29	11,70
29.09.24	24,00	708	29,50	---	---	---	6:45	195,24	11,75
30.09.24	24,00	693	28,88	---	---	---	0:19	195,37	11,63
Σ	707,30	20.557							
Mittelwert	23,58	685	29,06		197,06	9,93		195,26	11,73
Minimum	20,62	610	28,25		196,96	9,78		195,08	11,56
Maximum	24,00	711	29,63		197,21	10,04		195,43	11,92

Meßpunkthöhe (MP): 206,99 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB07
Monatsbericht vom September 2024
gedruckt am: 03.10.2024, 14:42 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.09.24	20,61	1.159	56,25	12:47	196,81	5,86	5:29	194,49	8,18
02.09.24	24,00	1.347	56,13	---	---	---	23:50	194,53	8,14
03.09.24	21,39	1.199	56,07	10:58	196,73	5,94	7:49	194,49	8,18
04.09.24	24,00	1.345	56,04	---	---	---	22:09	194,50	8,17
05.09.24	24,00	1.340	55,83	---	---	---	2:08	194,49	8,18
06.09.24	24,00	1.344	56,00	---	---	---	3:00	194,43	8,24
07.09.24	24,00	1.347	56,13	---	---	---	8:54	194,41	8,26
08.09.24	24,00	1.351	56,29	---	---	---	21:49	194,40	8,27
09.09.24	24,00	1.352	56,33	---	---	---	4:12	194,40	8,27
10.09.24	22,01	1.238	56,25	10:30	196,62	6,05	6:44	194,35	8,32
11.09.24	24,00	1.350	56,25	---	---	---	23:57	194,41	8,26
12.09.24	24,00	1.345	56,04	---	---	---	1:26	194,40	8,27
13.09.24	24,00	1.341	55,88	---	---	---	3:58	194,37	8,30
14.09.24	24,00	1.348	56,17	---	---	---	8:15	194,34	8,33
15.09.24	24,00	1.349	56,21	---	---	---	3:47	194,34	8,33
16.09.24	24,00	1.344	56,00	---	---	---	4:44	194,35	8,32
17.09.24	24,00	1.344	56,00	---	---	---	3:17	194,34	8,33
18.09.24	24,00	1.343	55,96	---	---	---	4:25	194,34	8,33
19.09.24	21,26	1.194	56,16	11:36	196,62	6,05	8:59	194,30	8,37
20.09.24	24,00	1.344	56,00	---	---	---	15:12	194,37	8,30
21.09.24	24,00	1.348	56,17	---	---	---	9:47	194,32	8,35
22.09.24	21,76	1.223	56,20	8:49	196,57	6,10	3:39	194,32	8,35
23.09.24	24,00	1.346	56,08	---	---	---	6:03	194,40	8,27
24.09.24	24,00	1.340	55,83	---	---	---	5:06	194,41	8,26
25.09.24	24,00	1.344	56,00	---	---	---	7:54	194,29	8,38
26.09.24	24,00	1.344	56,00	---	---	---	1:32	194,47	8,20
27.09.24	24,00	1.346	56,08	---	---	---	0:00	194,49	8,18
28.09.24	24,00	1.345	56,04	---	---	---	7:33	194,46	8,21
29.09.24	24,00	1.351	56,29	---	---	---	6:45	194,44	8,23
30.09.24	24,00	1.340	55,83	---	---	---	3:13	194,51	8,16
Σ	707,02	39.651							
Mittelwert	23,57	1.322	56,08		196,67	6,00		194,40	8,27
Minimum	20,61	1.159	55,83		196,57	5,86		194,29	8,14
Maximum	24,00	1.352	56,33		196,81	6,10		194,53	8,38

Meßpunkthöhe (MP): 202,67 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB08
Monatsbericht vom September 2024
gedruckt am: 03.10.2024, 14:42 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.09.24	20,59	1.017	49,40	12:48	197,38	7,91	6:38	195,17	10,13
02.09.24	24,00	1.180	49,17	---	---	---	21:36	195,24	10,06
03.09.24	21,38	1.050	49,10	10:48	197,30	7,99	7:49	195,20	10,10
04.09.24	24,00	1.177	49,04	---	---	---	22:27	195,20	10,10
05.09.24	24,00	1.172	48,83	---	---	---	2:08	195,17	10,13
06.09.24	24,00	1.175	48,96	---	---	---	13:46	195,14	10,16
07.09.24	24,00	1.180	49,17	---	---	---	8:21	195,09	10,20
08.09.24	24,00	1.184	49,33	---	---	---	11:33	195,11	10,19
09.09.24	24,00	1.185	49,38	---	---	---	4:12	195,09	10,20
10.09.24	21,61	1.067	49,37	10:29	197,19	8,10	6:44	195,06	10,23
11.09.24	24,00	1.185	49,38	---	---	---	16:04	195,12	10,17
12.09.24	24,00	1.179	49,13	---	---	---	5:31	195,09	10,20
13.09.24	24,00	1.176	49,00	---	---	---	3:51	195,06	10,23
14.09.24	24,00	1.183	49,29	---	---	---	8:22	195,01	10,28
15.09.24	24,00	1.184	49,33	---	---	---	3:31	195,03	10,26
16.09.24	24,00	1.178	49,08	---	---	---	2:59	195,04	10,25
17.09.24	24,00	1.178	49,08	---	---	---	5:19	195,01	10,28
18.09.24	24,00	1.177	49,04	---	---	---	4:25	195,01	10,29
19.09.24	21,24	1.044	49,14	11:44	197,18	8,11	8:58	194,98	10,32
20.09.24	24,00	1.177	49,04	---	---	---	21:25	195,04	10,25
21.09.24	24,00	1.181	49,21	---	---	---	9:50	195,01	10,29
22.09.24	21,75	1.070	49,20	8:47	197,12	8,17	3:35	195,01	10,29
23.09.24	24,00	1.177	49,04	---	---	---	1:52	195,09	10,20
24.09.24	24,00	1.170	48,75	---	---	---	9:24	195,08	10,22
25.09.24	24,00	1.175	48,96	---	---	---	7:54	194,96	10,33
26.09.24	24,00	1.177	49,04	---	---	---	4:23	195,12	10,17
27.09.24	24,00	1.178	49,08	---	---	---	1:00	195,16	10,13
28.09.24	24,00	1.177	49,04	---	---	---	7:04	195,14	10,16
29.09.24	24,00	1.185	49,38	---	---	---	6:45	195,11	10,19
30.09.24	24,00	1.174	48,92	---	---	---	0:00	195,18	10,11
Σ	706,58	34.712							
Mittelwert	23,55	1.157	49,13		197,23	8,06		195,09	10,20
Minimum	20,59	1.017	48,75		197,12	7,91		194,96	10,06
Maximum	24,00	1.185	49,40		197,38	8,17		195,24	10,33

Meßpunkthöhe (MP): 205,29 m üNN