

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.25	24,00	1.210	50,42	---	---	---	0:00	193,75	16,01
02.02.25	24,00	1.217	50,71	---	---	---	2:14	193,90	15,87
03.02.25	24,00	1.208	50,33	---	---	---	17:38	193,91	15,85
04.02.25	24,00	1.201	50,04	---	---	---	17:01	193,78	15,98
05.02.25	24,00	1.203	50,13	---	---	---	20:49	193,75	16,01
06.02.25	24,00	1.203	50,13	---	---	---	0:21	193,74	16,03
07.02.25	24,00	1.205	50,21	---	---	---	0:00	193,77	16,00
08.02.25	24,00	1.209	50,38	---	---	---	0:00	193,85	15,91
09.02.25	24,00	1.226	51,08	---	---	---	0:00	193,91	15,85
10.02.25	24,00	1.225	51,04	---	---	---	0:49	194,24	15,52
11.02.25	24,00	1.224	51,00	---	---	---	11:28	194,19	15,57
12.02.25	24,00	1.227	51,13	---	---	---	6:05	194,31	15,45
13.02.25	24,00	1.228	51,17	---	---	---	4:45	194,34	15,42
14.02.25	24,00	1.224	51,00	---	---	---	22:49	194,29	15,47
15.02.25	24,00	1.228	51,17	---	---	---	0:25	194,29	15,47
16.02.25	24,00	1.232	51,33	---	---	---	4:50	194,36	15,40
17.02.25	24,00	1.216	50,67	---	---	---	22:21	194,09	15,68
18.02.25	20,95	1.052	50,20	13:16	195,80	13,96	20:14	193,94	15,82
19.02.25	22,79	1.143	50,15	9:19	195,77	13,99	0:00	193,94	15,82
20.02.25	24,00	1.205	50,21	---	---	---	23:24	193,84	15,93
21.02.25	24,00	1.206	50,25	---	---	---	0:00	193,85	15,91
22.02.25	24,00	1.206	50,25	---	---	---	22:23	193,84	15,93
23.02.25	23,91	1.203	50,31	---	---	---	19:44	193,79	15,97
24.02.25	24,00	1.209	50,38	---	---	---	0:00	193,87	15,90
25.02.25	24,00	1.212	50,50	---	---	---	3:55	193,88	15,88
26.02.25	24,00	1.218	50,75	---	---	---	10:23	194,09	15,68
27.02.25	24,00	1.224	51,00	---	---	---	0:00	194,16	15,60
28.02.25	24,00	1.219	50,79	---	---	---	17:34	194,13	15,63
Σ	667,66	33.783							
Mittelwert	23,84	1.207	50,60		195,79	13,97		193,99	15,77
Minimum	20,95	1.052	50,04		195,77	13,96		193,74	15,40
Maximum	24,00	1.232	51,33		195,80	13,99		194,36	16,03

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.25	24,00	5.673	236,38	---	---	---	0:00	192,45	15,38
02.02.25	24,00	5.706	237,75	---	---	---	0:28	192,67	15,15
03.02.25	24,00	5.660	235,83	---	---	---	16:30	192,42	15,41
04.02.25	24,00	5.617	234,04	---	---	---	11:53	191,77	16,05
05.02.25	24,00	5.637	234,88	---	---	---	20:09	192,14	15,68
06.02.25	24,00	5.627	234,46	---	---	---	18:08	192,06	15,77
07.02.25	24,00	5.643	235,13	---	---	---	22:36	192,28	15,55
08.02.25	24,00	5.663	235,96	---	---	---	2:26	192,39	15,43
09.02.25	6,45	1.533	237,75	21:28	199,35	8,47	0:00	192,72	15,10
10.02.25	0,00	0	---	8:17	199,43	8,39	---	---	---
11.02.25	1,96	451	229,61	6:38	199,68	8,14	10:15	192,53	15,29
12.02.25	0,00	0	---	6:45	199,60	8,22	---	---	---
13.02.25	0,00	0	---	6:52	200,44	7,38	---	---	---
14.02.25	0,00	0	---	5:12	199,47	8,35	---	---	---
15.02.25	0,00	0	---	7:32	199,57	8,25	---	---	---
16.02.25	0,00	0	---	10:00	199,85	7,97	---	---	---
17.02.25	17,66	4.170	236,11	6:15	199,63	8,19	20:57	192,81	15,02
18.02.25	24,00	5.614	233,92	---	---	---	12:15	191,95	15,87
19.02.25	22,80	5.349	234,62	9:20	199,85	7,97	22:27	192,42	15,40
20.02.25	24,00	5.643	235,13	---	---	---	21:51	192,21	15,61
21.02.25	24,00	5.648	235,33	---	---	---	23:23	192,28	15,55
22.02.25	24,00	5.644	235,17	---	---	---	17:30	192,35	15,48
23.02.25	23,71	5.592	235,81	---	---	---	19:37	192,16	15,67
24.02.25	23,67	5.583	235,90	---	---	---	22:48	192,59	15,23
25.02.25	11,76	2.768	235,45	23:52	199,07	8,75	10:20	192,35	15,48
26.02.25	1,41	312	220,67	6:25	199,25	8,57	9:18	192,84	14,99
27.02.25	0,22	48	216,00	10:12	199,34	8,48	---	---	---
28.02.25	1,15	255	221,20	6:46	199,37	8,45	---	---	---
Σ	398,80	93.836							
Mittelwert	14,24	3.351	235,30		199,56	8,26		192,37	15,45
Minimum	0,00	0	216,00		199,07	7,38		191,77	14,99
Maximum	24,00	5.706	237,75		200,44	8,75		192,84	16,05

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.02.25	0,00	0	---	10:03	193,94	18,89	---	---	---
02.02.25	0,00	0	---	8:56	194,20	18,63	---	---	---
03.02.25	0,00	0	---	7:44	194,19	18,65	---	---	---
04.02.25	3,05	421	138,03	8:34	193,96	18,88	11:07	189,11	23,73
05.02.25	0,00	0	---	10:11	193,94	18,89	---	---	---
06.02.25	0,00	0	---	6:47	193,77	19,06	---	---	---
07.02.25	0,00	0	---	8:09	193,94	18,89	---	---	---
08.02.25	0,00	0	---	11:39	193,88	18,95	---	---	---
09.02.25	17,53	2.536	144,68	6:21	194,00	18,83	13:37	190,26	22,58
10.02.25	24,00	3.460	144,17	---	---	---	0:55	190,26	22,58
11.02.25	24,00	3.454	143,92	---	---	---	10:18	189,43	23,41
12.02.25	24,00	3.465	144,38	---	---	---	0:00	190,26	22,58
13.02.25	23,33	3.370	144,47	---	---	---	4:39	190,32	22,52
14.02.25	24,00	3.454	143,92	---	---	---	22:21	190,24	22,60
15.02.25	24,00	3.471	144,63	---	---	---	0:29	190,27	22,56
16.02.25	24,00	3.479	144,96	---	---	---	1:17	190,44	22,40
17.02.25	6,33	917	144,93	10:15	194,36	18,48	0:43	190,51	22,32
18.02.25	2,30	313	135,82	4:32	193,96	18,88	12:11	189,11	23,73
19.02.25	0,62	83	134,11	9:21	194,78	18,05	---	---	---
20.02.25	0,71	96	134,84	10:03	194,16	18,68	---	---	---
21.02.25	0,00	0	---	7:34	194,08	18,75	---	---	---
22.02.25	0,00	0	---	10:48	193,93	18,91	---	---	---
23.02.25	1,14	155	136,13	9:14	193,96	18,88	18:31	189,54	23,30
24.02.25	0,00	0	---	11:10	194,36	18,48	---	---	---
25.02.25	13,68	1.954	142,87	8:37	193,99	18,85	10:11	189,49	23,35
26.02.25	24,00	3.440	143,33	---	---	---	9:19	189,44	23,39
27.02.25	24,00	3.458	144,08	---	---	---	6:25	190,01	22,82
28.02.25	24,00	3.445	143,54	---	---	---	15:58	189,63	23,21
Σ	284,68	40.971							
Mittelwert	10,17	1.463	143,92		194,08	18,75		189,89	22,94
Minimum	0,00	0	134,11		193,77	18,05		189,11	22,32
Maximum	24,00	3.479	144,96		194,78	19,06		190,51	23,73

Meßpunkthöhe (MP): 212,83 m üNN

gedruckt am: 03.03.2025, 02:09 Uhr in Stadallendorf

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.02.25	23,17	2.803	120,98	---	---	---	0:00	183,83	30,95
02.02.25	20,86	2.531	121,34	7:38	194,50	20,27	0:26	184,00	30,78
03.02.25	22,81	2.750	120,56	---	---	---	16:31	183,81	30,96
04.02.25	23,52	2.824	120,06	---	---	---	16:49	183,55	31,22
05.02.25	22,80	2.739	120,13	---	---	---	20:09	183,49	31,28
06.02.25	24,00	2.882	120,08	---	---	---	18:04	183,37	31,40
07.02.25	23,20	2.789	120,23	---	---	---	22:34	183,58	31,19
08.02.25	24,00	2.899	120,79	---	---	---	2:24	183,68	31,10
09.02.25	10,77	1.306	121,30	17:17	194,91	19,86	0:00	184,06	30,72
10.02.25	11,86	1.435	121,01	7:49	195,05	19,72	13:05	184,76	30,01
11.02.25	11,24	1.356	120,63	7:48	195,37	19,40	23:13	184,75	30,03
12.02.25	11,61	1.412	121,59	7:27	195,30	19,48	16:57	184,98	29,80
13.02.25	13,55	1.647	121,57	7:18	195,83	18,95	21:21	184,87	29,91
14.02.25	16,01	1.940	121,16	4:57	194,79	19,98	17:30	184,67	30,11
15.02.25	10,37	1.258	121,34	7:55	195,26	19,51	0:12	185,04	29,74
16.02.25	8,67	1.053	121,40	9:46	195,75	19,02	21:27	185,25	29,52
17.02.25	18,69	2.266	121,24	3:10	195,33	19,45	20:55	184,30	30,47
18.02.25	24,00	2.878	119,92	---	---	---	14:38	183,54	31,24
19.02.25	21,78	2.616	120,10	9:24	194,24	20,53	22:23	183,80	30,98
20.02.25	22,06	2.652	120,20	9:43	194,49	20,29	21:53	183,57	31,21
21.02.25	21,36	2.567	120,18	6:45	194,44	20,33	23:19	183,65	31,13
22.02.25	23,41	2.818	120,35	---	---	---	21:45	183,69	31,08
23.02.25	22,93	2.766	120,62	---	---	---	19:36	183,72	31,05
24.02.25	21,57	2.597	120,42	---	---	---	22:44	183,95	30,82
25.02.25	19,45	2.337	120,16	---	---	---	0:44	183,83	30,95
26.02.25	13,36	1.601	119,84	6:25	194,79	19,98	11:38	184,38	30,40
27.02.25	12,44	1.499	120,54	8:43	194,90	19,88	18:22	184,73	30,04
28.02.25	13,57	1.635	120,50	2:21	194,64	20,14	17:17	184,47	30,31
Σ	513,06	61.856							
Mittelwert	18,32	2.209	120,56		194,97	19,80		184,12	30,65
Minimum	8,67	1.053	119,84		194,24	18,95		183,37	29,52
Maximum	24,00	2.899	121,59		195,83	20,53		185,25	31,40

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.25	23,23	1.305	56,17	---	---	---	0:00	188,70	24,58
02.02.25	21,01	1.193	56,78	7:36	194,61	18,67	2:12	188,87	24,41
03.02.25	22,90	1.281	55,95	---	---	---	23:26	188,87	24,41
04.02.25	23,55	1.306	55,45	---	---	---	23:38	188,70	24,58
05.02.25	22,86	1.267	55,43	---	---	---	20:54	188,63	24,65
06.02.25	24,00	1.327	55,29	---	---	---	19:11	188,52	24,76
07.02.25	23,25	1.291	55,52	---	---	---	0:00	188,58	24,70
08.02.25	24,00	1.339	55,79	---	---	---	0:00	188,68	24,60
09.02.25	10,92	629	57,59	20:54	196,59	16,69	0:00	188,85	24,43
10.02.25	12,05	704	58,44	7:40	196,84	16,44	13:08	191,01	22,27
11.02.25	11,49	665	57,90	8:02	197,17	16,11	12:04	190,99	22,29
12.02.25	11,86	700	59,01	7:32	197,09	16,19	17:00	191,32	21,96
13.02.25	13,70	804	58,69	7:46	197,42	15,86	21:36	191,22	22,06
14.02.25	16,21	949	58,55	4:55	196,72	16,56	17:36	191,02	22,26
15.02.25	10,66	630	59,10	8:00	197,12	16,16	0:16	191,34	21,94
16.02.25	8,84	521	58,95	10:55	197,64	15,64	21:30	191,63	21,65
17.02.25	18,74	1.066	56,88	3:03	197,26	16,02	22:24	189,53	23,75
18.02.25	24,00	1.326	55,25	---	---	---	15:19	188,90	24,38
19.02.25	21,89	1.216	55,55	9:22	194,86	18,42	0:01	188,96	24,32
20.02.25	22,09	1.226	55,50	9:42	194,61	18,67	23:48	188,81	24,47
21.02.25	21,42	1.189	55,51	6:44	194,58	18,70	0:00	188,82	24,46
22.02.25	23,45	1.301	55,48	---	---	---	22:39	188,82	24,46
23.02.25	22,90	1.279	55,86	---	---	---	0:00	188,82	24,46
24.02.25	21,72	1.212	55,81	---	---	---	4:59	188,94	24,34
25.02.25	19,81	1.120	56,55	---	---	---	3:52	188,92	24,36
26.02.25	13,71	788	57,47	6:26	196,54	16,74	11:51	190,57	22,71
27.02.25	12,85	754	58,66	8:37	196,72	16,56	18:28	191,05	22,23
28.02.25	13,91	807	58,01	13:14	196,35	16,93	17:25	190,74	22,54
Σ	517,02	29.195							
Mittelwert	18,46	1.043	56,47		196,38	16,90		189,64	23,64
Minimum	8,84	521	55,25		194,58	15,64		188,52	21,65
Maximum	24,00	1.339	59,10		197,64	18,70		191,63	24,76

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.02.25	24,00	2.646	110,25	---	---	---	4:44	193,55	23,25
02.02.25	24,00	2.665	111,04	---	---	---	2:26	193,62	23,18
03.02.25	24,00	2.636	109,83	---	---	---	3:50	193,72	23,08
04.02.25	22,78	2.482	108,96	9:10	200,74	16,06	7:59	193,56	23,24
05.02.25	24,00	2.622	109,25	---	---	---	7:57	193,54	23,26
06.02.25	24,00	2.616	109,00	---	---	---	19:11	193,51	23,29
07.02.25	24,00	2.624	109,33	---	---	---	1:39	193,43	23,37
08.02.25	24,00	2.636	109,83	---	---	---	0:24	193,60	23,20
09.02.25	6,42	713	111,05	21:00	202,31	14,49	5:45	193,60	23,20
10.02.25	0,00	0	---	7:57	202,50	14,30	---	---	---
11.02.25	0,81	89	109,61	8:19	202,74	14,06	---	---	---
12.02.25	0,00	0	---	7:44	202,74	14,06	---	---	---
13.02.25	0,00	0	---	7:55	202,93	13,87	---	---	---
14.02.25	0,00	0	---	4:53	202,64	14,16	---	---	---
15.02.25	0,00	0	---	8:08	202,80	14,00	---	---	---
16.02.25	0,00	0	---	10:43	203,09	13,71	---	---	---
17.02.25	17,71	1.958	110,57	3:21	202,93	13,87	22:36	194,26	22,54
18.02.25	24,00	2.615	108,96	---	---	---	20:11	193,84	22,96
19.02.25	22,83	2.494	109,24	9:17	201,00	15,80	5:19	193,76	23,04
20.02.25	24,00	2.630	109,58	---	---	---	23:41	193,75	23,05
21.02.25	24,00	2.629	109,54	---	---	---	3:53	193,62	23,18
22.02.25	24,00	2.627	109,46	---	---	---	7:05	193,65	23,15
23.02.25	23,53	2.587	109,95	---	---	---	6:27	193,60	23,20
24.02.25	23,69	2.601	109,80	---	---	---	5:11	193,65	23,15
25.02.25	11,74	1.289	109,84	23:57	201,92	14,88	3:53	193,61	23,19
26.02.25	1,45	151	104,42	6:26	202,33	14,47	9:16	196,04	20,76
27.02.25	0,24	27	110,58	8:58	202,49	14,31	---	---	---
28.02.25	1,19	126	106,13	6:34	202,55	14,25	---	---	---
Σ	396,38	43.463							
Mittelwert	14,16	1.552	109,65		202,38	14,42		193,79	23,01
Minimum	0,00	0	104,42		200,74	13,71		193,43	20,76
Maximum	24,00	2.665	111,05		203,09	16,06		196,04	23,37

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.02.25	24,00	4.517	188,21	---	---	---	4:45	179,20	41,95
02.02.25	24,00	4.579	190,79	---	---	---	2:22	179,22	41,93
03.02.25	24,00	4.472	186,33	---	---	---	3:50	179,35	41,80
04.02.25	22,75	4.168	183,22	9:12	196,44	24,71	6:32	179,20	41,95
05.02.25	24,00	4.428	184,50	---	---	---	8:05	179,13	42,02
06.02.25	24,00	4.413	183,88	---	---	---	18:58	179,47	41,68
07.02.25	24,00	4.437	184,88	---	---	---	1:47	179,03	42,12
08.02.25	24,00	4.489	187,04	---	---	---	0:23	179,62	41,53
09.02.25	6,44	1.237	191,96	21:16	198,23	22,92	5:54	179,18	41,97
10.02.25	0,00	0	---	7:56	198,47	22,68	---	---	---
11.02.25	0,85	152	178,01	8:03	198,76	22,39	---	---	---
12.02.25	0,00	0	---	7:52	198,80	22,35	---	---	---
13.02.25	0,00	0	---	8:03	199,05	22,10	---	---	---
14.02.25	0,00	0	---	5:07	198,73	22,42	---	---	---
15.02.25	0,00	0	---	8:19	198,88	22,27	---	---	---
16.02.25	0,00	0	---	10:48	199,20	21,95	---	---	---
17.02.25	17,70	3.340	188,67	3:07	199,02	22,13	22:38	180,30	40,85
18.02.25	24,00	4.408	183,67	---	---	---	15:33	179,85	41,30
19.02.25	22,86	4.211	184,19	9:16	196,64	24,51	5:19	179,37	41,78
20.02.25	24,00	4.458	185,75	---	---	---	7:55	179,42	41,73
21.02.25	24,00	4.448	185,33	---	---	---	4:00	179,25	41,90
22.02.25	24,00	4.450	185,42	---	---	---	7:07	179,22	41,93
23.02.25	23,81	4.464	187,50	---	---	---	19:43	178,58	42,57
24.02.25	23,70	4.421	186,51	---	---	---	10:48	178,90	42,25
25.02.25	11,75	2.199	187,09	23:48	197,84	23,31	4:10	179,24	41,91
26.02.25	1,48	249	168,18	6:13	198,27	22,88	9:18	183,86	37,29
27.02.25	0,27	45	168,75	9:55	198,51	22,64	---	---	---
28.02.25	1,22	207	168,98	5:30	198,61	22,54	---	---	---
Σ	396,85	73.792							
Mittelwert	14,17	2.635	185,94		198,36	22,79		179,55	41,60
Minimum	0,00	0	168,18		196,44	21,95		178,58	37,29
Maximum	24,00	4.579	191,96		199,20	24,71		183,86	42,57

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablutung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt			Zeitpunkt		
				Uhr			m üNN		
h	m³	m³/h							
01.02.25	0,00	0	---	6:18	188,02	39,51	---	---	---
02.02.25	0,00	0	---	---	---	---	---	---	---
03.02.25	0,00	0	---	0:27	188,02	39,51	---	---	---
04.02.25	0,00	0	---	6:33	188,02	39,51	---	---	---
05.02.25	0,00	0	---	---	---	---	---	---	---
06.02.25	0,00	0	---	---	---	---	---	---	---
07.02.25	0,00	0	---	15:50	188,02	39,51	---	---	---
08.02.25	0,00	0	---	3:23	188,02	39,51	---	---	---
09.02.25	0,00	0	---	8:24	188,02	39,51	---	---	---
10.02.25	0,00	0	---	15:58	188,02	39,51	---	---	---
11.02.25	0,00	0	---	4:05	188,02	39,51	---	---	---
12.02.25	0,00	0	---	12:48	188,02	39,51	---	---	---
13.02.25	0,00	0	---	2:27	188,02	39,51	---	---	---
14.02.25	0,00	0	---	2:48	188,02	39,51	---	---	---
15.02.25	0,00	0	---	---	---	---	---	---	---
16.02.25	0,00	0	---	10:57	188,02	39,51	---	---	---
17.02.25	0,00	0	---	2:45	188,02	39,51	---	---	---
18.02.25	0,00	0	---	18:36	188,02	39,51	---	---	---
19.02.25	0,00	0	---	19:06	188,02	39,51	---	---	---
20.02.25	0,00	0	---	3:02	188,02	39,51	---	---	---
21.02.25	0,00	0	---	19:52	188,02	39,51	---	---	---
22.02.25	0,00	0	---	0:19	188,02	39,51	---	---	---
23.02.25	0,00	0	---	6:46	188,02	39,51	---	---	---
24.02.25	0,00	0	---	6:34	188,02	39,51	---	---	---
25.02.25	0,00	0	---	0:00	188,01	39,51	---	---	---
26.02.25	0,00	0	---	13:05	188,02	39,51	---	---	---
27.02.25	0,00	0	---	7:22	188,02	39,51	---	---	---
28.02.25	0,00	0	---	0:40	188,02	39,51	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,01	39,51		---	---
Minimum	0,00	0	---		188,01	39,51		---	---
Maximum	0,00	0	---		188,02	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

gedruckt am: 03.03.2025, 02:09 Uhr in Stadallendorf

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom Februar 2025
gedruckt am: 03.03.2025, 02:09 Uhr in Stadtallendorf

Tag	Förderdaten			Abtutung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.25	0,00	0	---	13:33	197,15	47,67	---	---	---
02.02.25	0,00	0	---	10:17	197,32	47,51	---	---	---
03.02.25	0,00	0	---	9:50	197,30	47,52	---	---	---
04.02.25	0,91	155	170,54	9:40	197,26	47,57	---	---	---
05.02.25	0,00	0	---	11:32	197,16	47,66	---	---	---
06.02.25	0,00	0	---	7:33	197,07	47,75	---	---	---
07.02.25	0,00	0	---	10:13	197,18	47,64	---	---	---
08.02.25	0,00	0	---	12:58	197,19	47,63	---	---	---
09.02.25	17,61	2.992	169,94	4:52	197,21	47,61	11:13	193,47	51,35
10.02.25	24,00	4.058	169,08	---	---	---	13:48	193,42	51,40
11.02.25	24,00	4.053	168,88	---	---	---	23:29	193,41	51,42
12.02.25	24,00	4.053	168,88	---	---	---	0:00	193,41	51,42
13.02.25	23,45	3.951	168,49	---	---	---	23:27	193,46	51,36
14.02.25	24,00	4.017	167,38	---	---	---	17:36	193,36	51,46
15.02.25	24,00	4.021	167,54	---	---	---	0:00	193,36	51,46
16.02.25	24,00	4.030	167,92	---	---	---	1:30	193,47	51,36
17.02.25	6,37	1.069	167,69	14:55	197,26	47,57	1:24	193,50	51,32
18.02.25	2,31	386	166,96	0:00	197,18	47,64	12:14	193,55	51,27
19.02.25	0,74	128	172,52	10:06	197,21	47,61	---	---	---
20.02.25	0,84	142	168,99	10:23	197,22	47,60	---	---	---
21.02.25	0,00	0	---	9:44	197,26	47,57	---	---	---
22.02.25	0,00	0	---	12:03	197,24	47,58	---	---	---
23.02.25	0,00	0	---	21:40	197,21	47,61	---	---	---
24.02.25	0,00	0	---	14:43	197,35	47,47	---	---	---
25.02.25	13,49	2.283	169,29	8:35	197,34	47,48	22:11	193,38	51,45
26.02.25	24,00	4.034	168,08	---	---	---	12:55	193,36	51,46
27.02.25	24,00	4.035	168,13	---	---	---	0:00	193,39	51,43
28.02.25	24,00	4.020	167,50	---	---	---	19:08	193,30	51,52
Σ	281,72	47.427							
Mittelwert	10,06	1.694	168,35		197,23	47,59		193,42	51,40
Minimum	0,00	0	166,96		197,07	47,47		193,30	51,27
Maximum	24,00	4.058	172,52		197,35	47,75		193,55	51,52

Meßpunkthöhe (MP): 244,82 m üNN