

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	24,00	2.470	102,92	---	---	---	21:44	194,60	19,68
02.03.25	24,00	2.474	103,08	---	---	---	2:19	194,66	19,61
03.03.25	24,00	2.469	102,88	---	---	---	20:36	194,70	19,57
04.03.25	23,35	2.396	102,59	---	---	---	9:02	194,63	19,65
05.03.25	23,53	2.417	102,73	---	---	---	0:07	194,61	19,66
06.03.25	8,22	842	102,45	22:56	199,95	14,32	0:00	194,69	19,59
07.03.25	1,79	187	104,32	18:43	200,24	14,04	21:22	195,71	18,56
08.03.25	0,31	32	102,04	22:41	200,33	13,94	---	---	---
09.03.25	0,22	24	109,51	18:33	200,58	13,69	---	---	---
10.03.25	0,77	78	101,15	8:35	200,60	13,67	---	---	---
11.03.25	2,79	289	103,76	6:08	200,62	13,66	10:18	195,53	18,75
12.03.25	0,00	0	---	7:36	200,50	13,77	---	---	---
13.03.25	14,40	1.479	102,68	7:35	200,50	13,77	22:29	194,99	19,28
14.03.25	24,00	2.461	102,54	---	---	---	23:25	194,66	19,62
15.03.25	24,00	2.464	102,67	---	---	---	23:52	194,63	19,65
16.03.25	15,40	1.586	103,01	22:15	199,71	14,56	0:07	194,56	19,71
17.03.25	0,53	54	101,62	19:41	199,86	14,41	---	---	---
18.03.25	4,95	510	103,09	5:54	199,91	14,36	11:52	195,22	19,05
19.03.25	8,50	878	103,26	20:47	200,14	14,13	17:01	195,27	19,00
20.03.25	4,17	430	103,09	5:33	200,44	13,83	9:43	195,91	18,37
21.03.25	0,00	0	---	23:58	199,98	14,29	---	---	---
22.03.25	12,45	1.285	103,17	11:29	200,16	14,11	21:59	195,07	19,20
23.03.25	24,00	2.477	103,21	---	---	---	22:50	194,83	19,44
24.03.25	24,00	2.458	102,42	---	---	---	17:01	194,61	19,66
25.03.25	8,83	908	102,81	10:53	199,69	14,58	8:30	194,63	19,65
26.03.25	0,00	0	---	2:48	199,66	14,62	---	---	---
27.03.25	17,99	1.852	102,92	11:26	199,88	14,40	19:37	194,79	19,49
28.03.25	24,00	2.462	102,58	---	---	---	21:53	194,61	19,66
29.03.25	12,58	1.293	102,82	23:48	199,72	14,55	3:06	194,60	19,68
30.03.25	0,00	0	---	18:39	199,98	14,29	---	---	---
31.03.25	0,00	0	---	7:22	200,10	14,17	---	---	---
Σ	352,79	36.275							
Mittelwert	11,38	1.170	102,82		200,12	14,15		194,88	19,39
Minimum	0,00	0	101,15		199,66	13,66		194,56	18,37
Maximum	24,00	2.477	109,51		200,62	14,62		195,91	19,71

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.25	9,20	1.231	133,84	9:53	200,76	13,46	21:37	195,98	18,24
02.03.25	6,66	899	134,89	9:21	200,90	13,32	2:07	196,17	18,05
03.03.25	9,73	1.313	134,89	10:34	200,82	13,41	20:26	196,18	18,05
04.03.25	14,31	1.924	134,45	12:32	200,76	13,46	8:53	195,70	18,52
05.03.25	11,81	1.579	133,69	14:52	200,78	13,44	0:00	196,00	18,22
06.03.25	12,89	1.784	138,45	---	---	---	9:59	195,88	18,34
07.03.25	9,38	1.316	140,30	8:15	201,27	12,96	16:05	196,33	17,89
08.03.25	12,03	1.698	141,16	22:38	201,27	12,95	18:23	196,36	17,86
09.03.25	5,14	730	141,92	18:26	201,63	12,59	0:05	196,51	17,71
10.03.25	9,08	1.282	141,25	15:52	201,73	12,49	23:16	196,67	17,55
11.03.25	14,28	2.017	141,20	5:59	201,66	12,57	10:13	196,35	17,87
12.03.25	13,90	1.955	140,61	7:43	201,49	12,73	22:41	196,42	17,80
13.03.25	15,32	2.118	138,28	7:31	201,45	12,77	22:22	196,24	17,98
14.03.25	16,17	2.193	135,63	8:06	200,95	13,27	23:14	195,94	18,28
15.03.25	13,97	1.879	134,51	11:04	200,79	13,43	3:07	195,97	18,25
16.03.25	12,97	1.816	140,07	8:42	200,67	13,55	0:00	195,89	18,34
17.03.25	23,59	3.348	141,93	---	---	---	13:49	195,92	18,30
18.03.25	22,11	3.118	141,04	10:39	200,78	13,44	9:13	195,84	18,38
19.03.25	10,89	1.548	142,10	23:59	201,37	12,85	1:24	195,96	18,26
20.03.25	9,54	1.328	139,14	5:25	201,66	12,56	23:22	196,26	17,96
21.03.25	24,00	3.373	140,54	---	---	---	5:58	195,98	18,25
22.03.25	15,20	2.126	139,85	13:59	201,05	13,17	2:03	196,05	18,18
23.03.25	7,45	1.007	135,26	10:59	201,17	13,06	22:42	196,30	17,93
24.03.25	15,93	2.133	133,87	2:49	200,77	13,45	19:05	195,95	18,28
25.03.25	16,52	2.285	138,35	10:53	201,13	13,09	8:25	195,75	18,47
26.03.25	24,00	3.326	138,58	---	---	---	21:30	195,81	18,41
27.03.25	14,34	1.926	134,35	13:14	201,16	13,06	0:59	195,81	18,41
28.03.25	13,02	1.737	133,38	4:30	200,63	13,60	18:08	195,96	18,26
29.03.25	15,63	2.210	141,43	12:03	200,61	13,61	13:09	195,92	18,30
30.03.25	22,57	3.266	144,73	---	---	---	7:29	196,03	18,19
31.03.25	23,51	3.368	143,24	---	---	---	23:26	196,01	18,22
Σ	445,13	61.833							
Mittelwert	14,36	1.995	138,91		201,09	13,13		196,07	18,15
Minimum	5,14	730	133,38		200,61	12,49		195,70	17,55
Maximum	24,00	3.373	144,73		201,73	13,61		196,67	18,52

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	23,58	2.206	93,57	---	---	---	21:39	198,13	22,00
02.03.25	23,27	2.191	94,16	---	---	---	2:08	198,25	21,87
03.03.25	24,00	2.246	93,58	---	---	---	21:31	198,29	21,84
04.03.25	22,64	2.095	92,56	---	---	---	20:58	198,16	21,97
05.03.25	22,00	2.042	92,83	---	---	---	0:00	198,12	22,00
06.03.25	24,00	2.259	94,13	---	---	---	10:00	198,12	22,00
07.03.25	22,82	2.175	95,32	---	---	---	0:38	198,48	21,65
08.03.25	24,00	2.289	95,38	---	---	---	18:24	198,62	21,50
09.03.25	24,00	2.323	96,79	---	---	---	0:06	198,74	21,39
10.03.25	23,28	2.234	95,95	---	---	---	23:17	198,95	21,17
11.03.25	24,00	2.286	95,25	---	---	---	23:54	198,70	21,42
12.03.25	23,60	2.242	95,00	---	---	---	20:07	198,71	21,42
13.03.25	24,00	2.255	93,96	---	---	---	22:23	198,42	21,70
14.03.25	23,28	2.165	92,99	---	---	---	23:15	198,08	22,04
15.03.25	23,07	2.142	92,86	---	---	---	3:27	198,10	22,03
16.03.25	18,50	1.737	93,90	22:22	200,79	19,33	0:01	198,03	22,09
17.03.25	9,45	875	92,61	5:23	200,89	19,24	13:32	198,44	21,68
18.03.25	15,07	1.409	93,50	6:03	200,90	19,22	17:30	198,37	21,75
19.03.25	14,71	1.379	93,75	18:11	201,30	18,83	1:20	198,50	21,62
20.03.25	22,13	2.077	93,87	5:29	201,53	18,59	23:51	198,56	21,56
21.03.25	18,60	1.733	93,16	10:52	200,83	19,29	5:25	198,48	21,65
22.03.25	19,39	1.815	93,59	5:56	201,07	19,05	1:56	198,56	21,56
23.03.25	22,76	2.143	94,17	---	---	---	22:44	198,43	21,69
24.03.25	20,90	1.929	92,30	19:57	200,61	19,51	16:56	198,10	22,02
25.03.25	21,33	1.992	93,38	10:52	201,06	19,06	0:48	198,23	21,89
26.03.25	24,00	2.232	93,00	---	---	---	21:44	198,06	22,06
27.03.25	19,45	1.795	92,28	13:18	201,18	18,95	4:08	198,01	22,11
28.03.25	24,00	2.226	92,75	---	---	---	21:51	198,07	22,05
29.03.25	14,39	1.347	93,60	22:12	200,77	19,35	3:02	198,07	22,05
30.03.25	3,67	343	93,46	21:59	201,08	19,04	12:03	198,67	21,46
31.03.25	9,26	860	92,86	7:33	201,16	18,96	23:23	198,55	21,57
Σ	629,13	59.042							
Mittelwert	20,29	1.905	93,85		201,01	19,11		198,35	21,77
Minimum	3,67	343	92,28		200,61	18,59		198,01	21,17
Maximum	24,00	2.323	96,79		201,53	19,51		198,95	22,11

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.25	23,63	2.395	101,34	---	---	---	21:52	198,41	22,97
02.03.25	23,33	2.410	103,32	---	---	---	2:36	198,50	22,88
03.03.25	24,00	2.430	101,25	---	---	---	21:54	198,53	22,85
04.03.25	22,61	2.214	97,93	9:47	202,64	18,75	22:23	198,38	23,00
05.03.25	22,23	2.199	98,91	---	---	---	13:28	198,24	23,14
06.03.25	24,00	2.487	103,63	---	---	---	10:10	198,10	23,28
07.03.25	22,93	2.487	108,44	---	---	---	0:00	198,85	22,53
08.03.25	24,00	2.612	108,83	---	---	---	3:42	199,28	22,11
09.03.25	24,00	2.722	113,42	---	---	---	0:20	199,51	21,88
10.03.25	20,57	2.279	110,78	15:47	204,17	17,21	1:35	199,88	21,50
11.03.25	24,00	2.635	109,79	---	---	---	23:58	199,74	21,64
12.03.25	23,66	2.573	108,76	---	---	---	22:54	199,65	21,73
13.03.25	24,00	2.533	105,54	---	---	---	22:29	199,19	22,19
14.03.25	22,98	2.336	101,67	---	---	---	23:29	198,61	22,77
15.03.25	23,12	2.317	100,20	---	---	---	3:38	198,60	22,79
16.03.25	18,61	1.918	103,04	22:21	203,06	18,33	0:18	198,46	22,92
17.03.25	14,21	1.460	102,77	5:25	203,28	18,10	16:34	198,93	22,45
18.03.25	12,84	1.318	102,63	6:11	203,26	18,12	8:44	199,47	21,91
19.03.25	15,01	1.556	103,65	7:56	203,41	17,97	23:52	199,38	22,00
20.03.25	22,24	2.266	101,91	---	---	---	14:25	199,12	22,27
21.03.25	18,92	1.934	102,20	23:54	202,93	18,45	5:52	199,08	22,30
22.03.25	19,54	1.997	102,19	5:52	203,32	18,06	22:34	198,99	22,40
23.03.25	22,88	2.366	103,43	---	---	---	22:58	198,79	22,60
24.03.25	24,00	2.330	97,08	---	---	---	19:28	198,08	23,30
25.03.25	21,30	2.161	101,46	10:51	203,10	18,28	1:07	198,18	23,21
26.03.25	24,00	2.429	101,21	---	---	---	23:23	198,71	22,67
27.03.25	19,51	1.909	97,85	13:22	203,35	18,03	8:53	198,38	23,00
28.03.25	24,00	2.361	98,38	---	---	---	22:08	198,15	23,24
29.03.25	14,52	1.469	101,19	22:09	203,03	18,36	3:23	198,10	23,28
30.03.25	3,85	401	104,21	22:11	203,58	17,81	12:03	199,82	21,56
31.03.25	9,33	972	104,24	9:45	203,71	17,67	23:26	199,79	21,59
Σ	633,81	65.476							
Mittelwert	20,45	2.112	103,31		203,29	18,09		198,87	22,51
Minimum	3,85	401	97,08		202,64	17,21		198,08	21,50
Maximum	24,00	2.722	113,42		204,17	18,75		199,88	23,30

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	9,30	848	91,14	9:53	203,95	21,89	21:38	199,31	26,53
02.03.25	6,75	619	91,65	11:17	204,21	21,63	2:08	199,52	26,32
03.03.25	9,93	909	91,54	10:26	204,09	21,76	20:27	199,56	26,28
04.03.25	14,07	1.286	91,41	9:48	204,19	21,65	23:59	199,31	26,53
05.03.25	12,00	1.093	91,05	15:39	203,93	21,92	0:00	199,25	26,59
06.03.25	13,14	1.246	94,85	---	---	---	10:00	199,36	26,48
07.03.25	9,57	922	96,36	8:48	205,58	20,26	20:17	200,47	25,37
08.03.25	12,18	1.184	97,18	22:36	205,66	20,18	3:27	200,96	24,88
09.03.25	5,23	510	97,47	18:30	206,44	19,40	0:06	201,23	24,61
10.03.25	10,57	1.031	97,50	16:13	206,43	19,41	13:46	201,47	24,38
11.03.25	12,23	1.190	97,32	5:59	206,44	19,40	23:54	201,26	24,58
12.03.25	14,03	1.363	97,18	7:40	206,11	19,73	22:42	201,14	24,70
13.03.25	15,43	1.478	95,79	7:29	206,02	19,82	22:22	200,05	25,80
14.03.25	16,67	1.572	94,29	8:41	204,57	21,27	23:15	199,42	26,42
15.03.25	14,04	1.302	92,71	11:07	204,35	21,50	3:26	199,45	26,39
16.03.25	13,04	1.250	95,83	8:43	203,99	21,85	0:01	199,31	26,53
17.03.25	23,61	2.297	97,31	---	---	---	16:20	199,89	25,95
18.03.25	22,03	2.141	97,16	10:13	204,88	20,96	21:47	200,13	25,71
19.03.25	24,00	2.336	97,33	---	---	---	23:56	200,01	25,83
20.03.25	24,00	2.294	95,58	---	---	---	23:25	199,82	26,03
21.03.25	24,00	2.318	96,58	---	---	---	0:00	199,85	26,00
22.03.25	17,53	1.674	95,50	14:04	204,19	21,65	21:57	199,84	26,00
23.03.25	7,56	692	91,55	11:20	204,43	21,41	22:43	199,72	26,13
24.03.25	16,05	1.461	91,04	2:45	203,88	21,96	19:06	199,05	26,80
25.03.25	16,09	1.529	95,06	10:53	204,80	21,04	0:48	199,11	26,74
26.03.25	24,00	2.301	95,88	---	---	---	22:59	199,83	26,01
27.03.25	14,40	1.330	92,35	13:19	204,92	20,92	19:32	199,52	26,32
28.03.25	13,17	1.196	90,83	4:32	203,73	22,12	21:51	199,11	26,74
29.03.25	15,69	1.516	96,64	11:53	203,67	22,17	3:02	199,12	26,72
30.03.25	22,58	2.240	99,21	---	---	---	0:00	200,27	25,57
31.03.25	23,49	2.315	98,53	---	---	---	23:30	200,42	25,42
Σ	476,39	45.443							
Mittelwert	15,37	1.466	95,39		204,80	21,04		199,89	25,95
Minimum	5,23	510	90,83		203,67	19,40		199,05	24,38
Maximum	24,00	2.336	99,21		206,44	22,17		201,47	26,80

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	24,00	2.477	103,21	---	---	---	22:00	194,12	37,29
02.03.25	24,00	2.512	104,67	---	---	---	2:25	194,31	37,11
03.03.25	24,00	2.473	103,04	---	---	---	21:55	194,32	37,09
04.03.25	22,66	2.280	100,62	9:48	204,20	27,22	22:22	194,20	37,21
05.03.25	23,58	2.402	101,88	---	---	---	13:42	193,99	37,43
06.03.25	8,24	842	102,17	23:57	205,54	25,87	0:00	194,20	37,21
07.03.25	4,16	437	105,17	11:19	206,41	25,01	18:49	196,06	35,35
08.03.25	0,36	36	99,31	22:42	206,46	24,96	---	---	---
09.03.25	0,27	26	96,99	18:32	207,29	24,12	---	---	---
10.03.25	0,82	81	98,91	8:35	207,26	24,15	---	---	---
11.03.25	0,50	51	102,80	6:01	207,23	24,18	---	---	---
12.03.25	0,00	0	---	7:54	206,84	24,58	---	---	---
13.03.25	14,43	1.526	105,76	7:37	206,76	24,65	22:36	195,10	36,31
14.03.25	24,00	2.520	105,00	---	---	---	23:23	194,51	36,91
15.03.25	24,00	2.470	102,92	---	---	---	3:41	194,54	36,88
16.03.25	15,42	1.608	104,29	23:00	205,02	26,39	0:18	194,23	37,18
17.03.25	2,50	244	97,63	8:26	205,25	26,16	12:23	196,41	35,00
18.03.25	3,97	397	99,92	9:58	205,36	26,06	11:44	196,25	35,17
19.03.25	1,84	181	98,18	7:57	205,28	26,13	22:11	196,52	34,89
20.03.25	4,36	426	97,69	5:46	204,99	26,42	9:48	196,11	35,31
21.03.25	0,00	0	---	23:54	204,95	26,47	---	---	---
22.03.25	12,48	1.280	102,58	6:07	205,30	26,12	22:25	194,75	36,66
23.03.25	24,00	2.510	104,58	---	---	---	23:11	194,60	36,82
24.03.25	24,00	2.394	99,75	---	---	---	19:23	193,88	37,53
25.03.25	8,30	853	102,83	10:53	205,05	26,36	1:10	193,96	37,46
26.03.25	0,00	0	---	0:00	204,72	26,70	---	---	---
27.03.25	18,06	1.832	101,42	11:26	205,11	26,30	19:53	194,43	36,99
28.03.25	24,00	2.426	101,08	---	---	---	22:17	193,97	37,44
29.03.25	12,60	1.302	103,34	23:59	204,93	26,49	3:17	194,00	37,41
30.03.25	0,00	0	---	22:03	205,45	25,97	---	---	---
31.03.25	0,00	0	---	7:38	205,62	25,80	---	---	---
Σ	346,54	35.586							
Mittelwert	11,18	1.148	102,69		205,68	25,73		194,75	36,66
Minimum	0,00	0	96,99		204,20	24,12		193,88	34,89
Maximum	24,00	2.520	105,76		207,29	27,22		196,52	37,53

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	8,90	771	86,61	9:57	212,12	19,94	21:37	204,70	27,35
02.03.25	6,40	556	86,83	11:20	212,53	19,52	2:06	205,50	26,56
03.03.25	9,19	795	86,55	10:37	212,33	19,72	20:23	205,43	26,62
04.03.25	13,17	1.138	86,42	12:34	211,89	20,17	23:57	204,64	27,42
05.03.25	11,28	975	86,47	8:06	211,66	20,40	23:29	204,72	27,34
06.03.25	12,13	1.092	90,06	3:14	211,14	20,92	9:57	204,55	27,51
07.03.25	8,80	805	91,45	8:53	212,78	19,28	16:04	205,86	26,19
08.03.25	11,58	1.070	92,42	22:40	212,65	19,40	18:22	205,59	26,47
09.03.25	4,90	454	92,74	18:31	213,97	18,09	0:04	206,27	25,78
10.03.25	10,12	941	92,97	8:35	213,76	18,30	13:44	205,72	26,33
11.03.25	11,61	1.076	92,68	6:06	213,69	18,36	23:51	205,36	26,70
12.03.25	13,54	1.255	92,70	7:48	212,97	19,08	19:53	205,22	26,84
13.03.25	4,52	418	92,51	19:09	213,25	18,81	9:14	206,35	25,70
14.03.25	0,00	0	---	8:50	213,20	18,85	---	---	---
15.03.25	7,52	648	86,22	11:11	213,05	19,00	23:58	204,64	27,42
16.03.25	12,73	1.154	90,64	8:52	212,19	19,86	22:19	204,09	27,97
17.03.25	23,54	2.144	91,07	---	---	---	23:38	203,66	28,40
18.03.25	20,95	1.913	91,30	10:43	211,46	20,60	0:00	203,66	28,40
19.03.25	24,00	2.195	91,46	---	---	---	23:57	203,63	28,43
20.03.25	24,00	2.163	90,13	---	---	---	0:37	203,58	28,47
21.03.25	24,00	2.187	91,13	---	---	---	6:22	203,51	28,55
22.03.25	17,15	1.538	89,66	23:11	211,31	20,75	0:00	203,74	28,32
23.03.25	7,11	621	87,34	11:54	212,56	19,49	22:42	205,48	26,57
24.03.25	15,60	1.348	86,41	2:51	211,58	20,47	16:54	204,32	27,74
25.03.25	15,88	1.431	90,12	10:53	212,12	19,94	23:23	203,87	28,18
26.03.25	24,00	2.175	90,63	---	---	---	22:59	203,60	28,46
27.03.25	14,14	1.234	87,25	13:30	212,33	19,72	3:19	203,61	28,44
28.03.25	12,64	1.090	86,23	8:43	211,51	20,55	18:07	204,46	27,60
29.03.25	15,46	1.410	91,21	12:02	211,98	20,07	23:59	203,64	28,41
30.03.25	22,52	2.074	92,11	---	---	---	4:10	203,63	28,43
31.03.25	23,40	2.155	92,10	---	---	---	23:51	203,71	28,35
Σ	430,77	38.826							
Mittelwert	13,90	1.252	90,13		212,42	19,63		204,55	27,50
Minimum	0,00	0	86,22		211,14	18,09		203,51	25,70
Maximum	24,00	2.195	92,97		213,97	20,92		206,35	28,55

Meßpunkthöhe (MP): 232,05 m üNN