

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	24,00	1.228	51,17	---	---	---	0:09	194,16	15,60
02.03.25	24,00	1.231	51,29	---	---	---	0:00	194,21	15,55
03.03.25	24,00	1.228	51,17	---	---	---	7:26	194,29	15,48
04.03.25	21,49	1.094	50,91	9:40	195,98	13,78	0:12	194,33	15,43
05.03.25	24,00	1.226	51,08	---	---	---	5:46	194,29	15,48
06.03.25	24,00	1.208	50,33	---	---	---	23:38	193,90	15,87
07.03.25	24,00	1.194	49,75	---	---	---	20:30	193,66	16,10
08.03.25	24,00	1.194	49,75	---	---	---	21:44	193,64	16,12
09.03.25	24,00	1.202	50,08	---	---	---	1:55	193,64	16,12
10.03.25	24,00	1.195	49,79	---	---	---	15:18	193,61	16,15
11.03.25	22,63	1.122	49,57	10:15	195,20	14,56	23:56	193,58	16,18
12.03.25	24,00	1.189	49,54	---	---	---	23:46	193,52	16,24
13.03.25	24,00	1.203	50,13	---	---	---	1:41	193,52	16,24
14.03.25	21,63	1.095	50,62	12:14	195,67	14,09	6:00	193,93	15,84
15.03.25	24,00	1.224	51,00	---	---	---	7:25	193,99	15,77
16.03.25	24,00	1.221	50,88	---	---	---	21:52	193,96	15,81
17.03.25	24,00	1.201	50,04	---	---	---	16:42	193,69	16,07
18.03.25	24,00	1.194	49,75	---	---	---	22:58	193,57	16,19
19.03.25	24,00	1.188	49,50	---	---	---	23:57	193,50	16,26
20.03.25	24,00	1.184	49,33	---	---	---	14:39	193,38	16,39
21.03.25	24,00	1.199	49,96	---	---	---	23:37	193,58	16,18
22.03.25	24,00	1.206	50,25	---	---	---	3:51	193,57	16,19
23.03.25	24,00	1.226	51,08	---	---	---	0:36	193,93	15,84
24.03.25	24,00	1.213	50,54	---	---	---	22:36	194,03	15,73
25.03.25	24,00	1.203	50,13	---	---	---	21:18	193,71	16,06
26.03.25	24,00	1.211	50,46	---	---	---	1:13	193,71	16,06
27.03.25	21,50	1.087	50,55	11:18	195,93	13,83	0:55	193,87	15,90
28.03.25	24,00	1.221	50,88	---	---	---	8:01	194,15	15,61
29.03.25	24,00	1.219	50,79	---	---	---	23:57	193,93	15,84
30.03.25	23,00	1.161	50,48	---	---	---	14:12	193,88	15,88
31.03.25	24,00	1.199	49,96	---	---	---	23:51	193,66	16,10
Σ	734,25	36.966							
Mittelwert	23,69	1.192	50,35		195,70	14,06		193,82	15,94
Minimum	21,49	1.087	49,33		195,20	13,78		193,38	15,43
Maximum	24,00	1.231	51,29		195,98	14,56		194,33	16,39

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	0,00	0	---	10:03	199,45	8,37	---	---	---
02.03.25	0,00	0	---	9:39	199,68	8,14	---	---	---
03.03.25	0,35	77	220,00	6:07	199,54	8,28	---	---	---
04.03.25	2,39	542	226,80	13:10	199,99	7,83	10:50	192,55	15,27
05.03.25	0,00	0	---	14:11	199,92	7,90	---	---	---
06.03.25	15,75	3.678	233,49	6:15	199,53	8,29	22:53	192,35	15,48
07.03.25	24,00	5.572	232,17	---	---	---	18:52	191,70	16,12
08.03.25	24,00	5.579	232,46	---	---	---	9:54	192,00	15,83
09.03.25	24,00	5.616	234,00	---	---	---	0:39	192,04	15,78
10.03.25	24,00	5.579	232,46	---	---	---	15:20	191,86	15,96
11.03.25	24,00	5.547	231,13	---	---	---	10:36	191,30	16,52
12.03.25	24,00	5.556	231,50	---	---	---	6:16	191,74	16,08
13.03.25	9,59	2.219	231,50	23:38	198,85	8,97	1:28	191,83	16,00
14.03.25	1,96	437	222,55	9:08	199,20	8,62	11:16	192,35	15,47
15.03.25	0,00	0	---	23:47	199,32	8,50	---	---	---
16.03.25	8,58	2.025	236,13	8:57	199,37	8,45	19:21	192,93	14,89
17.03.25	24,00	5.632	234,67	---	---	---	16:32	192,09	15,74
18.03.25	23,52	5.480	233,02	---	---	---	21:20	191,84	15,98
19.03.25	24,00	5.560	231,67	---	---	---	22:14	191,66	16,16
20.03.25	14,47	3.299	228,01	22:14	199,45	8,37	9:53	191,34	16,48
21.03.25	17,65	4.106	232,59	6:18	199,92	7,90	22:48	191,87	15,96
22.03.25	10,74	2.499	232,59	23:38	198,89	8,93	2:15	191,94	15,88
23.03.25	0,00	0	---	11:11	199,47	8,35	---	---	---
24.03.25	0,00	0	---	5:46	199,24	8,58	---	---	---
25.03.25	11,68	2.683	229,72	4:52	199,20	8,62	20:59	192,38	15,44
26.03.25	11,88	2.746	231,16	7:55	199,56	8,26	0:59	192,39	15,43
27.03.25	3,60	819	227,64	11:29	200,34	7,48	3:03	192,91	14,91
28.03.25	0,00	0	---	11:23	199,30	8,52	---	---	---
29.03.25	11,40	2.709	237,72	12:12	199,34	8,48	23:22	192,93	14,90
30.03.25	23,00	5.454	237,13	---	---	---	12:23	192,76	15,06
31.03.25	24,00	5.647	235,29	---	---	---	23:39	192,16	15,66
Σ	382,55	89.061							
Mittelwert	12,34	2.873	232,81		199,48	8,34		192,13	15,69
Minimum	0,00	0	220,00		198,85	7,48		191,30	14,89
Maximum	24,00	5.647	237,72		200,34	8,97		192,93	16,52

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	24,00	3.470	144,58	---	---	---	0:20	190,15	22,69
02.03.25	24,00	3.482	145,08	---	---	---	0:00	190,30	22,53
03.03.25	24,00	3.471	144,63	---	---	---	6:29	190,21	22,63
04.03.25	22,50	3.221	143,18	13:08	194,83	18,01	10:52	189,35	23,48
05.03.25	23,55	3.397	144,26	---	---	---	4:57	190,21	22,63
06.03.25	8,24	1.188	144,11	9:13	193,70	19,14	1:23	190,44	22,40
07.03.25	3,39	463	136,49	8:20	193,38	19,46	18:46	188,69	24,14
08.03.25	0,33	43	129,65	5:46	192,66	20,18	---	---	---
09.03.25	0,24	31	130,07	18:55	192,81	20,02	---	---	---
10.03.25	0,79	104	132,11	15:55	192,95	19,89	---	---	---
11.03.25	2,82	385	136,51	7:41	192,73	20,10	10:23	188,48	24,35
12.03.25	0,00	0	---	6:37	192,66	20,18	---	---	---
13.03.25	14,40	2.057	142,89	8:20	192,49	20,34	10:52	189,29	23,54
14.03.25	24,00	3.424	142,67	---	---	---	11:17	189,04	23,79
15.03.25	24,00	3.464	144,33	---	---	---	0:00	189,83	23,01
16.03.25	15,42	2.233	144,82	22:34	194,14	18,69	3:43	190,30	22,53
17.03.25	0,54	73	134,22	5:27	194,03	18,80	---	---	---
18.03.25	3,70	503	135,80	9:12	193,62	19,21	10:16	189,38	23,45
19.03.25	1,78	236	132,79	8:03	193,52	19,32	22:10	188,74	24,10
20.03.25	4,23	571	134,86	22:07	193,94	18,89	9:42	188,40	24,43
21.03.25	0,00	0	---	6:19	194,54	18,30	---	---	---
22.03.25	13,34	1.910	143,22	6:04	193,39	19,44	13:10	189,40	23,44
23.03.25	24,00	3.471	144,63	---	---	---	0:21	189,84	22,99
24.03.25	24,00	3.446	143,58	---	---	---	19:47	190,03	22,81
25.03.25	10,97	1.563	142,49	17:14	193,79	19,05	10:52	189,25	23,59
26.03.25	0,00	0	---	7:53	194,13	18,71	---	---	---
27.03.25	17,85	2.562	143,51	11:27	195,23	17,61	8:55	189,20	23,64
28.03.25	24,00	3.459	144,13	---	---	---	22:09	190,18	22,66
29.03.25	12,60	1.820	144,46	19:16	194,27	18,57	0:08	190,19	22,64
30.03.25	0,00	0	---	5:08	194,16	18,68	---	---	---
31.03.25	0,00	0	---	5:52	194,07	18,77	---	---	---
Σ	348,69	50.047							
Mittelwert	11,25	1.614	143,53		193,68	19,15		189,58	23,25
Minimum	0,00	0	129,65		192,49	17,61		188,40	22,40
Maximum	24,00	3.482	145,08		195,23	20,34		190,44	24,43

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.03.25	23,60	4.604	195,07	---	---	---	0:17	177,92	32,20
02.03.25	23,30	4.566	196,00	---	---	---	2:25	178,12	32,00
03.03.25	24,00	4.684	195,17	---	---	---	20:44	178,10	32,01
04.03.25	22,56	4.347	192,72	13:06	194,07	16,04	19:42	177,89	32,23
05.03.25	22,11	4.291	194,04	---	---	---	0:14	177,87	32,24
06.03.25	24,00	4.603	191,79	---	---	---	22:18	177,97	32,15
07.03.25	22,88	4.328	189,20	---	---	---	20:27	177,60	32,52
08.03.25	24,00	4.550	189,58	---	---	---	18:34	177,57	32,55
09.03.25	24,00	4.587	191,13	---	---	---	0:27	177,65	32,47
10.03.25	23,32	4.416	189,40	---	---	---	14:00	177,45	32,67
11.03.25	23,48	4.416	188,11	---	---	---	23:58	177,37	32,74
12.03.25	23,63	4.451	188,37	---	---	---	22:56	177,29	32,82
13.03.25	24,00	4.570	190,42	---	---	---	10:55	177,00	33,11
14.03.25	23,35	4.462	191,11	---	---	---	2:39	177,26	32,85
15.03.25	23,09	4.483	194,14	---	---	---	0:00	177,39	32,73
16.03.25	18,56	3.601	194,01	22:22	194,20	15,92	13:01	177,83	32,29
17.03.25	9,64	1.806	187,39	5:27	194,07	16,04	13:41	178,33	31,78
18.03.25	10,99	2.050	186,53	9:05	193,55	16,56	21:43	177,89	32,23
19.03.25	14,90	2.769	185,80	7:47	193,45	16,67	23:54	177,72	32,39
20.03.25	22,15	4.140	186,95	---	---	---	14:27	177,14	32,97
21.03.25	18,79	3.549	188,86	6:56	193,51	16,61	22:40	177,87	32,24
22.03.25	19,44	3.717	191,18	5:59	193,30	16,82	13:10	177,22	32,90
23.03.25	22,82	4.448	194,92	---	---	---	0:35	177,60	32,52
24.03.25	24,00	4.635	193,13	---	---	---	21:56	177,65	32,47
25.03.25	23,75	4.532	190,79	---	---	---	21:14	177,19	32,93
26.03.25	24,00	4.617	192,38	---	---	---	1:17	177,16	32,96
27.03.25	19,24	3.696	192,14	13:19	195,05	15,07	1:00	177,34	32,77
28.03.25	24,00	4.651	193,79	---	---	---	21:58	177,69	32,42
29.03.25	14,49	2.806	193,62	18:46	194,38	15,74	3:26	177,68	32,44
30.03.25	3,76	711	188,97	5:34	194,23	15,89	12:04	178,99	31,13
31.03.25	9,18	1.728	188,17	10:10	194,13	15,98	23:27	178,21	31,91
Σ	631,02	120.814							
Mittelwert	20,36	3.897	191,46		193,99	16,12		177,67	32,44
Minimum	3,76	711	185,80		193,30	15,07		177,00	31,13
Maximum	24,00	4.684	196,00		195,05	16,82		178,99	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.03.25	9,19	1.114	121,16	9:48	195,23	19,54	21:38	184,85	29,92
02.03.25	6,66	811	121,84	9:36	195,59	19,19	2:07	185,28	29,49
03.03.25	9,75	1.177	120,70	10:29	195,37	19,40	20:24	185,33	29,45
04.03.25	16,99	2.043	120,24	---	---	---	11:52	184,53	30,24
05.03.25	11,82	1.422	120,32	15:32	195,28	19,49	0:00	184,76	30,01
06.03.25	12,88	1.532	118,95	3:13	194,82	19,95	11:41	184,98	29,80
07.03.25	9,37	1.101	117,53	8:36	194,33	20,44	20:15	184,30	30,47
08.03.25	12,03	1.422	118,23	7:12	193,65	21,13	18:21	183,98	30,79
09.03.25	5,14	608	118,27	18:01	194,14	20,64	0:03	184,26	30,52
10.03.25	10,47	1.233	117,82	5:12	194,04	20,73	13:40	183,98	30,79
11.03.25	13,80	1.623	117,61	5:53	193,95	20,82	23:50	183,65	31,13
12.03.25	13,89	1.638	117,94	7:48	193,66	21,11	19:52	183,65	31,13
13.03.25	15,32	1.831	119,52	17:04	193,69	21,08	10:24	183,68	31,10
14.03.25	16,63	1.994	119,93	8:37	194,81	19,97	14:59	184,16	30,61
15.03.25	7,60	918	120,74	10:54	195,02	19,75	3:21	184,38	30,40
16.03.25	12,92	1.569	121,41	8:48	195,17	19,60	23:57	184,70	30,08
17.03.25	23,59	2.835	120,20	---	---	---	13:53	183,78	30,99
18.03.25	24,00	2.865	119,38	---	---	---	21:54	183,42	31,36
19.03.25	24,00	2.850	118,75	---	---	---	23:58	183,14	31,63
20.03.25	23,64	2.786	117,86	---	---	---	16:00	183,07	31,71
21.03.25	24,00	2.859	119,13	---	---	---	22:46	183,10	31,68
22.03.25	17,43	2.080	119,30	23:09	194,01	20,76	2:10	183,19	31,59
23.03.25	7,44	900	120,89	11:11	195,23	19,54	0:14	184,64	30,14
24.03.25	15,94	1.927	120,92	2:50	194,70	20,07	16:41	184,58	30,20
25.03.25	18,73	2.238	119,47	4:38	194,87	19,91	21:37	183,51	31,27
26.03.25	24,00	2.901	120,88	---	---	---	1:38	183,45	31,33
27.03.25	14,33	1.727	120,51	13:23	195,72	19,05	1:29	183,69	31,08
28.03.25	13,04	1.576	120,82	8:42	194,81	19,97	18:01	184,75	30,03
29.03.25	15,62	1.901	121,67	12:02	195,16	19,62	23:19	184,50	30,27
30.03.25	22,57	2.738	121,33	---	---	---	23:52	184,24	30,53
31.03.25	23,51	2.831	120,41	---	---	---	23:34	183,63	31,14
Σ	476,30	57.050							
Mittelwert	15,36	1.840	119,78		194,69	20,08		184,10	30,67
Minimum	5,14	608	117,53		193,65	19,05		183,07	29,45
Maximum	24,00	2.901	121,84		195,72	21,13		185,33	31,71

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	9,39	552	58,79	9:54	197,12	16,16	21:39	191,27	22,01
02.03.25	6,84	405	59,17	11:29	197,45	15,83	2:08	191,66	21,62
03.03.25	10,11	599	59,23	10:23	197,32	15,96	20:28	191,72	21,56
04.03.25	16,67	959	57,53	---	---	---	12:34	190,04	23,24
05.03.25	12,17	709	58,26	7:59	197,00	16,28	12:34	190,94	22,34
06.03.25	13,35	758	56,77	---	---	---	16:55	190,23	23,05
07.03.25	9,74	535	54,94	8:48	194,96	18,32	16:06	189,68	23,60
08.03.25	12,31	676	54,92	0:07	194,43	18,85	18:24	189,28	24,00
09.03.25	5,32	292	54,93	18:04	194,88	18,40	0:07	189,52	23,76
10.03.25	10,66	582	54,59	5:01	194,77	18,51	13:47	189,30	23,98
11.03.25	14,53	787	54,16	6:06	194,68	18,60	23:54	188,92	24,36
12.03.25	14,13	766	54,20	7:47	194,28	19,00	20:07	188,92	24,36
13.03.25	15,53	876	56,39	17:03	195,30	17,98	9:40	189,10	24,18
14.03.25	16,72	952	56,93	8:44	196,54	16,74	11:39	190,31	22,97
15.03.25	14,10	833	59,06	10:59	196,85	16,43	3:27	190,67	22,61
16.03.25	13,12	758	57,78	8:46	197,09	16,19	22:13	189,92	23,36
17.03.25	23,62	1.315	55,68	---	---	---	23:41	189,00	24,28
18.03.25	24,00	1.318	54,92	---	---	---	22:44	188,70	24,58
19.03.25	24,00	1.301	54,21	---	---	---	23:58	188,54	24,74
20.03.25	24,00	1.283	53,46	---	---	---	22:10	188,22	25,06
21.03.25	24,00	1.302	54,25	---	---	---	6:02	188,05	25,23
22.03.25	17,62	975	55,32	23:07	195,63	17,65	3:48	188,30	24,98
23.03.25	7,66	449	58,63	11:56	196,85	16,43	0:16	190,74	22,54
24.03.25	16,15	939	58,15	2:47	196,54	16,74	16:56	190,91	22,37
25.03.25	18,80	1.051	55,91	4:40	196,75	16,53	21:10	189,14	24,14
26.03.25	24,00	1.364	56,83	---	---	---	1:09	189,07	24,21
27.03.25	14,46	823	56,93	11:41	196,62	16,66	0:49	189,40	23,88
28.03.25	13,29	776	58,41	8:41	196,67	16,61	0:14	191,04	22,24
29.03.25	15,73	909	57,77	11:49	197,07	16,21	23:56	189,73	23,55
30.03.25	22,59	1.276	56,47	---	---	---	14:14	189,42	23,86
31.03.25	23,55	1.310	55,63	---	---	---	23:53	188,94	24,34
Σ	488,16	27.430							
Mittelwert	15,75	885	56,19		196,13	17,15		189,70	23,58
Minimum	5,32	292	53,46		194,28	15,83		188,05	21,56
Maximum	24,00	1.364	59,23		197,45	19,00		191,72	25,23

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	0,00	0	---	9:40	202,72	14,08	---	---	---
02.03.25	0,00	0	---	11:26	202,92	13,88	---	---	---
03.03.25	0,37	39	105,48	10:41	202,92	13,88	---	---	---
04.03.25	4,93	534	108,22	8:30	202,82	13,98	12:27	195,01	21,79
05.03.25	2,07	222	107,46	8:07	202,76	14,04	11:35	196,14	20,66
06.03.25	16,08	1.754	109,05	5:49	202,74	14,06	22:20	194,50	22,30
07.03.25	24,00	2.601	108,38	---	---	---	7:13	194,15	22,65
08.03.25	24,00	2.601	108,38	---	---	---	22:12	194,03	22,77
09.03.25	24,00	2.621	109,21	---	---	---	0:17	194,16	22,64
10.03.25	24,00	2.601	108,38	---	---	---	15:25	193,89	22,91
11.03.25	23,27	2.505	107,67	---	---	---	23:55	193,89	22,91
12.03.25	24,00	2.585	107,71	---	---	---	6:22	193,74	23,06
13.03.25	9,56	1.031	107,84	23:23	201,86	14,94	1:15	193,88	22,92
14.03.25	1,99	208	104,64	8:39	202,34	14,46	11:14	195,60	21,20
15.03.25	0,00	0	---	11:10	202,55	14,25	---	---	---
16.03.25	8,62	956	110,87	8:58	202,74	14,06	22:25	194,46	22,34
17.03.25	24,00	2.625	109,38	---	---	---	23:37	193,81	22,99
18.03.25	24,00	2.604	108,50	---	---	---	23:15	193,62	23,18
19.03.25	24,00	2.581	107,54	---	---	---	18:03	193,59	23,21
20.03.25	24,00	2.553	106,38	---	---	---	5:15	193,48	23,32
21.03.25	24,00	2.581	107,54	---	---	---	6:14	193,21	23,59
22.03.25	11,37	1.224	107,66	23:19	201,83	14,97	3:49	193,27	23,53
23.03.25	0,00	0	---	11:59	202,47	14,33	---	---	---
24.03.25	0,00	0	---	5:24	202,43	14,37	---	---	---
25.03.25	11,42	1.230	107,70	4:40	202,49	14,31	20:57	194,52	22,28
26.03.25	12,04	1.304	108,26	7:52	201,46	15,34	0:54	194,49	22,31
27.03.25	4,87	528	108,47	11:31	202,31	14,49	3:01	194,92	21,88
28.03.25	0,00	0	---	11:03	202,53	14,27	---	---	---
29.03.25	11,44	1.279	111,80	12:01	202,72	14,08	23:40	194,31	22,49
30.03.25	23,00	2.547	110,74	---	---	---	21:59	194,05	22,75
31.03.25	24,00	2.628	109,50	---	---	---	23:51	193,78	23,02
Σ	405,04	43.942							
Mittelwert	13,07	1.417	108,49		202,48	14,32		194,19	22,61
Minimum	0,00	0	104,64		201,46	13,88		193,21	20,66
Maximum	24,00	2.628	111,80		202,92	15,34		196,14	23,59

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	0,00	0	---	9:26	198,76	22,39	---	---	---
02.03.25	0,00	0	---	10:29	198,98	22,17	---	---	---
03.03.25	0,39	67	172,41	10:40	199,02	22,13	---	---	---
04.03.25	5,22	939	180,00	8:27	198,98	22,17	12:57	180,28	40,87
05.03.25	2,11	375	178,05	7:58	198,85	22,30	11:35	183,48	37,67
06.03.25	16,09	2.931	182,16	5:37	198,85	22,30	22:41	181,19	39,96
07.03.25	24,00	4.320	180,00	---	---	---	7:13	179,70	41,45
08.03.25	24,00	4.321	180,04	---	---	---	22:22	179,90	41,25
09.03.25	24,00	4.371	182,13	---	---	---	21:29	180,84	40,31
10.03.25	24,00	4.315	179,79	---	---	---	15:27	179,45	41,70
11.03.25	23,33	4.142	177,54	---	---	---	7:31	180,07	41,08
12.03.25	24,00	4.265	177,71	---	---	---	6:20	179,27	41,88
13.03.25	9,58	1.710	178,47	23:41	197,84	23,31	1:24	180,55	40,60
14.03.25	1,99	338	169,45	8:43	198,30	22,85	11:16	183,24	37,91
15.03.25	0,00	0	---	11:27	198,56	22,59	---	---	---
16.03.25	8,61	1.638	190,14	8:36	198,78	22,37	22:14	180,60	40,55
17.03.25	24,00	4.452	185,50	---	---	---	16:39	179,47	41,68
18.03.25	23,84	4.350	182,49	---	---	---	22:53	179,66	41,49
19.03.25	24,00	4.295	178,96	---	---	---	18:02	179,57	41,58
20.03.25	24,00	4.180	174,17	---	---	---	5:06	179,50	41,65
21.03.25	24,00	4.275	178,13	---	---	---	6:16	178,77	42,38
22.03.25	11,39	2.046	179,57	23:56	197,74	23,41	4:00	178,85	42,30
23.03.25	0,00	0	---	20:45	198,46	22,69	---	---	---
24.03.25	0,00	0	---	5:20	198,46	22,69	---	---	---
25.03.25	11,55	2.041	176,75	4:57	198,54	22,61	20:59	181,29	39,86
26.03.25	12,18	2.175	178,63	7:53	197,38	23,77	0:59	181,41	39,74
27.03.25	4,95	897	181,12	22:11	198,28	22,87	12:39	180,95	40,20
28.03.25	0,00	0	---	11:35	198,57	22,58	---	---	---
29.03.25	11,43	2.212	193,53	11:55	198,78	22,37	23:45	180,40	40,75
30.03.25	23,00	4.387	190,74	---	---	---	7:47	179,76	41,39
31.03.25	24,00	4.463	185,96	---	---	---	7:03	179,52	41,63
Σ	405,66	73.505							
Mittelwert	13,09	2.371	181,20		198,51	22,64		180,32	40,83
Minimum	0,00	0	169,45		197,38	22,13		178,77	37,67
Maximum	24,00	4.463	193,53		199,02	23,77		183,48	42,38

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Abtutung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.03.25	0,00	0	---	23:27	188,02	39,51	---	---	---
02.03.25	0,00	0	---	10:58	188,02	39,51	---	---	---
03.03.25	0,00	0	---	5:27	188,02	39,51	---	---	---
04.03.25	0,00	0	---	13:13	188,02	39,51	---	---	---
05.03.25	0,00	0	---	18:48	188,02	39,51	---	---	---
06.03.25	0,00	0	---	9:20	188,02	39,51	---	---	---
07.03.25	0,00	0	---	14:42	188,02	39,51	---	---	---
08.03.25	0,00	0	---	---	---	---	---	---	---
09.03.25	0,00	0	---	5:19	188,02	39,51	---	---	---
10.03.25	0,00	0	---	6:16	188,02	39,51	---	---	---
11.03.25	0,00	0	---	10:36	188,02	39,51	---	---	---
12.03.25	0,00	0	---	0:29	188,02	39,51	---	---	---
13.03.25	0,00	0	---	18:55	188,02	39,51	---	---	---
14.03.25	0,00	0	---	23:09	188,02	39,51	---	---	---
15.03.25	0,00	0	---	---	---	---	---	---	---
16.03.25	0,00	0	---	9:44	188,02	39,51	---	---	---
17.03.25	0,00	0	---	---	---	---	---	---	---
18.03.25	0,00	0	---	13:28	188,02	39,51	---	---	---
19.03.25	0,00	0	---	20:56	188,02	39,51	---	---	---
20.03.25	0,00	0	---	4:29	188,02	39,51	---	---	---
21.03.25	0,00	0	---	---	---	---	---	---	---
22.03.25	0,00	0	---	0:16	188,02	39,51	---	---	---
23.03.25	0,00	0	---	11:20	188,02	39,51	---	---	---
24.03.25	0,00	0	---	1:14	188,02	39,51	---	---	---
25.03.25	0,00	0	---	0:00	188,01	39,51	---	---	---
26.03.25	0,00	0	---	2:14	188,02	39,51	---	---	---
27.03.25	0,00	0	---	0:00	188,01	39,51	---	---	---
28.03.25	0,00	0	---	0:00	188,01	39,51	---	---	---
29.03.25	0,00	0	---	7:38	188,02	39,51	---	---	---
30.03.25	0,00	0	---	21:45	188,02	39,51	---	---	---
31.03.25	0,00	0	---	3:20	188,02	39,51	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,01	39,51		---	---
Minimum	0,00	0	---		188,01	39,51		---	---
Maximum	0,00	0	---		188,02	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.25	23,65	1.637	69,23	---	---	---	12:52	191,44	44,02
02.03.25	23,34	1.508	64,61	---	---	---	1:27	191,76	43,70
03.03.25	24,00	1.465	61,04	---	---	---	6:29	191,36	44,10
04.03.25	22,28	1.406	63,10	8:58	202,09	33,37	15:10	190,27	45,20
05.03.25	22,29	1.423	63,84	---	---	---	11:37	190,59	44,87
06.03.25	24,00	1.574	65,58	---	---	---	23:25	190,69	44,78
07.03.25	22,96	1.563	68,07	---	---	---	20:18	189,87	45,59
08.03.25	22,49	1.519	67,54	23:27	199,84	35,62	12:17	189,77	45,70
09.03.25	24,00	1.573	65,54	---	---	---	22:31	189,82	45,64
10.03.25	23,36	1.546	66,19	---	---	---	13:47	189,87	45,59
11.03.25	23,86	1.597	66,94	---	---	---	8:38	189,80	45,66
12.03.25	23,67	1.595	67,38	---	---	---	20:07	189,39	46,07
13.03.25	24,00	1.433	59,71	---	---	---	5:20	190,32	45,14
14.03.25	23,43	1.527	65,16	---	---	---	11:17	190,48	44,98
15.03.25	23,14	1.450	62,67	---	---	---	12:23	192,07	43,40
16.03.25	18,65	1.163	62,36	17:34	201,63	33,83	23:59	190,77	44,69
17.03.25	9,84	723	73,50	4:37	200,92	34,54	13:40	190,20	45,27
18.03.25	11,84	856	72,28	3:10	200,23	35,23	16:40	189,81	45,65
19.03.25	15,10	1.105	73,19	7:44	200,06	35,40	23:41	189,35	46,12
20.03.25	22,25	1.588	71,36	---	---	---	14:27	189,00	46,46
21.03.25	19,01	1.392	73,24	23:55	199,18	36,28	5:01	189,05	46,41
22.03.25	19,57	1.371	70,05	5:54	199,70	35,76	9:40	189,58	45,88
23.03.25	22,91	1.589	69,36	---	---	---	0:00	191,32	44,14
24.03.25	24,00	1.690	70,42	---	---	---	0:57	191,64	43,82
25.03.25	23,83	1.689	70,89	---	---	---	20:59	190,27	45,20
26.03.25	24,00	1.650	68,75	---	---	---	0:59	190,17	45,30
27.03.25	19,53	1.347	68,98	13:15	201,53	33,93	6:29	190,36	45,11
28.03.25	24,00	1.630	67,92	---	---	---	0:14	191,84	43,63
29.03.25	14,56	993	68,19	14:48	201,61	33,85	12:52	191,58	43,88
30.03.25	3,89	293	75,26	4:15	200,99	34,47	11:58	190,61	44,85
31.03.25	9,41	702	74,63	5:26	200,69	34,77	23:24	189,90	45,56
Σ	632,85	42.597							
Mittelwert	20,41	1.374	67,31		200,70	34,76		190,42	45,04
Minimum	3,89	293	59,71		199,18	33,37		189,00	43,40
Maximum	24,00	1.690	75,26		202,09	36,28		192,07	46,46

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom März 2025
gedruckt am: 03.04.2025, 01:33 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.03.25	24,00	4.030	167,92	---	---	---	0:03	193,31	51,51
02.03.25	24,00	4.036	168,17	---	---	---	0:00	193,35	51,48
03.03.25	24,00	4.029	167,88	---	---	---	22:16	193,44	51,38
04.03.25	21,92	3.682	167,95	9:11	196,84	47,99	17:04	193,25	51,57
05.03.25	23,67	3.980	168,13	---	---	---	0:00	193,27	51,55
06.03.25	8,29	1.386	167,18	16:01	197,18	47,64	0:00	193,39	51,43
07.03.25	3,38	571	168,92	10:23	197,22	47,60	20:04	193,47	51,35
08.03.25	0,46	78	170,91	23:19	197,19	47,63	---	---	---
09.03.25	0,37	62	169,86	17:07	197,36	47,46	---	---	---
10.03.25	0,91	154	168,56	8:21	197,38	47,44	---	---	---
11.03.25	1,92	326	169,45	5:49	197,35	47,47	10:34	193,78	51,04
12.03.25	0,00	0	---	13:46	197,27	47,55	---	---	---
13.03.25	14,47	2.435	168,24	7:30	197,26	47,57	22:44	193,31	51,51
14.03.25	24,00	4.018	167,42	---	---	---	22:16	193,22	51,60
15.03.25	24,00	4.036	168,17	---	---	---	3:12	193,22	51,60
16.03.25	15,47	2.603	168,32	20:40	197,13	47,69	0:02	193,39	51,43
17.03.25	0,65	111	171,43	0:08	197,13	47,69	---	---	---
18.03.25	1,76	300	170,32	7:37	197,01	47,81	---	---	---
19.03.25	1,99	335	168,06	18:07	196,97	47,85	22:11	193,72	51,10
20.03.25	4,74	791	166,80	3:38	196,87	47,96	9:49	193,39	51,43
21.03.25	0,00	0	---	21:36	196,93	47,90	---	---	---
22.03.25	13,48	2.272	168,53	7:42	197,03	47,80	14:24	193,16	51,66
23.03.25	24,00	4.052	168,83	---	---	---	0:28	193,28	51,54
24.03.25	24,00	4.050	168,75	---	---	---	19:06	193,24	51,58
25.03.25	11,11	1.871	168,44	18:52	197,03	47,79	10:57	193,15	51,68
26.03.25	0,00	0	---	16:36	197,19	47,63	---	---	---
27.03.25	18,21	3.091	169,75	2:21	197,22	47,60	8:56	193,36	51,46
28.03.25	24,00	4.041	168,38	---	---	---	1:40	193,36	51,46
29.03.25	12,65	2.114	167,17	20:23	197,18	47,64	0:24	193,39	51,43
30.03.25	0,00	0	---	15:22	197,21	47,61	---	---	---
31.03.25	0,00	0	---	0:00	197,19	47,63	---	---	---
Σ	347,45	58.454							
Mittelwert	11,21	1.886	168,24		197,14	47,68		193,35	51,47
Minimum	0,00	0	166,80		196,84	47,44		193,15	51,04
Maximum	24,00	4.052	171,43		197,38	47,99		193,78	51,68

Meßpunkthöhe (MP): 244,82 m üNN