

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB02
Monatsbericht vom April 2025
gedruckt am: 03.05.2025, 02:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.04.25	24,00	1.760	73,33	---	---	---	6:56	195,26	19,83
02.04.25	24,00	1.761	73,38	---	---	---	7:10	195,31	19,79
03.04.25	21,68	1.595	73,59	17:46	197,33	17,76	9:20	195,28	19,82
04.04.25	21,21	1.574	74,20	3:04	197,38	17,72	13:45	195,29	19,80
05.04.25	24,00	1.784	74,33	---	---	---	7:44	195,21	19,88
06.04.25	24,00	1.785	74,38	---	---	---	8:27	195,16	19,93
07.04.25	24,00	1.774	73,92	---	---	---	23:12	195,17	19,92
08.04.25	22,01	1.623	73,75	10:45	197,17	17,92	6:30	195,12	19,97
09.04.25	24,00	1.773	73,88	---	---	---	8:55	195,15	19,94
10.04.25	24,00	1.770	73,75	---	---	---	10:32	195,11	19,99
11.04.25	24,00	1.770	73,75	---	---	---	11:25	195,12	19,97
12.04.25	24,00	1.776	74,00	---	---	---	8:03	195,11	19,99
13.04.25	24,00	1.779	74,13	---	---	---	13:30	195,14	19,96
14.04.25	24,00	1.769	73,71	---	---	---	11:01	195,09	20,00
15.04.25	24,00	1.761	73,38	---	---	---	23:11	195,13	19,96
16.04.25	24,00	1.759	73,29	---	---	---	8:10	195,04	20,05
17.04.25	24,00	1.766	73,58	---	---	---	7:46	195,02	20,07
18.04.25	24,00	1.780	74,17	---	---	---	10:12	195,04	20,05
19.04.25	24,00	1.779	74,13	---	---	---	3:54	195,07	20,02
20.04.25	24,00	1.770	73,75	---	---	---	5:35	195,07	20,02
21.04.25	24,00	1.771	73,79	---	---	---	5:08	195,08	20,01
22.04.25	24,00	1.755	73,13	---	---	---	12:10	195,11	19,99
23.04.25	24,00	1.753	73,04	---	---	---	7:36	195,14	19,96
24.04.25	24,00	1.758	73,25	---	---	---	0:00	195,20	19,89
25.04.25	24,00	1.753	73,04	---	---	---	19:31	195,18	19,92
26.04.25	24,00	1.772	73,83	---	---	---	8:14	195,09	20,00
27.04.25	24,00	1.776	74,00	---	---	---	8:45	195,08	20,02
28.04.25	24,00	1.764	73,50	---	---	---	10:15	195,05	20,04
29.04.25	21,73	1.594	73,34	13:34	197,08	18,01	8:13	195,03	20,06
30.04.25	24,00	1.763	73,46	---	---	---	13:52	195,05	20,05
Σ	710,63	52.367							
Mittelwert	23,69	1.746	73,69		197,24	17,85		195,13	19,96
Minimum	21,21	1.574	73,04		197,08	17,72		195,02	19,79
Maximum	24,00	1.785	74,38		197,38	18,01		195,31	20,07

Meßpunkthöhe (MP): 215,09 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB05
Monatsbericht vom April 2025
gedruckt am: 03.05.2025, 02:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.04.25	24,00	528	22,00	---	---	---	7:11	196,00	13,58
02.04.25	24,00	530	22,08	---	---	---	7:04	196,05	13,53
03.04.25	21,66	479	22,12	17:51	197,16	12,42	15:34	196,05	13,53
04.04.25	21,20	471	22,22	3:13	197,24	12,35	23:58	196,02	13,56
05.04.25	24,00	532	22,17	---	---	---	20:25	195,96	13,62
06.04.25	24,00	533	22,21	---	---	---	6:17	195,91	13,67
07.04.25	24,00	528	22,00	---	---	---	10:51	195,93	13,66
08.04.25	21,87	483	22,08	10:41	197,05	12,53	6:27	195,91	13,67
09.04.25	24,00	530	22,08	---	---	---	11:10	195,91	13,67
10.04.25	24,00	529	22,04	---	---	---	9:41	195,88	13,70
11.04.25	24,00	528	22,00	---	---	---	0:11	195,90	13,69
12.04.25	24,00	531	22,13	---	---	---	7:58	195,90	13,69
13.04.25	24,00	531	22,13	---	---	---	23:42	195,90	13,69
14.04.25	24,00	527	21,96	---	---	---	3:16	195,90	13,69
15.04.25	24,00	527	21,96	---	---	---	22:38	195,90	13,69
16.04.25	24,00	526	21,92	---	---	---	8:08	195,85	13,73
17.04.25	24,00	528	22,00	---	---	---	21:51	195,85	13,73
18.04.25	24,00	531	22,13	---	---	---	23:13	195,77	13,81
19.04.25	24,00	531	22,13	---	---	---	9:24	195,76	13,82
20.04.25	24,00	529	22,04	---	---	---	5:34	195,76	13,82
21.04.25	24,00	530	22,08	---	---	---	4:59	195,81	13,78
22.04.25	24,00	526	21,92	---	---	---	8:44	195,84	13,75
23.04.25	24,00	526	21,92	---	---	---	7:34	195,87	13,72
24.04.25	24,00	527	21,96	---	---	---	7:12	195,85	13,73
25.04.25	24,00	526	21,92	---	---	---	11:22	195,84	13,74
26.04.25	24,00	529	22,04	---	---	---	23:41	195,73	13,85
27.04.25	24,00	529	22,04	---	---	---	9:35	195,70	13,89
28.04.25	24,00	526	21,92	---	---	---	9:38	195,68	13,90
29.04.25	21,72	477	21,96	13:33	196,75	12,83	8:20	195,65	13,93
30.04.25	24,00	526	21,92	---	---	---	10:27	195,67	13,92
Σ	710,45	15.654							
Mittelwert	23,68	522	22,03		197,05	12,53		195,86	13,72
Minimum	21,20	471	21,92		196,75	12,35		195,65	13,53
Maximum	24,00	533	22,22		197,24	12,83		196,05	13,93

Meßpunkthöhe (MP): 209,58 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB06
Monatsbericht vom April 2025
gedruckt am: 03.05.2025, 02:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.04.25	24,00	712	29,67	---	---	---	6:39	195,61	11,38
02.04.25	24,00	712	29,67	---	---	---	16:23	195,65	11,35
03.04.25	21,64	645	29,81	17:53	197,43	9,56	15:33	195,62	11,38
04.04.25	21,18	639	30,17	3:07	197,48	9,51	23:40	195,63	11,36
05.04.25	24,00	723	30,13	---	---	---	7:44	195,55	11,45
06.04.25	24,00	724	30,17	---	---	---	6:17	195,50	11,49
07.04.25	24,00	713	29,71	---	---	---	20:26	195,52	11,47
08.04.25	21,77	647	29,72	10:43	197,26	9,73	7:08	195,44	11,55
09.04.25	24,00	712	29,67	---	---	---	10:23	195,51	11,48
10.04.25	24,00	711	29,63	---	---	---	10:31	195,47	11,52
11.04.25	24,00	710	29,58	---	---	---	0:52	195,49	11,51
12.04.25	24,00	717	29,88	---	---	---	7:58	195,44	11,55
13.04.25	24,00	718	29,92	---	---	---	13:28	195,50	11,49
14.04.25	24,00	709	29,54	---	---	---	10:41	195,43	11,57
15.04.25	24,00	707	29,46	---	---	---	1:55	195,49	11,50
16.04.25	24,00	702	29,25	---	---	---	8:09	195,35	11,64
17.04.25	24,00	709	29,54	---	---	---	7:46	195,42	11,57
18.04.25	24,00	720	30,00	---	---	---	11:18	195,43	11,56
19.04.25	24,00	719	29,96	---	---	---	0:10	195,45	11,54
20.04.25	24,00	715	29,79	---	---	---	5:35	195,41	11,58
21.04.25	24,00	717	29,88	---	---	---	5:11	195,43	11,57
22.04.25	24,00	704	29,33	---	---	---	11:53	195,47	11,52
23.04.25	24,00	704	29,33	---	---	---	7:37	195,51	11,48
24.04.25	24,00	708	29,50	---	---	---	0:23	195,59	11,41
25.04.25	24,00	705	29,38	---	---	---	0:19	195,60	11,39
26.04.25	24,00	713	29,71	---	---	---	7:37	195,49	11,51
27.04.25	24,00	716	29,83	---	---	---	9:44	195,47	11,52
28.04.25	24,00	706	29,42	---	---	---	14:34	195,43	11,56
29.04.25	21,71	639	29,44	13:37	197,18	9,81	8:21	195,40	11,60
30.04.25	24,00	707	29,46	---	---	---	10:52	195,43	11,56
Σ	710,29	21.083							
Mittelwert	23,68	703	29,68		197,34	9,65		195,49	11,50
Minimum	21,18	639	29,25		197,18	9,51		195,35	11,35
Maximum	24,00	724	30,17		197,48	9,81		195,65	11,64

Meßpunkthöhe (MP): 206,99 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB07
Monatsbericht vom April 2025
gedruckt am: 03.05.2025, 02:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.04.25	24,00	1.294	53,92	---	---	---	6:39	194,87	7,80
02.04.25	24,00	1.296	54,00	---	---	---	5:29	194,87	7,80
03.04.25	21,62	1.170	54,11	17:48	197,01	5,66	7:02	194,88	7,79
04.04.25	21,17	1.147	54,19	3:05	197,15	5,52	23:30	194,87	7,80
05.04.25	24,00	1.301	54,21	---	---	---	22:20	194,80	7,87
06.04.25	24,00	1.302	54,25	---	---	---	21:18	194,76	7,91
07.04.25	24,00	1.296	54,00	---	---	---	10:56	194,76	7,91
08.04.25	21,59	1.167	54,06	10:36	196,88	5,79	6:44	194,72	7,95
09.04.25	24,00	1.297	54,04	---	---	---	21:23	194,72	7,95
10.04.25	24,00	1.296	54,00	---	---	---	8:10	194,69	7,98
11.04.25	24,00	1.295	53,96	---	---	---	0:43	194,70	7,97
12.04.25	24,00	1.299	54,13	---	---	---	0:19	194,71	7,96
13.04.25	24,00	1.298	54,08	---	---	---	0:07	194,74	7,93
14.04.25	24,00	1.295	53,96	---	---	---	11:09	194,69	7,98
15.04.25	24,00	1.295	53,96	---	---	---	0:34	194,72	7,95
16.04.25	24,00	1.293	53,88	---	---	---	8:10	194,66	8,01
17.04.25	24,00	1.294	53,92	---	---	---	6:44	194,68	7,99
18.04.25	24,00	1.299	54,13	---	---	---	15:21	194,65	8,02
19.04.25	24,00	1.299	54,13	---	---	---	0:16	194,66	8,01
20.04.25	24,00	1.298	54,08	---	---	---	0:06	194,69	7,98
21.04.25	24,00	1.298	54,08	---	---	---	5:15	194,69	7,98
22.04.25	24,00	1.294	53,92	---	---	---	8:24	194,69	7,98
23.04.25	24,00	1.293	53,88	---	---	---	7:39	194,72	7,95
24.04.25	24,00	1.294	53,92	---	---	---	2:41	194,76	7,91
25.04.25	24,00	1.294	53,92	---	---	---	11:44	194,77	7,90
26.04.25	24,00	1.296	54,00	---	---	---	7:33	194,72	7,95
27.04.25	24,00	1.297	54,04	---	---	---	10:40	194,68	7,99
28.04.25	24,00	1.295	53,96	---	---	---	0:42	194,66	8,01
29.04.25	21,68	1.169	53,91	13:20	196,76	5,91	0:57	194,65	8,02
30.04.25	24,00	1.295	53,96	---	---	---	13:27	194,65	8,02
Σ	710,06	38.356							
Mittelwert	23,67	1.279	54,02		196,95	5,72		194,73	7,94
Minimum	21,17	1.147	53,88		196,76	5,52		194,65	7,79
Maximum	24,00	1.302	54,25		197,15	5,91		194,88	8,02

Meßpunkthöhe (MP): 202,67 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB08
Monatsbericht vom April 2025
gedruckt am: 03.05.2025, 02:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.04.25	24,00	1.181	49,21	---	---	---	7:03	195,50	9,79
02.04.25	24,00	1.181	49,21	---	---	---	16:23	195,53	9,76
03.04.25	21,60	1.066	49,34	17:54	197,65	7,64	9:26	195,51	9,78
04.04.25	21,15	1.048	49,56	3:12	197,73	7,56	23:09	195,54	9,75
05.04.25	24,00	1.188	49,50	---	---	---	22:13	195,47	9,82
06.04.25	24,00	1.189	49,54	---	---	---	6:25	195,42	9,87
07.04.25	24,00	1.182	49,25	---	---	---	23:19	195,40	9,89
08.04.25	21,42	1.057	49,34	10:45	197,51	7,78	6:27	195,37	9,92
09.04.25	24,00	1.183	49,29	---	---	---	21:39	195,38	9,91
10.04.25	24,00	1.181	49,21	---	---	---	9:59	195,35	9,94
11.04.25	24,00	1.181	49,21	---	---	---	0:08	195,37	9,92
12.04.25	24,00	1.184	49,33	---	---	---	7:58	195,34	9,95
13.04.25	24,00	1.185	49,38	---	---	---	23:42	195,37	9,92
14.04.25	24,00	1.180	49,17	---	---	---	10:41	195,32	9,97
15.04.25	24,00	1.179	49,13	---	---	---	23:13	195,34	9,95
16.04.25	24,00	1.177	49,04	---	---	---	8:08	195,27	10,02
17.04.25	24,00	1.180	49,17	---	---	---	7:46	195,30	9,99
18.04.25	24,00	1.185	49,38	---	---	---	9:41	195,29	10,00
19.04.25	24,00	1.185	49,38	---	---	---	3:45	195,30	10,00
20.04.25	24,00	1.184	49,33	---	---	---	5:35	195,29	10,00
21.04.25	24,00	1.184	49,33	---	---	---	5:09	195,30	9,99
22.04.25	24,00	1.178	49,08	---	---	---	11:54	195,32	9,97
23.04.25	24,00	1.178	49,08	---	---	---	7:32	195,36	9,93
24.04.25	24,00	1.179	49,13	---	---	---	8:54	195,39	9,90
25.04.25	24,00	1.178	49,08	---	---	---	0:14	195,40	9,89
26.04.25	24,00	1.181	49,21	---	---	---	23:29	195,34	9,95
27.04.25	24,00	1.183	49,29	---	---	---	8:44	195,32	9,97
28.04.25	24,00	1.179	49,13	---	---	---	23:58	195,29	10,00
29.04.25	21,67	1.064	49,10	13:37	197,41	7,88	8:17	195,27	10,02
30.04.25	24,00	1.180	49,17	---	---	---	10:45	195,30	9,99
Σ	709,84	34.960							
Mittelwert	23,66	1.165	49,25		197,57	7,72		195,36	9,93
Minimum	21,15	1.048	49,04		197,41	7,56		195,27	9,75
Maximum	24,00	1.189	49,56		197,73	7,88		195,54	10,02

Meßpunkthöhe (MP): 205,29 m üNN