

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.05.25	0,00	0	---	22:22	199,70	14,57	---	---	---
02.05.25	0,00	0	---	22:52	199,79	14,48	---	---	---
03.05.25	0,00	0	---	16:16	199,90	14,37	---	---	---
04.05.25	0,00	0	---	8:49	200,14	14,13	---	---	---
05.05.25	0,00	0	---	8:08	200,12	14,15	---	---	---
06.05.25	15,73	1.619	102,92	6:16	200,04	14,23	21:11	194,80	19,47
07.05.25	24,00	2.457	102,38	---	---	---	20:51	194,48	19,79
08.05.25	20,71	2.114	102,09	23:56	199,47	14,80	17:13	194,39	19,88
09.05.25	9,66	990	102,52	8:12	199,81	14,46	23:42	194,48	19,79
10.05.25	24,00	2.453	102,21	---	---	---	22:56	194,20	20,08
11.05.25	24,00	2.464	102,67	---	---	---	12:40	194,32	19,95
12.05.25	5,94	609	102,55	14:59	199,44	14,83	0:29	194,40	19,87
13.05.25	1,12	117	104,03	15:08	200,21	14,07	8:36	195,27	19,01
14.05.25	15,69	1.607	102,42	4:11	199,75	14,52	19:56	194,58	19,69
15.05.25	24,00	2.452	102,17	---	---	---	14:11	194,34	19,93
16.05.25	24,00	2.446	101,92	---	---	---	19:36	194,20	20,07
17.05.25	24,00	2.453	102,21	---	---	---	2:13	194,23	20,04
18.05.25	24,00	2.457	102,38	---	---	---	23:16	194,23	20,04
19.05.25	23,72	2.420	102,03	---	---	---	23:39	194,12	20,15
20.05.25	2,98	306	102,52	22:24	199,25	15,02	9:50	194,63	19,65
21.05.25	0,64	65	101,04	13:54	199,43	14,85	---	---	---
22.05.25	0,00	0	---	6:12	199,58	14,69	---	---	---
23.05.25	0,00	0	---	4:16	199,56	14,71	---	---	---
24.05.25	0,00	0	---	5:54	199,66	14,62	---	---	---
25.05.25	2,37	246	103,91	6:56	199,82	14,46	23:54	195,18	19,10
26.05.25	24,00	2.461	102,54	---	---	---	22:41	194,39	19,88
27.05.25	21,14	2.165	102,42	11:47	199,34	14,94	8:53	194,32	19,95
28.05.25	24,00	2.452	102,17	---	---	---	22:47	194,15	20,12
29.05.25	24,00	2.464	102,67	---	---	---	5:28	194,13	20,14
30.05.25	11,09	1.138	102,64	23:56	199,37	14,91	2:27	194,36	19,91
31.05.25	0,00	0	---	5:23	199,53	14,74	---	---	---
Σ	370,79	37.955							
Mittelwert	11,96	1.224	102,36		199,69	14,58		194,44	19,83
Minimum	0,00	0	101,04		199,25	14,07		194,12	19,01
Maximum	24,00	2.464	104,03		200,21	15,02		195,27	20,15

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.25	24,00	3.399	141,63	---	---	---	0:26	195,59	18,63
02.05.25	24,00	3.430	142,92	---	---	---	0:44	195,88	18,34
03.05.25	24,00	3.450	143,75	---	---	---	8:07	195,97	18,25
04.05.25	22,07	3.202	145,05	8:47	201,21	13,01	7:39	196,12	18,10
05.05.25	22,72	3.258	143,40	---	---	---	23:57	196,05	18,18
06.05.25	15,90	2.206	138,78	12:01	201,01	13,21	10:26	195,77	18,45
07.05.25	15,19	2.018	132,84	5:19	200,69	13,53	20:46	195,86	18,36
08.05.25	14,26	1.883	132,09	23:59	200,61	13,61	17:07	195,78	18,44
09.05.25	18,01	2.434	135,14	7:59	200,80	13,42	23:20	195,65	18,57
10.05.25	20,50	2.748	134,07	7:06	200,13	14,09	22:13	195,45	18,77
11.05.25	9,57	1.273	133,01	20:46	200,35	13,87	12:33	195,74	18,48
12.05.25	19,74	2.746	139,13	5:24	200,39	13,83	23:55	195,57	18,65
13.05.25	16,61	2.373	142,88	15:04	201,43	12,80	0:00	195,58	18,64
14.05.25	19,24	2.654	137,91	21:23	200,37	13,85	19:50	195,87	18,35
15.05.25	15,19	2.018	132,88	4:56	200,47	13,76	11:39	195,59	18,64
16.05.25	17,03	2.236	131,30	5:49	200,31	13,92	19:30	195,54	18,68
17.05.25	13,19	1.741	132,04	19:38	200,15	14,07	17:27	195,63	18,59
18.05.25	10,82	1.434	132,57	7:02	200,34	13,88	23:10	195,68	18,54
19.05.25	14,82	1.953	131,82	7:37	200,27	13,95	23:33	195,53	18,70
20.05.25	24,00	3.307	137,79	---	---	---	0:43	195,38	18,84
21.05.25	24,00	3.329	138,71	---	---	---	0:10	195,41	18,81
22.05.25	23,52	3.309	140,67	---	---	---	0:50	195,50	18,72
23.05.25	24,00	3.374	140,58	---	---	---	13:25	195,64	18,58
24.05.25	23,73	3.376	142,25	---	---	---	0:39	195,66	18,57
25.05.25	22,12	3.165	143,06	23:57	200,59	13,63	1:53	195,86	18,36
26.05.25	13,12	1.748	133,19	5:24	200,70	13,52	22:31	195,82	18,40
27.05.25	13,03	1.740	133,54	10:32	200,63	13,59	8:50	195,40	18,83
28.05.25	15,78	2.074	131,40	6:07	200,36	13,86	22:42	195,51	18,71
29.05.25	8,74	1.157	132,31	22:13	200,33	13,89	5:20	195,53	18,70
30.05.25	16,38	2.274	138,82	8:28	200,40	13,83	12:53	195,46	18,77
31.05.25	23,63	3.335	141,14	---	---	---	16:17	195,63	18,59
Σ	568,91	78.644							
Mittelwert	18,35	2.537	138,24		200,55	13,67		195,66	18,56
Minimum	8,74	1.157	131,30		200,13	12,80		195,38	18,10
Maximum	24,00	3.450	145,05		201,43	14,09		196,12	18,84

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	8,73	807	92,47	22:44	200,73	19,40	0:19	198,01	22,11
02.05.25	8,06	745	92,44	11:01	200,84	19,28	0:35	198,42	21,70
03.05.25	6,29	583	92,74	16:26	200,96	19,16	7:51	198,52	21,60
04.05.25	3,95	367	92,96	8:46	201,27	18,85	22:13	198,79	21,33
05.05.25	9,16	852	92,97	8:05	201,24	18,89	23:40	198,61	21,51
06.05.25	16,84	1.558	92,54	6:05	201,15	18,97	21:07	198,37	21,75
07.05.25	24,00	2.204	91,83	---	---	---	20:47	198,02	22,10
08.05.25	24,00	2.196	91,50	---	---	---	17:08	197,91	22,21
09.05.25	23,44	2.153	91,87	---	---	---	23:23	197,88	22,24
10.05.25	24,00	2.202	91,75	---	---	---	22:50	197,61	22,51
11.05.25	24,00	2.224	92,67	---	---	---	0:00	197,83	22,29
12.05.25	18,25	1.688	92,50	15:11	200,44	19,69	0:20	198,02	22,10
13.05.25	7,76	724	93,25	15:04	201,40	18,73	23:09	198,44	21,68
14.05.25	19,30	1.779	92,19	4:22	200,77	19,35	19:52	198,06	22,06
15.05.25	24,00	2.202	91,75	---	---	---	14:03	197,86	22,26
16.05.25	24,00	2.185	91,04	---	---	---	19:31	197,66	22,46
17.05.25	24,00	2.204	91,83	---	---	---	17:28	197,72	22,40
18.05.25	24,00	2.217	92,38	---	---	---	23:12	197,77	22,36
19.05.25	23,72	2.170	91,49	---	---	---	23:35	197,61	22,51
20.05.25	17,94	1.645	91,72	4:35	200,18	19,95	23:40	197,81	22,31
21.05.25	17,10	1.573	92,00	13:43	200,27	19,85	0:00	197,82	22,30
22.05.25	12,02	1.107	92,13	7:37	200,48	19,64	0:28	197,94	22,19
23.05.25	13,00	1.201	92,41	4:46	200,54	19,59	13:18	198,14	21,98
24.05.25	8,86	818	92,32	20:24	200,65	19,47	0:26	198,16	21,97
25.05.25	7,36	684	92,97	6:59	200,86	19,26	22:40	198,45	21,67
26.05.25	24,00	2.211	92,13	---	---	---	22:33	197,97	22,16
27.05.25	22,24	2.048	92,09	10:28	200,60	19,53	21:37	197,90	22,22
28.05.25	24,00	2.193	91,38	---	---	---	22:43	197,63	22,49
29.05.25	24,00	2.226	92,75	---	---	---	5:21	197,65	22,48
30.05.25	18,50	1.715	92,72	20:30	200,31	19,82	12:52	197,91	22,21
31.05.25	11,55	1.067	92,42	10:44	200,59	19,53	20:15	198,13	22,00
Σ	538,03	49.548							
Mittelwert	17,36	1.598	92,09		200,74	19,38		198,02	22,10
Minimum	3,95	367	91,04		200,18	18,73		197,61	21,33
Maximum	24,00	2.226	93,25		201,40	19,95		198,79	22,51

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	9,08	924	101,74	19:35	202,95	18,43	0:25	198,36	23,02
02.05.25	8,36	862	103,15	11:01	203,28	18,10	0:38	199,35	22,04
03.05.25	6,52	678	103,98	23:57	203,49	17,89	8:00	199,70	21,68
04.05.25	4,18	440	105,15	8:54	203,83	17,55	22:16	200,23	21,15
05.05.25	9,52	998	104,83	8:56	203,90	17,48	23:51	200,00	21,38
06.05.25	17,83	1.823	102,22	6:22	203,78	17,60	21:37	199,19	22,19
07.05.25	24,00	2.354	98,08	---	---	---	21:11	198,40	22,98
08.05.25	24,00	2.292	95,50	---	---	---	17:27	198,04	23,34
09.05.25	23,49	2.237	95,21	---	---	---	0:52	197,66	23,72
10.05.25	24,00	2.381	99,21	---	---	---	1:56	197,73	23,66
11.05.25	24,00	2.394	99,75	---	---	---	16:09	197,97	23,41
12.05.25	18,50	1.865	100,82	15:09	202,68	18,70	0:38	198,07	23,31
13.05.25	7,83	822	105,04	14:59	203,89	17,49	23:20	199,52	21,86
14.05.25	19,53	1.963	100,54	4:19	203,22	18,17	20:06	198,63	22,76
15.05.25	24,00	2.331	97,13	---	---	---	20:33	198,06	23,32
16.05.25	24,00	2.255	93,96	---	---	---	22:53	197,54	23,84
17.05.25	24,00	2.305	96,04	---	---	---	2:26	197,59	23,79
18.05.25	24,00	2.351	97,96	---	---	---	23:27	197,66	23,72
19.05.25	23,73	2.254	95,00	---	---	---	19:02	197,47	23,91
20.05.25	18,08	1.778	98,32	13:33	202,26	19,12	11:32	198,33	23,05
21.05.25	17,40	1.737	99,85	13:38	202,50	18,88	0:00	198,21	23,18
22.05.25	12,44	1.263	101,52	7:46	202,83	18,55	0:43	198,48	22,90
23.05.25	13,40	1.369	102,13	4:41	202,93	18,45	13:24	199,07	22,31
24.05.25	9,17	943	102,85	20:23	203,11	18,27	0:31	199,15	22,23
25.05.25	7,64	793	103,80	8:52	203,40	17,98	23:43	199,57	21,82
26.05.25	24,00	2.384	99,33	---	---	---	22:50	198,30	23,08
27.05.25	22,29	2.196	98,54	10:26	202,74	18,64	8:28	198,15	23,24
28.05.25	24,00	2.283	95,13	---	---	---	22:58	197,57	23,81
29.05.25	24,00	2.382	99,25	---	---	---	5:43	197,54	23,84
30.05.25	18,62	1.868	100,31	23:58	202,55	18,84	0:00	198,02	23,37
31.05.25	11,83	1.208	102,10	10:58	203,04	18,34	3:17	199,02	22,37
Σ	543,44	53.733							
Mittelwert	17,53	1.733	98,88		203,13	18,25		198,47	22,91
Minimum	4,18	440	93,96		202,26	17,48		197,47	21,15
Maximum	24,00	2.394	105,15		203,90	19,12		200,23	23,91

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	2.338	97,42	---	---	---	0:31	199,36	26,48
02.05.25	24,00	2.359	98,29	---	---	---	0:41	199,87	25,97
03.05.25	24,00	2.370	98,75	---	---	---	8:07	200,29	25,55
04.05.25	22,13	2.201	99,46	8:47	205,26	20,58	3:59	200,62	25,22
05.05.25	22,76	2.247	98,71	---	---	---	23:58	200,60	25,25
06.05.25	15,76	1.498	95,05	11:57	204,60	21,24	21:07	199,84	26,00
07.05.25	15,30	1.391	90,93	5:25	204,02	21,83	20:47	199,09	26,75
08.05.25	17,64	1.604	90,92	5:28	203,43	22,41	20:36	199,02	26,83
09.05.25	18,77	1.720	91,62	7:58	203,15	22,70	10:18	199,02	26,83
10.05.25	20,54	1.946	94,75	7:05	203,96	21,89	1:45	199,08	26,77
11.05.25	9,69	883	91,13	1:19	203,67	22,17	15:53	199,12	26,72
12.05.25	19,77	1.900	96,11	5:23	203,52	22,32	0:19	199,29	26,55
13.05.25	16,32	1.608	98,55	15:05	205,71	20,14	0:00	199,63	26,21
14.05.25	19,33	1.841	95,26	21:25	203,57	22,28	19:51	199,39	26,45
15.05.25	14,15	1.285	90,84	4:55	203,64	22,20	20:14	199,08	26,76
16.05.25	17,10	1.546	90,39	5:48	203,35	22,50	12:29	199,02	26,83
17.05.25	13,30	1.202	90,40	19:39	203,00	22,84	7:45	199,02	26,83
18.05.25	10,93	991	90,67	7:02	203,37	22,47	2:27	199,02	26,82
19.05.25	14,92	1.353	90,67	7:37	203,32	22,53	13:02	199,02	26,83
20.05.25	24,00	2.292	95,50	---	---	---	0:46	199,03	26,81
21.05.25	24,00	2.308	96,17	---	---	---	0:04	199,32	26,52
22.05.25	23,54	2.289	97,24	---	---	---	0:44	199,51	26,33
23.05.25	24,00	2.333	97,21	---	---	---	13:29	199,87	25,97
24.05.25	23,75	2.330	98,12	---	---	---	0:37	199,90	25,94
25.05.25	22,17	2.181	98,39	23:53	204,30	21,54	0:00	200,26	25,58
26.05.25	13,25	1.208	91,15	0:00	204,30	21,54	22:33	199,18	26,66
27.05.25	12,46	1.137	91,24	10:32	204,32	21,53	0:46	199,15	26,69
28.05.25	15,86	1.434	90,43	8:38	203,48	22,37	18:26	199,03	26,81
29.05.25	8,85	801	90,51	22:13	203,46	22,38	11:50	199,02	26,82
30.05.25	16,42	1.571	95,66	8:43	203,64	22,20	12:53	199,15	26,69
31.05.25	23,65	2.308	97,61	---	---	---	0:00	199,87	25,97
Σ	572,34	54.475							
Mittelwert	18,46	1.757	95,18		203,86	21,98		199,44	26,40
Minimum	8,85	801	90,39		203,00	20,14		199,02	25,22
Maximum	24,00	2.370	99,46		205,71	22,84		200,62	26,83

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.05.25	2,52	256	101,39	18:51	204,82	26,59	21:36	195,64	35,78
02.05.25	0,00	0	---	11:07	205,08	26,33	---	---	---
03.05.25	0,00	0	---	17:00	205,30	26,12	---	---	---
04.05.25	0,00	0	---	8:56	205,83	25,58	---	---	---
05.05.25	0,00	0	---	8:13	205,80	25,62	---	---	---
06.05.25	16,11	1.644	102,07	6:19	205,68	25,74	21:46	194,73	36,68
07.05.25	24,00	2.401	100,04	---	---	---	21:06	194,02	37,40
08.05.25	24,00	2.365	98,54	---	---	---	17:29	193,88	37,53
09.05.25	19,49	1.919	98,47	23:57	203,57	27,84	6:32	193,45	37,96
10.05.25	1,63	174	106,49	7:21	204,64	26,78	23:57	194,96	36,45
11.05.25	24,00	2.467	102,79	---	---	---	16:16	194,19	37,23
12.05.25	6,01	624	103,87	16:11	204,66	26,76	3:13	194,34	37,08
13.05.25	0,43	45	103,85	15:10	206,09	25,33	---	---	---
14.05.25	15,71	1.597	101,62	0:41	205,17	26,24	20:12	194,38	37,03
15.05.25	24,00	2.405	100,21	---	---	---	20:27	194,05	37,37
16.05.25	24,00	2.360	98,33	---	---	---	19:47	193,47	37,95
17.05.25	24,00	2.404	100,17	---	---	---	2:24	193,62	37,79
18.05.25	24,00	2.441	101,71	---	---	---	23:25	193,83	37,58
19.05.25	23,74	2.361	99,44	---	---	---	19:01	193,54	37,87
20.05.25	1,80	174	96,68	14:35	204,15	27,26	---	---	---
21.05.25	0,69	66	95,65	14:51	204,52	26,90	---	---	---
22.05.25	0,00	0	---	8:11	204,81	26,61	---	---	---
23.05.25	0,00	0	---	5:02	204,84	26,58	---	---	---
24.05.25	0,00	0	---	7:24	205,01	26,41	---	---	---
25.05.25	2,39	250	104,53	7:09	205,28	26,13	23:55	195,47	35,95
26.05.25	24,00	2.428	101,17	---	---	---	22:49	194,17	37,24
27.05.25	20,48	2.061	100,64	11:46	204,81	26,61	1:07	194,12	37,29
28.05.25	24,00	2.376	99,00	---	---	---	22:57	193,54	37,87
29.05.25	24,00	2.463	102,63	---	---	---	5:42	193,58	37,84
30.05.25	11,16	1.155	103,51	23:46	204,47	26,94	0:00	194,32	37,09
31.05.25	0,00	0	---	11:03	204,93	26,49	---	---	---
Σ	362,17	36.436							
Mittelwert	11,68	1.175	100,60		204,97	26,44		194,16	37,25
Minimum	0,00	0	95,65		203,57	25,33		193,45	35,78
Maximum	24,00	2.467	106,49		206,09	27,84		195,64	37,96

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:16 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	2.183	90,96	---	---	---	3:26	203,29	28,76
02.05.25	24,00	2.192	91,33	---	---	---	0:54	203,42	28,64
03.05.25	24,00	2.208	92,00	---	---	---	2:00	203,58	28,47
04.05.25	21,94	2.035	92,77	8:49	210,68	21,37	0:09	203,72	28,33
05.05.25	22,58	2.076	91,95	---	---	---	0:37	203,86	28,20
06.05.25	15,01	1.335	88,96	13:08	211,68	20,38	4:21	203,80	28,26
07.05.25	14,91	1.283	86,02	5:30	211,64	20,41	20:43	203,97	28,09
08.05.25	17,33	1.484	85,64	5:35	211,00	21,05	23:48	203,49	28,56
09.05.25	18,53	1.605	86,64	8:06	210,74	21,31	22:57	203,29	28,76
10.05.25	20,39	1.834	89,97	7:09	210,59	21,47	1:08	203,29	28,76
11.05.25	9,27	802	86,50	5:55	211,68	20,38	15:50	204,87	27,19
12.05.25	19,64	1.776	90,44	5:31	211,71	20,35	23:55	203,54	28,52
13.05.25	23,33	2.183	93,58	---	---	---	5:30	203,42	28,64
14.05.25	14,84	1.327	89,43	13:59	211,93	20,12	3:59	203,39	28,67
15.05.25	13,70	1.195	87,25	5:02	211,40	20,66	10:40	204,36	27,69
16.05.25	16,82	1.457	86,60	5:51	211,20	20,86	19:25	203,31	28,75
17.05.25	12,87	1.124	87,37	19:42	210,76	21,30	1:58	203,98	28,07
18.05.25	10,49	925	88,21	7:02	211,75	20,30	23:09	204,35	27,71
19.05.25	14,50	1.271	87,66	7:46	211,54	20,52	23:29	203,60	28,46
20.05.25	24,00	2.204	91,83	---	---	---	1:15	203,00	29,05
21.05.25	24,00	2.210	92,08	---	---	---	0:42	203,00	29,05
22.05.25	23,47	2.180	92,88	---	---	---	2:21	203,11	28,95
23.05.25	24,00	2.225	92,71	---	---	---	0:00	203,21	28,84
24.05.25	23,68	2.208	93,23	---	---	---	3:08	203,21	28,84
25.05.25	22,01	2.040	92,68	23:59	210,37	21,68	1:07	203,35	28,70
26.05.25	12,77	1.120	87,71	5:30	211,89	20,17	22:29	204,38	27,68
27.05.25	12,03	1.055	87,70	10:34	211,47	20,58	21:35	204,26	27,80
28.05.25	15,60	1.354	86,82	8:43	211,40	20,66	22:36	203,39	28,67
29.05.25	8,46	744	87,92	22:19	211,83	20,23	5:16	203,74	28,32
30.05.25	16,26	1.495	91,92	8:40	212,09	19,97	23:52	203,20	28,86
31.05.25	23,58	2.191	92,90	---	---	---	0:48	203,18	28,87
Σ	567,99	51.321							
Mittelwert	18,32	1.656	90,36		211,36	20,69		203,60	28,45
Minimum	8,46	744	85,64		210,37	19,97		203,00	27,19
Maximum	24,00	2.225	93,58		212,09	21,68		204,87	29,05

Meßpunkthöhe (MP): 232,05 m üNN