

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.25	24,00	1.198	49,92	---	---	---	11:57	193,52	16,24
02.05.25	24,00	1.200	50,00	---	---	---	21:58	193,53	16,23
03.05.25	24,00	1.203	50,13	---	---	---	1:57	193,54	16,22
04.05.25	24,00	1.207	50,29	---	---	---	0:10	193,55	16,21
05.05.25	24,00	1.198	49,92	---	---	---	23:57	193,50	16,26
06.05.25	22,24	1.115	50,14	13:47	195,25	14,51	0:29	193,47	16,29
07.05.25	24,00	1.211	50,46	---	---	---	0:48	193,72	16,04
08.05.25	24,00	1.208	50,33	---	---	---	22:07	193,75	16,01
09.05.25	24,00	1.210	50,42	---	---	---	6:46	193,72	16,04
10.05.25	24,00	1.220	50,83	---	---	---	1:51	193,83	15,94
11.05.25	24,00	1.224	51,00	---	---	---	22:23	193,97	15,79
12.05.25	24,00	1.195	49,79	---	---	---	23:59	193,51	16,25
13.05.25	20,04	1.010	50,41	11:53	195,73	14,03	6:51	193,45	16,31
14.05.25	24,00	1.207	50,29	---	---	---	8:21	193,60	16,16
15.05.25	24,00	1.216	50,67	---	---	---	0:53	193,84	15,93
16.05.25	24,00	1.212	50,50	---	---	---	1:20	193,85	15,91
17.05.25	24,00	1.217	50,71	---	---	---	0:00	193,85	15,91
18.05.25	24,00	1.220	50,83	---	---	---	0:00	193,88	15,88
19.05.25	24,00	1.212	50,50	---	---	---	23:39	193,77	16,00
20.05.25	24,00	1.187	49,46	---	---	---	23:09	193,41	16,35
21.05.25	24,00	1.183	49,29	---	---	---	19:38	193,27	16,49
22.05.25	24,00	1.189	49,54	---	---	---	1:58	193,22	16,54
23.05.25	24,00	1.188	49,50	---	---	---	20:55	193,22	16,54
24.05.25	24,00	1.195	49,79	---	---	---	1:57	193,22	16,55
25.05.25	24,00	1.202	50,08	---	---	---	0:00	193,29	16,48
26.05.25	24,00	1.213	50,54	---	---	---	0:00	193,47	16,29
27.05.25	24,00	1.209	50,38	---	---	---	11:42	193,50	16,26
28.05.25	24,00	1.213	50,54	---	---	---	1:38	193,67	16,09
29.05.25	24,00	1.221	50,88	---	---	---	7:39	193,72	16,04
30.05.25	21,48	1.081	50,32	12:01	195,48	14,28	23:54	193,48	16,28
31.05.25	24,00	1.193	49,71	---	---	---	21:07	193,33	16,43
Σ	735,75	36.957							
Mittelwert	23,73	1.192	50,23		195,49	14,27		193,57	16,19
Minimum	20,04	1.010	49,29		195,25	14,03		193,22	15,79
Maximum	24,00	1.224	51,00		195,73	14,51		193,97	16,55

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.25	24,00	5.630	234,58	---	---	---	11:26	192,15	15,67
02.05.25	24,00	5.642	235,08	---	---	---	18:01	192,22	15,60
03.05.25	24,00	5.652	235,50	---	---	---	8:13	192,23	15,59
04.05.25	24,00	5.678	236,58	---	---	---	22:28	192,44	15,38
05.05.25	24,00	5.637	234,88	---	---	---	23:59	192,06	15,77
06.05.25	12,95	3.024	233,48	19:19	198,69	9,13	0:09	192,05	15,77
07.05.25	0,73	163	222,19	14:43	198,90	8,92	---	---	---
08.05.25	0,76	167	220,14	8:37	198,91	8,91	---	---	---
09.05.25	1,54	352	228,49	23:26	199,59	8,23	20:27	192,90	14,93
10.05.25	2,90	657	226,77	9:35	200,16	7,66	0:36	193,22	14,60
11.05.25	0,00	0	---	0:00	199,51	8,31	---	---	---
12.05.25	18,44	4.291	232,76	5:17	199,22	8,60	23:59	191,90	15,93
13.05.25	18,86	4.447	235,83	9:09	200,18	7,64	0:00	191,90	15,92
14.05.25	8,30	1.941	233,80	23:53	198,89	8,93	7:39	192,35	15,47
15.05.25	0,00	0	---	22:22	199,00	8,82	---	---	---
16.05.25	0,00	0	---	6:10	199,05	8,77	---	---	---
17.05.25	0,00	0	---	20:02	199,05	8,78	---	---	---
18.05.25	0,00	0	---	7:29	199,19	8,63	---	---	---
19.05.25	1,86	416	224,06	8:02	199,19	8,63	---	---	---
20.05.25	22,15	5.135	231,84	11:31	198,44	9,38	23:53	191,93	15,89
21.05.25	24,00	5.550	231,25	---	---	---	19:16	191,61	16,21
22.05.25	24,00	5.590	232,92	---	---	---	0:50	191,64	16,18
23.05.25	24,00	5.584	232,67	---	---	---	13:43	191,77	16,05
24.05.25	24,00	5.618	234,08	---	---	---	0:44	191,77	16,06
25.05.25	21,62	5.085	235,18	23:54	198,54	9,28	0:00	192,10	15,72
26.05.25	0,00	0	---	17:19	198,77	9,05	---	---	---
27.05.25	2,19	500	228,75	11:50	198,92	8,90	10:11	191,92	15,90
28.05.25	1,61	362	225,31	21:11	199,89	7,94	---	---	---
29.05.25	0,00	0	---	0:00	199,09	8,73	---	---	---
30.05.25	13,97	3.256	233,05	8:57	199,15	8,67	22:55	192,18	15,64
31.05.25	24,00	5.610	233,75	---	---	---	20:32	191,89	15,93
Σ	367,87	85.987							
Mittelwert	11,87	2.774	233,74		199,16	8,66		192,11	15,71
Minimum	0,00	0	220,14		198,44	7,64		191,61	14,60
Maximum	24,00	5.678	236,58		200,18	9,38		193,22	16,21

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	0,00	0	---	22:58	193,64	19,20	---	---	---
02.05.25	0,00	0	---	7:46	193,71	19,12	---	---	---
03.05.25	0,00	0	---	5:11	193,61	19,23	---	---	---
04.05.25	0,00	0	---	11:43	193,81	19,03	---	---	---
05.05.25	0,00	0	---	10:21	193,74	19,09	---	---	---
06.05.25	13,20	1.871	141,69	10:36	193,58	19,26	12:20	188,92	23,91
07.05.25	24,00	3.433	143,04	---	---	---	18:38	189,04	23,79
08.05.25	24,00	3.426	142,75	---	---	---	21:25	189,00	23,84
09.05.25	19,51	2.793	143,16	23:27	194,11	18,72	0:49	189,40	23,44
10.05.25	1,60	235	146,62	9:11	194,68	18,16	23:57	190,30	22,53
11.05.25	24,00	3.468	144,50	---	---	---	16:12	189,93	22,90
12.05.25	5,97	857	143,44	9:21	193,90	18,94	0:59	190,00	22,84
13.05.25	1,27	184	145,01	9:09	195,11	17,73	10:16	189,95	22,89
14.05.25	15,68	2.248	143,35	4:27	193,47	19,37	12:54	189,51	23,33
15.05.25	24,00	3.449	143,71	---	---	---	0:40	189,69	23,15
16.05.25	24,00	3.438	143,25	---	---	---	20:05	189,63	23,21
17.05.25	24,00	3.454	143,92	---	---	---	2:14	189,69	23,15
18.05.25	24,00	3.462	144,25	---	---	---	0:05	189,84	22,99
19.05.25	23,74	3.400	143,21	---	---	---	21:37	189,11	23,73
20.05.25	3,45	474	137,45	8:23	194,16	18,68	10:28	189,09	23,74
21.05.25	0,66	87	132,49	4:38	192,96	19,87	---	---	---
22.05.25	0,00	0	---	7:54	193,10	19,73	---	---	---
23.05.25	0,00	0	---	4:52	193,13	19,70	---	---	---
24.05.25	0,00	0	---	7:16	193,15	19,69	---	---	---
25.05.25	2,36	341	144,49	9:11	193,45	19,38	23:34	189,44	23,39
26.05.25	24,00	3.445	143,54	---	---	---	1:34	189,43	23,41
27.05.25	23,34	3.334	142,87	---	---	---	10:13	188,60	24,23
28.05.25	16,09	2.313	143,77	21:09	194,40	18,43	1:54	189,57	23,27
29.05.25	24,00	3.464	144,33	---	---	---	5:46	189,69	23,15
30.05.25	11,13	1.598	143,60	15:27	193,53	19,30	12:25	189,20	23,64
31.05.25	0,00	0	---	10:58	193,53	19,30	---	---	---
Σ	354,00	50.774							
Mittelwert	11,42	1.638	143,43		193,74	19,09		189,47	23,36
Minimum	0,00	0	132,49		192,96	17,73		188,60	22,53
Maximum	24,00	3.468	146,62		195,11	19,87		190,30	24,23

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	8,91	1.669	187,37	22:53	193,74	16,38	11:15	178,04	32,07
02.05.25	8,24	1.544	187,34	7:47	193,83	16,29	17:37	178,29	31,83
03.05.25	6,40	1.203	187,89	5:10	193,71	16,41	8:01	178,26	31,86
04.05.25	4,07	766	188,21	10:41	193,97	16,15	22:17	178,65	31,46
05.05.25	9,35	1.755	187,78	10:00	193,89	16,22	23:52	178,10	32,01
06.05.25	14,70	2.794	190,03	10:43	193,83	16,29	21:26	177,13	32,99
07.05.25	24,00	4.603	191,79	---	---	---	20:55	177,07	33,05
08.05.25	24,00	4.585	191,04	---	---	---	1:30	177,16	32,96
09.05.25	23,46	4.493	191,48	---	---	---	0:44	177,00	33,11
10.05.25	24,00	4.658	194,08	---	---	---	1:49	177,42	32,70
11.05.25	24,00	4.656	194,00	---	---	---	12:49	177,43	32,68
12.05.25	18,40	3.480	189,13	9:16	194,04	16,07	0:30	177,55	32,56
13.05.25	9,36	1.778	189,86	15:12	194,99	15,13	23:21	178,29	31,83
14.05.25	19,38	3.708	191,32	4:30	193,52	16,59	12:39	177,23	32,88
15.05.25	24,00	4.625	192,71	---	---	---	18:02	177,32	32,79
16.05.25	24,00	4.600	191,67	---	---	---	19:47	177,11	33,00
17.05.25	24,00	4.626	192,75	---	---	---	2:12	177,20	32,91
18.05.25	24,00	4.639	193,29	---	---	---	23:23	177,31	32,81
19.05.25	23,76	4.548	191,41	---	---	---	23:37	177,00	33,11
20.05.25	16,30	3.031	185,94	8:51	193,81	16,30	23:45	177,46	32,65
21.05.25	17,25	3.203	185,70	4:39	192,96	17,16	18:06	177,40	32,71
22.05.25	12,27	2.283	186,08	7:55	193,17	16,94	0:44	177,40	32,71
23.05.25	13,17	2.461	186,94	4:44	193,17	16,94	13:26	177,66	32,45
24.05.25	9,05	1.690	186,66	7:11	193,22	16,90	0:33	177,71	32,41
25.05.25	7,47	1.417	189,74	9:09	193,55	16,56	23:56	177,36	32,76
26.05.25	24,00	4.620	192,50	---	---	---	13:26	177,19	32,93
27.05.25	23,37	4.472	191,40	---	---	---	21:57	177,16	32,96
28.05.25	24,00	4.621	192,54	---	---	---	1:38	177,25	32,87
29.05.25	24,00	4.646	193,58	---	---	---	5:32	177,22	32,90
30.05.25	18,60	3.544	190,57	15:20	193,63	16,48	0:00	177,57	32,55
31.05.25	11,65	2.182	187,25	10:49	193,65	16,47	20:23	177,75	32,36
Σ	539,16	102.900							
Mittelwert	17,39	3.319	190,85		193,68	16,43		177,50	32,61
Minimum	4,07	766	185,70		192,96	15,13		177,00	31,46
Maximum	24,00	4.658	194,08		194,99	17,16		178,65	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	2.884	120,17	---	---	---	11:22	183,74	31,04
02.05.25	24,00	2.889	120,38	---	---	---	20:52	183,75	31,02
03.05.25	24,00	2.894	120,58	---	---	---	8:14	183,75	31,02
04.05.25	22,07	2.670	120,98	8:48	193,98	20,79	22:26	184,01	30,76
05.05.25	22,71	2.728	120,10	---	---	---	23:57	183,63	31,14
06.05.25	17,45	2.083	119,39	22:53	193,89	20,88	0:00	183,63	31,14
07.05.25	15,19	1.826	120,18	5:26	194,33	20,44	20:43	184,10	30,67
08.05.25	17,56	2.110	120,14	5:31	194,33	20,44	23:14	184,06	30,72
09.05.25	18,70	2.255	120,58	8:02	194,44	20,33	0:00	184,06	30,72
10.05.25	20,50	2.486	121,25	7:06	194,43	20,35	1:38	184,07	30,70
11.05.25	9,55	1.161	121,53	5:50	194,96	19,82	12:29	184,91	29,86
12.05.25	19,74	2.358	119,44	5:23	195,01	19,77	23:59	183,65	31,13
13.05.25	17,84	2.147	120,38	15:02	195,28	19,49	0:00	183,65	31,13
14.05.25	19,25	2.314	120,24	21:25	194,07	20,70	7:33	183,92	30,85
15.05.25	14,03	1.695	120,79	4:58	194,53	20,24	10:39	184,59	30,18
16.05.25	17,04	2.053	120,45	5:50	194,69	20,09	19:00	184,23	30,55
17.05.25	13,19	1.595	120,95	19:41	194,61	20,17	1:58	184,62	30,15
18.05.25	10,82	1.311	121,13	6:53	195,08	19,69	23:10	184,95	29,83
19.05.25	14,80	1.783	120,50	7:40	195,01	19,77	23:22	184,42	30,35
20.05.25	24,00	2.857	119,04	---	---	---	23:29	183,58	31,19
21.05.25	24,00	2.845	118,54	---	---	---	19:15	183,22	31,56
22.05.25	23,52	2.804	119,22	---	---	---	0:49	183,17	31,60
23.05.25	24,00	2.860	119,17	---	---	---	13:43	183,29	31,48
24.05.25	23,73	2.844	119,83	---	---	---	0:43	183,28	31,50
25.05.25	22,13	2.660	120,19	23:59	193,53	21,25	0:00	183,68	31,10
26.05.25	13,12	1.583	120,67	5:28	194,40	20,38	10:19	184,36	30,41
27.05.25	13,68	1.641	119,96	5:23	194,46	20,32	21:35	184,36	30,41
28.05.25	15,80	1.907	120,71	8:41	194,58	20,20	18:03	184,39	30,38
29.05.25	8,75	1.058	120,86	22:13	194,99	19,78	5:18	184,55	30,23
30.05.25	16,37	1.964	119,95	8:43	195,14	19,63	22:57	183,89	30,89
31.05.25	23,63	2.828	119,69	---	---	---	20:28	183,52	31,25
Σ	575,19	69.093							
Mittelwert	18,55	2.229	120,12		194,56	20,21		183,97	30,80
Minimum	8,75	1.058	118,54		193,53	19,49		183,17	29,83
Maximum	24,00	2.894	121,53		195,28	21,25		184,95	31,60

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.25	24,00	1.362	56,75	---	---	---	12:29	188,94	24,34
02.05.25	24,00	1.362	56,75	---	---	---	22:13	188,82	24,46
03.05.25	24,00	1.364	56,83	---	---	---	0:54	188,85	24,43
04.05.25	22,17	1.270	57,30	8:44	194,22	19,06	0:00	188,90	24,38
05.05.25	22,81	1.291	56,59	---	---	---	23:59	188,85	24,43
06.05.25	17,74	1.005	56,64	22:52	195,51	17,77	1:26	188,74	24,54
07.05.25	15,38	897	58,34	5:24	196,10	17,18	20:47	190,24	23,04
08.05.25	17,72	1.031	58,19	5:31	196,20	17,08	21:42	190,22	23,06
09.05.25	18,83	1.100	58,43	8:03	196,25	17,03	20:51	190,24	23,04
10.05.25	20,58	1.209	58,75	7:05	196,03	17,25	0:50	189,97	23,31
11.05.25	9,77	585	59,86	20:39	196,85	16,43	12:35	191,18	22,10
12.05.25	19,80	1.119	56,52	5:26	197,00	16,28	23:56	189,07	24,21
13.05.25	17,83	1.016	56,97	10:02	196,18	17,10	6:30	188,90	24,38
14.05.25	19,40	1.118	57,63	21:24	195,88	17,40	8:12	189,04	24,24
15.05.25	14,25	843	59,18	4:59	196,42	16,86	10:43	190,84	22,44
16.05.25	17,18	1.006	58,54	5:47	196,64	16,64	18:36	190,31	22,97
17.05.25	13,39	794	59,30	19:40	196,59	16,69	2:02	190,94	22,34
18.05.25	11,03	658	59,64	6:46	197,09	16,19	23:12	191,30	21,98
19.05.25	15,01	881	58,69	7:45	197,04	16,24	23:35	190,70	22,58
20.05.25	24,00	1.337	55,71	---	---	---	23:58	188,94	24,34
21.05.25	24,00	1.321	55,04	---	---	---	19:46	188,49	24,79
22.05.25	23,55	1.310	55,62	---	---	---	1:17	188,42	24,86
23.05.25	24,00	1.331	55,46	---	---	---	14:26	188,47	24,81
24.05.25	23,76	1.330	55,97	---	---	---	1:10	188,44	24,84
25.05.25	22,20	1.254	56,48	23:59	194,77	18,51	0:00	188,57	24,71
26.05.25	13,35	786	58,88	16:30	196,08	17,20	10:22	190,56	22,72
27.05.25	13,79	803	58,23	9:00	196,37	16,91	11:38	190,51	22,77
28.05.25	15,92	935	58,71	8:37	196,52	16,76	22:43	190,44	22,84
29.05.25	8,94	530	59,31	22:04	196,97	16,31	5:21	190,82	22,46
30.05.25	16,46	939	57,06	8:35	197,17	16,11	23:57	189,19	24,09
31.05.25	23,66	1.329	56,17	---	---	---	21:13	188,76	24,52
Σ	578,52	33.116							
Mittelwert	18,66	1.068	57,24		196,28	17,00		189,60	23,68
Minimum	8,94	530	55,04		194,22	16,11		188,42	21,98
Maximum	24,00	1.364	59,86		197,17	19,06		191,30	24,86

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	2.629	109,54	---	---	---	17:02	193,83	22,97
02.05.25	24,00	2.629	109,54	---	---	---	22:00	193,75	23,05
03.05.25	24,00	2.636	109,83	---	---	---	10:27	193,72	23,08
04.05.25	24,00	2.651	110,46	---	---	---	4:11	193,66	23,14
05.05.25	24,00	2.624	109,33	---	---	---	3:23	193,68	23,12
06.05.25	13,85	1.508	108,89	23:31	201,70	15,10	4:33	193,59	23,21
07.05.25	1,97	216	109,80	11:52	202,10	14,70	13:06	196,11	20,69
08.05.25	0,77	81	105,08	5:42	202,22	14,58	---	---	---
09.05.25	1,61	174	107,85	8:11	202,25	14,55	20:26	195,78	21,02
10.05.25	2,94	311	105,71	7:19	202,14	14,66	0:33	195,56	21,24
11.05.25	0,00	0	---	20:51	202,62	14,18	---	---	---
12.05.25	18,48	2.007	108,60	5:19	202,69	14,11	23:59	194,04	22,76
13.05.25	19,75	2.172	110,00	10:07	201,96	14,84	6:46	193,36	23,44
14.05.25	8,28	902	108,98	23:25	202,12	14,68	8:08	193,89	22,91
15.05.25	0,00	0	---	22:01	202,38	14,42	---	---	---
16.05.25	3,19	363	113,66	5:54	202,49	14,31	18:29	195,73	21,07
17.05.25	0,00	0	---	19:44	202,52	14,28	---	---	---
18.05.25	0,00	0	---	7:05	202,76	14,04	---	---	---
19.05.25	1,95	209	107,18	7:56	202,76	14,04	---	---	---
20.05.25	24,00	2.595	108,13	---	---	---	13:16	194,05	22,75
21.05.25	24,00	2.579	107,46	---	---	---	19:48	193,59	23,21
22.05.25	24,00	2.600	108,33	---	---	---	5:44	193,44	23,36
23.05.25	24,00	2.594	108,08	---	---	---	21:00	193,50	23,30
24.05.25	24,00	2.616	109,00	---	---	---	5:36	193,39	23,41
25.05.25	21,60	2.367	109,57	23:59	201,10	15,70	1:59	193,43	23,37
26.05.25	0,00	0	---	16:40	202,09	14,71	---	---	---
27.05.25	1,92	207	107,59	8:57	202,27	14,53	11:39	195,22	21,58
28.05.25	1,64	175	106,94	8:43	202,39	14,41	---	---	---
29.05.25	0,00	0	---	22:25	202,64	14,16	---	---	---
30.05.25	14,01	1.526	108,90	8:54	202,75	14,05	23:56	194,02	22,78
31.05.25	24,00	2.610	108,75	---	---	---	21:58	193,67	23,13
Σ	375,96	40.981							
Mittelwert	12,13	1.322	109,00		202,30	14,50		194,14	22,66
Minimum	0,00	0	105,08		201,10	14,04		193,36	20,69
Maximum	24,00	2.651	113,66		202,76	15,70		196,11	23,44

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	4.483	186,79	---	---	---	17:02	179,92	41,23
02.05.25	24,00	4.481	186,71	---	---	---	22:12	179,84	41,31
03.05.25	24,00	4.507	187,79	---	---	---	16:06	179,78	41,37
04.05.25	24,00	4.560	190,00	---	---	---	4:04	179,38	41,77
05.05.25	24,00	4.455	185,63	---	---	---	3:21	179,36	41,79
06.05.25	15,09	2.784	184,52	23:49	197,59	23,56	6:02	179,22	41,93
07.05.25	1,66	297	179,10	11:36	198,08	23,07	---	---	---
08.05.25	3,11	569	183,11	8:47	198,25	22,90	17:13	181,83	39,32
09.05.25	1,62	285	176,35	8:22	198,28	22,87	20:27	183,33	37,82
10.05.25	3,00	521	173,65	7:33	198,16	22,99	0:36	183,08	38,07
11.05.25	0,00	0	---	20:39	198,70	22,45	---	---	---
12.05.25	18,48	3.373	182,55	5:27	198,80	22,35	20:41	180,22	40,93
13.05.25	19,52	3.659	187,41	10:09	197,86	23,29	6:34	179,50	41,65
14.05.25	8,30	1.533	184,64	23:32	198,16	22,99	7:45	180,00	41,15
15.05.25	0,00	0	---	22:49	198,47	22,68	---	---	---
16.05.25	0,00	0	---	6:09	198,58	22,57	---	---	---
17.05.25	0,00	0	---	19:44	198,63	22,52	---	---	---
18.05.25	0,00	0	---	6:54	198,88	22,27	---	---	---
19.05.25	1,95	346	177,01	7:31	198,88	22,27	---	---	---
20.05.25	24,00	4.364	181,83	---	---	---	8:23	179,90	41,25
21.05.25	24,00	4.297	179,04	---	---	---	19:46	179,62	41,53
22.05.25	24,00	4.384	182,67	---	---	---	6:02	179,14	42,01
23.05.25	24,00	4.359	181,63	---	---	---	14:31	179,52	41,63
24.05.25	24,00	4.442	185,08	---	---	---	5:39	179,02	42,13
25.05.25	21,62	4.052	187,41	23:57	196,80	24,35	2:02	179,14	42,01
26.05.25	0,00	0	---	17:01	198,08	23,07	---	---	---
27.05.25	1,97	352	178,55	9:19	198,32	22,83	11:41	180,67	40,48
28.05.25	1,66	292	175,40	8:37	198,44	22,71	---	---	---
29.05.25	0,00	0	---	22:04	198,70	22,45	---	---	---
30.05.25	14,00	2.581	184,31	8:50	198,85	22,30	23:42	180,14	41,01
31.05.25	24,00	4.425	184,38	---	---	---	5:02	179,54	41,61
Σ	375,99	69.401							
Mittelwert	12,13	2.239	184,58		198,33	22,82		180,10	41,05
Minimum	0,00	0	173,65		196,80	22,27		179,02	37,82
Maximum	24,00	4.560	190,00		198,88	24,35		183,33	42,13

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	0,00	0	---	7:09	188,02	39,51	---	---	---
02.05.25	0,00	0	---	0:22	188,02	39,51	---	---	---
03.05.25	0,00	0	---	6:10	188,02	39,51	---	---	---
04.05.25	0,00	0	---	---	---	---	---	---	---
05.05.25	0,00	0	---	0:21	188,02	39,51	---	---	---
06.05.25	0,00	0	---	3:15	188,02	39,51	---	---	---
07.05.25	0,00	0	---	3:27	188,02	39,51	---	---	---
08.05.25	0,00	0	---	0:53	188,02	39,51	---	---	---
09.05.25	0,00	0	---	15:15	188,02	39,51	---	---	---
10.05.25	0,00	0	---	23:19	188,02	39,51	---	---	---
11.05.25	0,00	0	---	1:19	188,02	39,51	---	---	---
12.05.25	0,00	0	---	3:06	188,02	39,51	---	---	---
13.05.25	0,00	0	---	16:04	188,02	39,51	---	---	---
14.05.25	0,00	0	---	13:41	188,02	39,51	---	---	---
15.05.25	0,00	0	---	5:02	188,02	39,51	---	---	---
16.05.25	0,00	0	---	---	---	---	---	---	---
17.05.25	0,00	0	---	4:50	188,02	39,51	---	---	---
18.05.25	0,00	0	---	2:34	188,02	39,51	---	---	---
19.05.25	0,00	0	---	0:00	188,01	39,51	---	---	---
20.05.25	0,00	0	---	---	---	---	---	---	---
21.05.25	0,00	0	---	4:01	188,02	39,51	---	---	---
22.05.25	0,00	0	---	3:03	188,02	39,51	---	---	---
23.05.25	0,00	0	---	16:25	188,02	39,51	---	---	---
24.05.25	0,00	0	---	---	---	---	---	---	---
25.05.25	0,00	0	---	0:00	188,01	39,51	---	---	---
26.05.25	0,00	0	---	4:56	188,02	39,51	---	---	---
27.05.25	0,00	0	---	14:16	188,02	39,51	---	---	---
28.05.25	0,00	0	---	0:06	188,02	39,51	---	---	---
29.05.25	0,00	0	---	0:09	188,02	39,51	---	---	---
30.05.25	0,00	0	---	5:31	188,02	39,51	---	---	---
31.05.25	0,00	0	---	0:00	188,01	39,51	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,01	39,51		---	---
Minimum	0,00	0	---		188,01	39,51		---	---
Maximum	0,00	0	---		188,02	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	9,17	669	72,96	4:24	198,37	37,09	2:37	193,38	42,09
02.05.25	8,45	618	73,17	7:54	198,33	37,13	17:32	193,13	42,33
03.05.25	6,59	486	73,76	5:06	198,25	37,21	7:51	193,09	42,37
04.05.25	4,24	312	73,50	12:21	198,33	37,13	22:15	193,34	42,13
05.05.25	9,60	710	73,94	10:03	198,29	37,17	23:43	192,86	42,60
06.05.25	14,86	1.005	67,62	10:40	198,19	37,27	13:44	193,08	42,38
07.05.25	24,00	1.589	66,21	---	---	---	13:07	193,47	42,00
08.05.25	24,00	1.588	66,17	---	---	---	17:08	193,46	42,00
09.05.25	23,51	1.541	65,55	---	---	---	20:28	193,51	41,95
10.05.25	24,00	1.630	67,92	---	---	---	0:36	193,50	41,96
11.05.25	24,00	1.595	66,46	---	---	---	1:25	194,08	41,38
12.05.25	18,57	1.324	71,31	8:50	198,78	36,68	20:06	193,18	42,29
13.05.25	8,97	657	73,24	10:19	198,70	36,76	23:20	193,17	42,29
14.05.25	19,58	1.286	65,68	4:26	198,24	37,22	2:15	193,16	42,30
15.05.25	24,00	1.621	67,54	---	---	---	10:42	194,03	41,43
16.05.25	24,00	1.533	63,88	---	---	---	18:24	194,03	41,44
17.05.25	24,00	1.517	63,21	---	---	---	8:38	194,21	41,25
18.05.25	24,00	1.590	66,25	---	---	---	13:16	194,26	41,21
19.05.25	23,74	1.585	66,77	---	---	---	21:35	193,80	41,67
20.05.25	14,81	1.136	76,68	1:59	198,78	36,69	23:55	193,05	42,41
21.05.25	17,47	1.262	72,22	4:29	198,06	37,40	7:39	192,94	42,52
22.05.25	12,55	913	72,72	7:47	198,03	37,43	12:14	192,91	42,55
23.05.25	13,50	981	72,67	4:48	198,03	37,43	23:55	192,89	42,57
24.05.25	9,24	672	72,70	20:23	198,02	37,45	0:25	192,87	42,59
25.05.25	7,71	546	70,84	8:56	198,14	37,32	11:15	193,05	42,42
26.05.25	24,00	1.564	65,17	---	---	---	1:45	193,75	41,71
27.05.25	23,91	1.639	68,55	---	---	---	11:12	193,44	42,03
28.05.25	24,00	1.610	67,08	---	---	---	15:54	193,70	41,77
29.05.25	24,00	1.597	66,54	---	---	---	0:00	194,13	41,34
30.05.25	18,66	1.315	70,48	15:10	198,64	36,82	22:40	193,20	42,26
31.05.25	11,90	866	72,80	1:25	198,33	37,13	20:20	193,06	42,40
Σ	541,03	36.957							
Mittelwert	17,45	1.192	68,31		198,32	37,14		193,41	42,05
Minimum	4,24	312	63,21		198,02	36,68		192,86	41,21
Maximum	24,00	1.639	76,68		198,78	37,45		194,26	42,60

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.25	0,00	0	---	22:42	196,97	47,85	---	---	---
02.05.25	0,00	0	---	12:32	197,03	47,79	---	---	---
03.05.25	0,00	0	---	16:42	197,10	47,72	---	---	---
04.05.25	0,00	0	---	17:11	197,18	47,64	---	---	---
05.05.25	0,00	0	---	12:39	197,16	47,66	---	---	---
06.05.25	13,28	2.236	168,37	10:10	197,09	47,73	16:03	193,08	51,75
07.05.25	24,00	4.038	168,25	---	---	---	20:48	193,05	51,78
08.05.25	24,00	4.022	167,58	---	---	---	22:44	193,02	51,80
09.05.25	24,00	4.024	167,67	---	---	---	0:48	193,00	51,82
10.05.25	24,00	4.019	167,46	---	---	---	2:17	192,89	51,93
11.05.25	24,00	4.032	168,00	---	---	---	0:01	193,02	51,81
12.05.25	6,15	1.036	168,46	11:07	197,03	47,79	1:48	193,30	51,52
13.05.25	1,88	321	171,02	10:23	197,22	47,60	12:16	193,73	51,09
14.05.25	15,76	2.652	168,27	0:00	197,12	47,70	16:08	193,19	51,63
15.05.25	24,00	4.020	167,50	---	---	---	1:38	193,22	51,60
16.05.25	24,00	4.006	166,92	---	---	---	19:34	193,06	51,76
17.05.25	24,00	4.034	168,08	---	---	---	2:56	193,14	51,68
18.05.25	24,00	4.033	168,04	---	---	---	0:00	193,25	51,57
19.05.25	23,79	3.990	167,72	---	---	---	23:24	193,09	51,73
20.05.25	2,27	386	169,98	7:02	196,91	47,91	11:46	193,64	51,18
21.05.25	0,78	132	168,99	15:37	196,85	47,97	---	---	---
22.05.25	0,00	0	---	10:02	196,87	47,96	---	---	---
23.05.25	0,00	0	---	9:03	196,87	47,96	---	---	---
24.05.25	0,00	0	---	21:23	196,91	47,91	---	---	---
25.05.25	2,44	418	171,60	17:22	197,01	47,81	23:59	193,39	51,43
26.05.25	24,00	4.032	168,00	---	---	---	23:10	193,15	51,68
27.05.25	24,00	4.010	167,08	---	---	---	13:22	193,08	51,75
28.05.25	24,00	4.012	167,17	---	---	---	23:23	193,02	51,81
29.05.25	24,00	4.009	167,04	---	---	---	0:01	193,05	51,78
30.05.25	11,30	1.888	167,10	17:54	196,91	47,91	0:00	193,31	51,51
31.05.25	0,00	0	---	7:08	196,93	47,90	---	---	---
Σ	389,64	65.350							
Mittelwert	12,57	2.108	167,72		197,01	47,81		193,17	51,65
Minimum	0,00	0	166,92		196,85	47,60		192,89	51,09
Maximum	24,00	4.038	171,60		197,22	47,97		193,73	51,93

Meßpunkthöhe (MP): 244,82 m üNN