

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB02
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:17 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.05.25	24,00	1.757	73,21	---	---	---	1:08	195,11	19,99
02.05.25	24,00	1.762	73,42	---	---	---	2:44	195,17	19,92
03.05.25	24,00	1.766	73,58	---	---	---	0:15	195,18	19,92
04.05.25	24,00	1.771	73,79	---	---	---	8:27	195,15	19,94
05.05.25	24,00	1.759	73,29	---	---	---	7:47	195,16	19,93
06.05.25	22,32	1.640	73,49	13:45	197,12	17,98	21:54	195,12	19,97
07.05.25	24,00	1.763	73,46	---	---	---	21:52	195,06	20,03
08.05.25	24,00	1.758	73,25	---	---	---	17:34	195,04	20,05
09.05.25	24,00	1.762	73,42	---	---	---	6:27	195,04	20,05
10.05.25	24,00	1.767	73,63	---	---	---	6:08	195,00	20,09
11.05.25	24,00	1.775	73,96	---	---	---	4:01	195,01	20,08
12.05.25	24,00	1.746	72,75	---	---	---	1:15	195,02	20,08
13.05.25	20,10	1.483	73,79	11:49	197,11	17,98	6:51	194,98	20,12
14.05.25	24,00	1.762	73,42	---	---	---	22:52	195,07	20,02
15.05.25	24,00	1.767	73,63	---	---	---	14:30	195,00	20,09
16.05.25	24,00	1.760	73,33	---	---	---	23:52	194,98	20,12
17.05.25	24,00	1.768	73,67	---	---	---	10:56	194,96	20,13
18.05.25	24,00	1.770	73,75	---	---	---	17:59	194,95	20,15
19.05.25	24,00	1.757	73,21	---	---	---	1:47	194,94	20,15
20.05.25	24,00	1.737	72,38	---	---	---	0:00	194,96	20,13
21.05.25	24,00	1.737	72,38	---	---	---	3:25	195,00	20,09
22.05.25	24,00	1.747	72,79	---	---	---	6:08	194,98	20,11
23.05.25	24,00	1.745	72,71	---	---	---	20:24	195,00	20,09
24.05.25	24,00	1.757	73,21	---	---	---	5:36	194,98	20,12
25.05.25	24,00	1.763	73,46	---	---	---	1:56	195,01	20,08
26.05.25	24,00	1.766	73,58	---	---	---	22:48	194,93	20,16
27.05.25	24,00	1.757	73,21	---	---	---	11:43	194,88	20,21
28.05.25	24,00	1.761	73,38	---	---	---	13:18	194,89	20,20
29.05.25	24,00	1.770	73,75	---	---	---	9:12	194,84	20,25
30.05.25	21,56	1.581	73,34	12:23	196,90	18,19	2:55	194,86	20,23
31.05.25	24,00	1.748	72,83	---	---	---	5:11	194,95	20,14
Σ	735,97	53.962							
Mittelwert	23,74	1.741	73,32		197,04	18,05		195,01	20,08
Minimum	20,10	1.483	72,38		196,90	17,98		194,84	19,92
Maximum	24,00	1.775	73,96		197,12	18,19		195,18	20,25

Meßpunkthöhe (MP): 215,09 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB05
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:17 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	527	21,96	---	---	---	2:54	195,75	13,83
02.05.25	24,00	529	22,04	---	---	---	0:51	195,82	13,76
03.05.25	24,00	530	22,08	---	---	---	0:10	195,85	13,73
04.05.25	24,00	531	22,13	---	---	---	7:45	195,84	13,75
05.05.25	24,00	528	22,00	---	---	---	3:23	195,85	13,73
06.05.25	22,30	491	22,01	13:42	197,10	12,48	22:32	196,00	13,58
07.05.25	24,00	528	22,00	---	---	---	21:59	195,94	13,64
08.05.25	24,00	526	21,92	---	---	---	13:30	195,78	13,80
09.05.25	24,00	527	21,96	---	---	---	0:09	195,84	13,75
10.05.25	24,00	528	22,00	---	---	---	14:32	195,88	13,70
11.05.25	24,00	530	22,08	---	---	---	0:03	195,88	13,70
12.05.25	24,00	524	21,83	---	---	---	0:35	195,91	13,67
13.05.25	19,99	444	22,21	11:47	197,20	12,38	6:51	195,97	13,61
14.05.25	24,00	527	21,96	---	---	---	22:57	195,97	13,61
15.05.25	24,00	528	22,00	---	---	---	20:35	195,90	13,69
16.05.25	24,00	525	21,88	---	---	---	4:54	195,88	13,70
17.05.25	24,00	527	21,96	---	---	---	11:43	195,85	13,73
18.05.25	24,00	528	22,00	---	---	---	12:22	195,85	13,73
19.05.25	24,00	524	21,83	---	---	---	3:38	195,85	13,73
20.05.25	24,00	520	21,67	---	---	---	0:13	195,87	13,72
21.05.25	24,00	521	21,71	---	---	---	9:21	195,97	13,61
22.05.25	24,00	524	21,83	---	---	---	21:20	195,97	13,62
23.05.25	24,00	523	21,79	---	---	---	21:02	195,96	13,62
24.05.25	24,00	526	21,92	---	---	---	3:51	195,96	13,62
25.05.25	24,00	527	21,96	---	---	---	6:50	195,98	13,60
26.05.25	24,00	526	21,92	---	---	---	22:47	195,84	13,75
27.05.25	24,00	524	21,83	---	---	---	1:34	195,82	13,76
28.05.25	24,00	524	21,83	---	---	---	23:54	195,81	13,77
29.05.25	24,00	527	21,96	---	---	---	9:46	195,76	13,82
30.05.25	21,55	474	22,00	12:25	196,94	12,64	5:33	195,79	13,79
31.05.25	24,00	525	21,88	---	---	---	5:14	195,93	13,66
Σ	735,84	16.143							
Mittelwert	23,74	521	21,94		197,08	12,50		195,88	13,70
Minimum	19,99	444	21,67		196,94	12,38		195,75	13,58
Maximum	24,00	531	22,21		197,20	12,64		196,00	13,83

Meßpunkthöhe (MP): 209,58 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB06
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:17 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	709	29,54	---	---	---	0:58	195,52	11,47
02.05.25	24,00	715	29,79	---	---	---	1:14	195,59	11,41
03.05.25	24,00	718	29,92	---	---	---	0:49	195,60	11,39
04.05.25	24,00	722	30,08	---	---	---	14:24	195,55	11,44
05.05.25	24,00	712	29,67	---	---	---	3:20	195,57	11,42
06.05.25	22,28	662	29,71	13:40	197,23	9,76	10:25	195,54	11,45
07.05.25	24,00	708	29,50	---	---	---	21:43	195,46	11,53
08.05.25	24,00	702	29,25	---	---	---	8:24	195,44	11,55
09.05.25	24,00	706	29,42	---	---	---	6:39	195,43	11,56
10.05.25	24,00	707	29,46	---	---	---	6:37	195,38	11,61
11.05.25	24,00	716	29,83	---	---	---	8:52	195,39	11,60
12.05.25	24,00	697	29,04	---	---	---	0:43	195,41	11,58
13.05.25	19,86	597	30,06	11:45	197,28	9,72	6:51	195,33	11,66
14.05.25	24,00	707	29,46	---	---	---	16:08	195,46	11,53
15.05.25	24,00	705	29,38	---	---	---	15:02	195,38	11,61
16.05.25	24,00	699	29,13	---	---	---	23:12	195,37	11,62
17.05.25	24,00	705	29,38	---	---	---	11:28	195,35	11,64
18.05.25	24,00	708	29,50	---	---	---	14:17	195,33	11,66
19.05.25	24,00	698	29,08	---	---	---	19:00	195,32	11,67
20.05.25	24,00	685	28,54	---	---	---	0:11	195,36	11,64
21.05.25	24,00	690	28,75	---	---	---	4:31	195,43	11,56
22.05.25	24,00	698	29,08	---	---	---	5:45	195,40	11,59
23.05.25	24,00	696	29,00	---	---	---	9:13	195,44	11,55
24.05.25	24,00	704	29,33	---	---	---	5:39	195,38	11,61
25.05.25	24,00	710	29,58	---	---	---	1:58	195,41	11,58
26.05.25	24,00	707	29,46	---	---	---	15:03	195,33	11,67
27.05.25	24,00	702	29,25	---	---	---	11:43	195,24	11,75
28.05.25	24,00	699	29,13	---	---	---	23:41	195,29	11,70
29.05.25	24,00	709	29,54	---	---	---	13:45	195,24	11,76
30.05.25	21,52	633	29,41	12:28	197,02	9,97	0:43	195,27	11,72
31.05.25	24,00	697	29,04	---	---	---	5:00	195,37	11,63
Σ	735,67	21.623							
Mittelwert	23,73	698	29,39		197,17	9,82		195,41	11,58
Minimum	19,86	597	28,54		197,02	9,72		195,24	11,39
Maximum	24,00	722	30,08		197,28	9,97		195,60	11,76

Meßpunkthöhe (MP): 206,99 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB07
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:17 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	1.294	53,92	---	---	---	0:29	194,71	7,96
02.05.25	24,00	1.297	54,04	---	---	---	0:42	194,76	7,91
03.05.25	24,00	1.298	54,08	---	---	---	1:29	194,77	7,90
04.05.25	24,00	1.299	54,13	---	---	---	15:30	194,79	7,88
05.05.25	24,00	1.295	53,96	---	---	---	15:03	194,78	7,89
06.05.25	22,27	1.203	54,02	13:46	196,84	5,83	22:47	194,74	7,93
07.05.25	24,00	1.295	53,96	---	---	---	21:53	194,68	7,99
08.05.25	24,00	1.293	53,88	---	---	---	12:59	194,66	8,01
09.05.25	24,00	1.293	53,88	---	---	---	6:45	194,71	7,96
10.05.25	24,00	1.295	53,96	---	---	---	16:04	194,62	8,05
11.05.25	24,00	1.298	54,08	---	---	---	8:41	194,60	8,07
12.05.25	24,00	1.291	53,79	---	---	---	0:31	194,62	8,05
13.05.25	19,49	1.055	54,14	11:29	196,93	5,74	6:51	194,66	8,01
14.05.25	24,00	1.293	53,88	---	---	---	16:17	194,66	8,01
15.05.25	24,00	1.292	53,83	---	---	---	14:58	194,60	8,07
16.05.25	24,00	1.290	53,75	---	---	---	9:23	194,56	8,11
17.05.25	24,00	1.292	53,83	---	---	---	11:21	194,56	8,11
18.05.25	24,00	1.294	53,92	---	---	---	13:43	194,54	8,13
19.05.25	24,00	1.290	53,75	---	---	---	19:04	194,53	8,14
20.05.25	24,00	1.285	53,54	---	---	---	0:00	194,56	8,11
21.05.25	24,00	1.287	53,63	---	---	---	0:45	194,60	8,07
22.05.25	24,00	1.289	53,71	---	---	---	4:53	194,60	8,07
23.05.25	24,00	1.289	53,71	---	---	---	6:16	194,62	8,05
24.05.25	24,00	1.292	53,83	---	---	---	3:42	194,62	8,05
25.05.25	24,00	1.294	53,92	---	---	---	1:55	194,63	8,04
26.05.25	24,00	1.293	53,88	---	---	---	20:01	194,54	8,13
27.05.25	24,00	1.290	53,75	---	---	---	11:44	194,50	8,17
28.05.25	24,00	1.290	53,75	---	---	---	23:54	194,49	8,18
29.05.25	24,00	1.293	53,88	---	---	---	14:06	194,46	8,21
30.05.25	21,51	1.159	53,89	12:29	196,62	6,05	3:36	194,49	8,18
31.05.25	24,00	1.289	53,71	---	---	---	22:29	194,57	8,10
Σ	735,26	39.607							
Mittelwert	23,72	1.278	53,87		196,79	5,88		194,62	8,05
Minimum	19,49	1.055	53,54		196,62	5,74		194,46	7,88
Maximum	24,00	1.299	54,14		196,93	6,05		194,79	8,21

Meßpunkthöhe (MP): 202,67 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB08
Monatsbericht vom Mai 2025
gedruckt am: 04.06.2025, 01:17 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.05.25	24,00	1.180	49,17	---	---	---	0:33	195,36	9,93
02.05.25	24,00	1.182	49,25	---	---	---	1:25	195,40	9,89
03.05.25	24,00	1.185	49,38	---	---	---	0:56	195,42	9,87
04.05.25	24,00	1.186	49,42	---	---	---	4:02	195,42	9,87
05.05.25	24,00	1.181	49,21	---	---	---	7:28	195,41	9,88
06.05.25	22,25	1.096	49,26	13:47	197,45	7,84	10:25	195,40	9,89
07.05.25	24,00	1.179	49,13	---	---	---	21:53	195,33	9,96
08.05.25	24,00	1.176	49,00	---	---	---	12:20	195,31	9,98
09.05.25	24,00	1.178	49,08	---	---	---	1:31	195,31	9,98
10.05.25	24,00	1.178	49,08	---	---	---	23:59	195,25	10,04
11.05.25	24,00	1.183	49,29	---	---	---	3:27	195,25	10,04
12.05.25	24,00	1.174	48,92	---	---	---	1:46	195,26	10,03
13.05.25	19,39	957	49,35	11:49	197,48	7,81	6:47	195,24	10,05
14.05.25	24,00	1.178	49,08	---	---	---	22:52	195,31	9,98
15.05.25	24,00	1.177	49,04	---	---	---	14:44	195,24	10,05
16.05.25	24,00	1.173	48,88	---	---	---	23:44	195,21	10,08
17.05.25	24,00	1.178	49,08	---	---	---	11:37	195,20	10,10
18.05.25	24,00	1.178	49,08	---	---	---	14:23	195,18	10,11
19.05.25	24,00	1.173	48,88	---	---	---	6:18	195,17	10,13
20.05.25	24,00	1.167	48,63	---	---	---	0:00	195,18	10,11
21.05.25	24,00	1.170	48,75	---	---	---	0:12	195,24	10,05
22.05.25	24,00	1.172	48,83	---	---	---	5:42	195,24	10,05
23.05.25	24,00	1.172	48,83	---	---	---	9:46	195,24	10,06
24.05.25	24,00	1.177	49,04	---	---	---	5:35	195,21	10,08
25.05.25	24,00	1.178	49,08	---	---	---	1:58	195,23	10,06
26.05.25	24,00	1.177	49,04	---	---	---	22:40	195,15	10,14
27.05.25	24,00	1.174	48,92	---	---	---	11:43	195,12	10,17
28.05.25	24,00	1.172	48,83	---	---	---	22:55	195,11	10,19
29.05.25	24,00	1.178	49,08	---	---	---	8:41	195,08	10,22
30.05.25	21,49	1.054	49,04	12:27	197,22	8,07	0:44	195,09	10,20
31.05.25	24,00	1.172	48,83	---	---	---	5:01	195,18	10,11
Σ	735,13	36.055							
Mittelwert	23,71	1.163	49,05		197,38	7,91		195,25	10,04
Minimum	19,39	957	48,63		197,22	7,81		195,08	9,87
Maximum	24,00	1.186	49,42		197,48	8,07		195,42	10,22

Meßpunkthöhe (MP): 205,29 m üNN