

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom Juni 2025
gedruckt am: 04.07.2025, 02:15 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.06.25	0,00	0	---	23:32	199,97	14,30	---	---	---
02.06.25	0,00	0	---	5:50	200,03	14,24	---	---	---
03.06.25	0,83	86	103,51	7:20	199,95	14,32	---	---	---
04.06.25	2,05	211	103,07	4:00	199,92	14,35	9:11	195,33	18,94
05.06.25	1,19	122	102,23	5:36	199,86	14,41	23:19	195,38	18,89
06.06.25	0,00	0	---	6:50	199,94	14,33	---	---	---
07.06.25	17,51	1.803	102,96	4:32	199,91	14,36	22:48	194,56	19,72
08.06.25	24,00	2.470	102,92	---	---	---	23:28	194,43	19,85
09.06.25	24,00	2.474	103,08	---	---	---	21:49	194,39	19,88
10.06.25	23,84	2.442	102,41	---	---	---	21:26	194,31	19,96
11.06.25	24,00	2.454	102,25	---	---	---	19:32	194,17	20,11
12.06.25	24,00	2.451	102,13	---	---	---	23:53	194,11	20,16
13.06.25	24,00	2.441	101,71	---	---	---	23:59	194,04	20,24
14.06.25	24,00	2.448	102,00	---	---	---	20:13	193,96	20,31
15.06.25	24,00	2.463	102,63	---	---	---	1:08	194,05	20,22
16.06.25	24,00	2.456	102,33	---	---	---	23:51	193,98	20,30
17.06.25	14,72	1.506	102,32	14:31	199,14	15,14	0:00	193,98	20,30
18.06.25	12,84	1.308	101,85	8:53	199,39	14,88	22:43	194,15	20,12
19.06.25	24,00	2.447	101,96	---	---	---	18:37	193,96	20,31
20.06.25	22,81	2.332	102,25	23:59	198,39	15,88	19:04	193,96	20,31
21.06.25	1,93	197	102,22	19:26	199,18	15,09	---	---	---
22.06.25	0,00	0	---	22:20	199,41	14,86	---	---	---
23.06.25	1,17	120	102,52	5:02	199,47	14,80	17:17	195,11	19,17
24.06.25	6,20	640	103,29	6:36	199,36	14,91	11:29	194,45	19,82
25.06.25	5,74	585	101,96	7:54	199,36	14,91	23:59	194,63	19,65
26.06.25	5,31	539	101,53	10:11	199,55	14,72	0:29	194,56	19,71
27.06.25	2,63	271	102,86	5:57	199,25	15,02	---	---	---
28.06.25	2,18	222	101,65	8:48	199,30	14,98	21:25	194,98	19,29
29.06.25	15,88	1.628	102,50	5:59	199,27	15,01	23:47	194,18	20,09
30.06.25	10,40	1.064	102,29	23:29	199,27	15,01	0:00	194,20	20,08
Σ	363,24	37.180							
Mittelwert	12,11	1.239	102,36		199,49	14,78		194,38	19,89
Minimum	0,00	0	101,53		198,39	14,24		193,96	18,89
Maximum	24,00	2.474	103,51		200,03	15,88		195,38	20,31

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom Juni 2025
gedruckt am: 04.07.2025, 02:15 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.06.25	17,38	2.498	143,76	23:33	200,97	13,25	0:46	195,70	18,52
02.06.25	13,28	1.851	139,35	5:42	201,07	13,15	16:59	195,98	18,24
03.06.25	15,01	2.084	138,88	7:24	200,93	13,29	22:51	195,94	18,28
04.06.25	17,53	2.453	139,91	3:57	200,85	13,38	9:03	195,84	18,38
05.06.25	17,18	2.376	138,31	5:33	200,75	13,48	19:57	195,91	18,31
06.06.25	14,54	2.025	139,29	6:49	200,89	13,33	0:06	195,86	18,36
07.06.25	10,52	1.422	135,15	4:34	200,83	13,39	0:27	195,92	18,30
08.06.25	7,61	1.017	133,73	10:04	200,68	13,54	18:42	195,99	18,23
09.06.25	6,93	928	133,88	9:27	200,92	13,31	21:43	195,89	18,34
10.06.25	13,45	1.789	132,98	5:32	200,52	13,70	9:00	195,46	18,76
11.06.25	14,76	1.949	132,03	4:10	200,30	13,93	15:08	195,63	18,59
12.06.25	16,19	2.124	131,18	4:49	200,29	13,93	23:41	195,56	18,67
13.06.25	19,41	2.521	129,89	11:23	199,98	14,24	1:42	195,42	18,80
14.06.25	16,54	2.155	130,30	7:06	199,85	14,37	0:44	195,32	18,90
15.06.25	9,25	1.219	131,77	11:13	200,19	14,03	14:38	195,55	18,67
16.06.25	13,53	1.774	131,16	6:56	200,43	13,80	23:48	195,40	18,82
17.06.25	16,04	2.156	134,39	14:27	200,41	13,81	11:53	195,45	18,77
18.06.25	19,71	2.615	132,67	3:50	200,25	13,97	0:48	195,43	18,79
19.06.25	16,46	2.141	130,11	6:09	199,85	14,37	2:16	195,34	18,88
20.06.25	13,50	1.776	131,52	7:20	200,04	14,18	22:57	195,30	18,93
21.06.25	24,00	3.339	139,13	---	---	---	0:29	195,14	19,09
22.06.25	23,76	3.344	140,74	---	---	---	1:37	195,41	18,81
23.06.25	24,00	3.335	138,96	---	---	---	14:41	195,49	18,74
24.06.25	24,00	3.322	138,42	---	---	---	9:52	195,21	19,01
25.06.25	24,00	3.267	136,13	---	---	---	1:04	195,43	18,80
26.06.25	21,57	2.921	135,40	10:09	200,57	13,65	0:44	195,42	18,80
27.06.25	24,00	3.272	136,33	---	---	---	21:59	195,26	18,96
28.06.25	24,00	3.304	137,67	---	---	---	0:57	195,26	18,96
29.06.25	17,03	2.297	134,91	12:08	200,12	14,10	2:27	195,32	18,90
30.06.25	16,99	2.283	134,37	6:21	200,23	13,99	11:25	195,60	18,62
Σ	512,17	69.557							
Mittelwert	17,07	2.319	135,81		200,47	13,75		195,55	18,67
Minimum	6,93	928	129,89		199,85	13,15		195,14	18,23
Maximum	24,00	3.344	143,76		201,07	14,37		195,99	19,09

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom Juni 2025
gedruckt am: 04.07.2025, 02:15 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.06.25	9,32	881	94,58	9:43	200,94	19,18	0:37	198,23	21,89
02.06.25	24,00	2.264	94,33	---	---	---	22:31	198,26	21,87
03.06.25	24,00	2.253	93,88	---	---	---	22:52	198,21	21,91
04.06.25	20,57	1.923	93,49	12:01	200,78	19,34	22:08	198,21	21,91
05.06.25	24,00	2.241	93,38	---	---	---	19:59	198,17	21,95
06.06.25	24,00	2.255	93,96	---	---	---	0:07	198,16	21,97
07.06.25	24,00	2.239	93,29	---	---	---	22:41	198,13	22,00
08.06.25	23,47	2.189	93,28	---	---	---	18:43	198,10	22,02
09.06.25	20,85	1.946	93,34	9:24	200,95	19,17	21:45	198,03	22,09
10.06.25	23,69	2.180	92,02	---	---	---	21:23	197,92	22,20
11.06.25	24,00	2.198	91,58	---	---	---	19:28	197,74	22,39
12.06.25	24,00	2.189	91,21	---	---	---	23:57	197,66	22,46
13.06.25	23,33	2.103	90,14	---	---	---	1:44	197,52	22,60
14.06.25	24,00	2.180	90,83	---	---	---	20:09	197,40	22,72
15.06.25	24,00	2.221	92,54	---	---	---	1:02	197,60	22,52
16.06.25	21,87	2.000	91,45	6:54	200,42	19,70	23:49	197,48	22,64
17.06.25	19,57	1.793	91,61	14:28	200,34	19,78	0:00	197,51	22,61
18.06.25	24,00	2.190	91,25	---	---	---	23:54	197,60	22,52
19.06.25	24,00	2.179	90,79	---	---	---	18:32	197,42	22,71
20.06.25	24,00	2.200	91,67	---	---	---	18:56	197,48	22,64
21.06.25	11,67	1.069	91,57	10:01	200,16	19,96	0:00	197,50	22,62
22.06.25	10,44	961	92,08	10:41	200,41	19,72	1:27	197,87	22,26
23.06.25	17,79	1.643	92,36	5:48	200,51	19,61	23:51	197,81	22,31
24.06.25	15,40	1.414	91,81	6:12	200,25	19,88	9:49	197,74	22,38
25.06.25	18,52	1.688	91,13	7:59	200,28	19,84	20:49	197,77	22,35
26.06.25	18,10	1.648	91,06	10:10	200,51	19,61	7:49	197,61	22,51
27.06.25	20,66	1.891	91,53	6:06	200,06	20,06	21:38	197,68	22,45
28.06.25	16,47	1.507	91,52	8:36	200,23	19,89	0:38	197,71	22,41
29.06.25	20,59	1.888	91,67	6:12	200,15	19,97	23:43	197,65	22,47
30.06.25	15,45	1.414	91,53	23:53	200,24	19,88	11:26	197,67	22,45
Σ	615,75	56.747							
Mittelwert	20,53	1.892	92,16		200,41	19,71		197,79	22,33
Minimum	9,32	881	90,14		200,06	19,17		197,40	21,87
Maximum	24,00	2.264	94,58		200,95	20,06		198,26	22,72

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom Juni 2025
gedruckt am: 04.07.2025, 02:15 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.06.25	9,43	1.027	108,91	12:31	203,48	17,90	0:45	199,24	22,14
02.06.25	24,00	2.589	107,88	---	---	---	22:45	199,02	22,36
03.06.25	24,00	2.549	106,21	---	---	---	23:14	198,85	22,53
04.06.25	20,48	2.153	105,15	11:59	203,37	18,01	0:01	198,95	22,43
05.06.25	24,00	2.510	104,58	---	---	---	20:10	198,82	22,56
06.06.25	24,00	2.554	106,42	---	---	---	0:24	198,73	22,66
07.06.25	24,00	2.476	103,17	---	---	---	22:57	198,52	22,86
08.06.25	23,53	2.404	102,18	---	---	---	23:53	198,38	23,00
09.06.25	20,91	2.143	102,50	9:25	203,08	18,30	22:00	198,38	23,01
10.06.25	23,74	2.325	97,93	---	---	---	21:44	198,05	23,33
11.06.25	24,00	2.296	95,67	---	---	---	19:45	197,73	23,66
12.06.25	24,00	2.261	94,21	---	---	---	16:03	197,63	23,75
13.06.25	23,39	2.117	90,51	---	---	---	10:25	197,30	24,08
14.06.25	24,00	2.218	92,42	---	---	---	20:23	197,08	24,30
15.06.25	24,00	2.355	98,13	---	---	---	1:19	197,28	24,10
16.06.25	21,93	2.082	94,94	6:56	202,40	18,98	23:59	197,31	24,08
17.06.25	19,48	1.878	96,42	14:48	202,65	18,73	0:11	197,30	24,08
18.06.25	24,00	2.294	95,58	---	---	---	0:59	197,71	23,67
19.06.25	24,00	2.225	92,71	---	---	---	19:02	197,15	24,24
20.06.25	24,00	2.287	95,29	---	---	---	0:00	197,24	24,15
21.06.25	12,03	1.181	98,21	9:51	202,43	18,95	0:29	197,39	23,99
22.06.25	10,74	1.087	101,23	10:39	202,82	18,56	1:32	198,44	22,95
23.06.25	17,96	1.825	101,62	5:46	202,95	18,43	23:54	198,41	22,97
24.06.25	15,64	1.567	100,19	11:55	203,01	18,37	1:38	198,30	23,08
25.06.25	18,76	1.822	97,12	7:57	202,67	18,71	21:53	198,39	22,99
26.06.25	18,23	1.755	96,26	10:10	202,77	18,61	7:48	198,02	23,37
27.06.25	20,89	2.049	98,07	---	---	---	21:54	198,11	23,27
28.06.25	16,70	1.644	98,44	8:46	202,62	18,76	22:56	198,20	23,18
29.06.25	20,77	2.025	97,48	6:07	202,48	18,91	23:56	197,69	23,69
30.06.25	24,00	2.279	94,96	---	---	---	14:30	197,36	24,02
Σ	626,60	61.977							
Mittelwert	20,89	2.066	98,91		202,82	18,56		198,03	23,35
Minimum	9,43	1.027	90,51		202,40	17,90		197,08	22,14
Maximum	24,00	2.589	108,91		203,48	18,98		199,24	24,30

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom Juni 2025
gedruckt am: 04.07.2025, 02:15 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.06.25	17,47	1.728	98,90	23:32	205,22	20,63	0:58	200,05	25,80
02.06.25	13,38	1.293	96,67	6:00	205,55	20,30	22:31	200,65	25,19
03.06.25	15,12	1.457	96,35	7:20	205,39	20,45	22:52	200,48	25,36
04.06.25	17,19	1.665	96,84	3:58	205,17	20,67	22:07	200,48	25,36
05.06.25	17,28	1.660	96,08	5:31	205,02	20,82	23:44	200,41	25,44
06.06.25	14,66	1.415	96,55	6:49	205,28	20,57	0:06	200,26	25,58
07.06.25	10,67	991	92,89	4:31	205,20	20,64	22:40	199,69	26,16
08.06.25	7,69	702	91,31	11:16	204,16	21,68	18:43	199,62	26,22
09.06.25	7,00	641	91,51	9:22	204,60	21,24	21:44	199,43	26,41
10.06.25	12,71	1.154	90,82	11:15	204,02	21,83	21:22	199,18	26,66
11.06.25	14,89	1.350	90,65	4:09	203,47	22,37	19:22	199,02	26,83
12.06.25	16,25	1.469	90,40	4:51	203,39	22,45	14:53	199,02	26,83
13.06.25	19,47	1.750	89,86	11:22	202,85	22,99	0:16	199,03	26,81
14.06.25	16,65	1.496	89,86	7:06	202,57	23,28	3:10	199,03	26,81
15.06.25	9,33	844	90,43	11:16	203,25	22,60	13:45	199,02	26,82
16.06.25	13,61	1.230	90,38	7:01	203,67	22,17	14:45	199,03	26,81
17.06.25	15,29	1.421	92,95	14:25	204,27	21,57	8:00	199,03	26,81
18.06.25	19,79	1.827	92,31	3:50	203,96	21,89	19:01	199,03	26,81
19.06.25	16,55	1.489	89,96	6:11	202,71	23,13	0:54	199,03	26,81
20.06.25	13,60	1.234	90,77	7:27	203,03	22,81	16:49	199,03	26,81
21.06.25	24,00	2.314	96,42	---	---	---	0:00	199,04	26,80
22.06.25	23,78	2.318	97,50	---	---	---	1:39	199,40	26,44
23.06.25	24,00	2.326	96,92	---	---	---	18:01	199,51	26,33
24.06.25	21,21	2.044	96,36	11:36	204,64	21,20	1:41	199,40	26,45
25.06.25	24,00	2.279	94,96	---	---	---	20:42	199,29	26,55
26.06.25	21,70	2.050	94,48	10:09	204,35	21,50	0:36	199,04	26,80
27.06.25	24,00	2.284	95,17	---	---	---	21:57	199,21	26,63
28.06.25	24,00	2.302	95,92	---	---	---	0:56	199,19	26,65
29.06.25	17,12	1.600	93,49	12:01	203,50	22,34	19:28	199,04	26,80
30.06.25	17,04	1.547	90,77	4:16	203,28	22,56	9:04	199,04	26,80
Σ	509,44	47.880							
Mittelwert	16,98	1.596	93,99		204,10	21,74		199,42	26,42
Minimum	7,00	641	89,86		202,57	20,30		199,02	25,19
Maximum	24,00	2.326	98,90		205,55	23,28		200,65	26,83

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom Juni 2025
gedruckt am: 04.07.2025, 02:15 Uhr in Stadtallendorf

Tag	Förderdaten			Abtutung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.06.25	0,00	0	---	23:35	206,03	25,39	---	---	---
02.06.25	0,00	0	---	6:02	206,43	24,99	---	---	---
03.06.25	0,88	86	97,54	7:24	206,23	25,19	---	---	---
04.06.25	1,35	134	99,28	4:01	205,92	25,49	---	---	---
05.06.25	1,24	120	96,64	5:39	205,78	25,63	23:20	197,08	34,33
06.06.25	0,00	0	---	6:57	206,04	25,37	---	---	---
07.06.25	17,54	1.808	103,10	4:46	205,97	25,45	22:57	194,66	36,76
08.06.25	24,00	2.494	103,92	---	---	---	19:02	194,57	36,85
09.06.25	24,00	2.513	104,71	---	---	---	22:09	194,34	37,08
10.06.25	22,92	2.299	100,30	---	---	---	21:40	194,14	37,28
11.06.25	24,00	2.391	99,63	---	---	---	19:59	193,80	37,61
12.06.25	24,00	2.368	98,67	---	---	---	16:04	193,76	37,66
13.06.25	24,00	2.318	96,58	---	---	---	10:28	193,33	38,08
14.06.25	24,00	2.350	97,92	---	---	---	1:05	193,16	38,25
15.06.25	24,00	2.453	102,21	---	---	---	0:00	193,50	37,92
16.06.25	24,00	2.407	100,29	---	---	---	23:59	193,41	38,01
17.06.25	12,98	1.288	99,22	14:48	204,73	26,68	0:16	193,39	38,02
18.06.25	12,96	1.244	95,96	8:55	204,82	26,59	14:51	194,60	36,82
19.06.25	24,00	2.356	98,17	---	---	---	23:11	193,42	37,99
20.06.25	22,83	2.284	100,05	23:59	202,61	28,80	0:00	193,53	37,89
21.06.25	2,07	200	96,59	10:40	204,21	27,20	---	---	---
22.06.25	0,00	0	---	11:03	204,69	26,73	---	---	---
23.06.25	1,22	121	99,34	5:44	204,82	26,59	17:20	195,91	35,51
24.06.25	2,90	284	97,87	12:01	205,25	26,16	---	---	---
25.06.25	5,93	569	96,03	8:09	204,62	26,79	23:58	195,53	35,89
26.06.25	5,47	523	95,56	10:30	204,84	26,58	0:32	195,38	36,04
27.06.25	2,80	272	97,01	7:04	204,33	27,08	---	---	---
28.06.25	2,30	220	95,48	9:19	204,47	26,94	21:26	196,06	35,35
29.06.25	15,91	1.600	100,59	6:53	204,37	27,05	23:55	193,94	37,47
30.06.25	24,00	2.373	98,88	---	---	---	14:28	193,59	37,82
Σ	371,31	37.075							
Mittelwert	12,38	1.236	99,85		205,06	26,35		194,34	37,07
Minimum	0,00	0	95,48		202,61	24,99		193,16	34,33
Maximum	24,00	2.513	104,71		206,43	28,80		197,08	38,25

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom Juni 2025
gedruckt am: 04.07.2025, 02:15 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.06.25	17,09	1.604	93,83	23:37	212,10	19,95	0:54	203,29	28,76
02.06.25	13,02	1.211	92,99	6:01	212,90	19,16	22:29	204,73	27,32
03.06.25	14,67	1.360	92,71	7:24	212,39	19,66	18:36	204,50	27,55
04.06.25	16,45	1.528	92,91	4:01	211,92	20,14	22:06	204,32	27,74
05.06.25	16,90	1.563	92,50	5:34	211,57	20,49	2:02	204,41	27,64
06.06.25	14,20	1.317	92,74	6:53	212,30	19,75	0:04	204,52	27,54
07.06.25	10,13	906	89,40	10:40	212,29	19,77	0:22	204,64	27,42
08.06.25	7,37	650	88,20	11:37	212,36	19,69	18:41	205,42	26,64
09.06.25	6,71	592	88,18	11:14	212,72	19,34	21:40	204,67	27,39
10.06.25	14,18	1.241	87,55	5:39	211,90	20,15	10:52	204,32	27,74
11.06.25	14,40	1.259	87,44	4:14	211,26	20,79	19:22	204,00	28,06
12.06.25	16,00	1.388	86,77	4:56	211,55	20,50	23:43	203,32	28,73
13.06.25	19,21	1.655	86,13	5:18	210,19	21,86	23:15	203,05	29,01
14.06.25	16,24	1.404	86,43	23:58	210,10	21,96	0:36	203,03	29,02
15.06.25	9,02	793	87,96	11:11	211,84	20,21	19:31	204,35	27,71
16.06.25	13,29	1.160	87,27	8:56	212,03	20,03	23:48	203,45	28,61
17.06.25	16,77	1.507	89,85	14:28	210,85	21,21	22:58	203,43	28,62
18.06.25	19,47	1.724	88,56	3:53	210,60	21,45	23:59	203,25	28,81
19.06.25	16,21	1.399	86,33	6:13	210,19	21,86	2:12	203,14	28,92
20.06.25	13,24	1.159	87,54	7:29	211,41	20,64	23:59	203,17	28,89
21.06.25	24,00	2.202	91,75	---	---	---	0:32	203,00	29,05
22.06.25	23,71	2.198	92,70	---	---	---	2:09	203,00	29,05
23.06.25	24,00	2.243	93,46	---	---	---	14:59	203,00	29,05
24.06.25	20,76	1.921	92,53	11:37	211,28	20,78	0:00	203,00	29,05
25.06.25	24,00	2.167	90,29	---	---	---	2:14	203,18	28,87
26.06.25	21,67	1.953	90,13	10:11	210,71	21,34	7:49	203,00	29,05
27.06.25	24,00	2.175	90,63	---	---	---	21:57	203,00	29,05
28.06.25	24,00	2.179	90,79	---	---	---	0:58	203,00	29,05
29.06.25	16,74	1.496	89,39	21:00	210,67	21,39	3:07	203,00	29,05
30.06.25	16,81	1.469	87,37	4:20	211,44	20,61	23:06	203,00	29,05
Σ	504,26	45.423							
Mittelwert	16,81	1.514	90,08		211,52	20,53		203,64	28,41
Minimum	6,71	592	86,13		210,10	19,16		203,00	26,64
Maximum	24,00	2.243	93,83		212,90	21,96		205,42	29,05

Meßpunkthöhe (MP): 232,05 m üNN