

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom Juli 2025
gedruckt am: 03.08.2025, 18:09 Uhr in Stadtallendorf

Tag	Förderdaten			Abtutung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.07.25	23,80	2.424	101,86	---	---	---	23:10	194,18	20,09
02.07.25	24,00	2.436	101,50	---	---	---	23:05	194,04	20,24
03.07.25	24,00	2.437	101,54	---	---	---	4:06	193,88	20,40
04.07.25	24,00	2.445	101,88	---	---	---	21:48	193,79	20,48
05.07.25	24,00	2.461	102,54	---	---	---	1:28	193,82	20,46
06.07.25	24,00	2.475	103,13	---	---	---	1:05	194,09	20,18
07.07.25	24,00	2.466	102,75	---	---	---	22:54	194,30	19,97
08.07.25	21,24	2.169	102,13	11:33	199,16	15,11	23:54	194,21	20,06
09.07.25	24,00	2.456	102,33	---	---	---	23:39	194,09	20,18
10.07.25	24,00	2.448	102,00	---	---	---	18:39	194,01	20,27
11.07.25	24,00	2.451	102,13	---	---	---	22:48	194,01	20,27
12.07.25	24,00	2.458	102,42	---	---	---	2:08	194,07	20,20
13.07.25	24,00	2.466	102,75	---	---	---	22:58	194,17	20,11
14.07.25	24,00	2.450	102,08	---	---	---	23:58	194,01	20,26
15.07.25	9,67	989	102,23	16:48	199,11	15,17	0:00	194,02	20,25
16.07.25	0,00	0	---	12:02	199,14	15,14	---	---	---
17.07.25	1,74	177	101,46	6:10	199,30	14,98	---	---	---
18.07.25	0,93	95	101,73	15:22	199,12	15,15	---	---	---
19.07.25	2,29	233	101,66	11:24	199,12	15,15	13:48	194,75	19,52
20.07.25	0,00	0	---	16:17	199,14	15,14	---	---	---
21.07.25	0,00	0	---	16:07	199,30	14,98	---	---	---
22.07.25	2,67	276	103,21	7:46	199,28	14,99	10:00	194,76	19,51
23.07.25	17,36	1.777	102,34	0:56	199,15	15,12	23:49	194,20	20,08
24.07.25	24,00	2.452	102,17	---	---	---	12:23	194,14	20,14
25.07.25	24,00	2.456	102,33	---	---	---	15:44	193,98	20,29
26.07.25	24,00	2.468	102,83	---	---	---	3:36	194,02	20,25
27.07.25	24,00	2.481	103,38	---	---	---	0:34	194,17	20,11
28.07.25	24,00	2.469	102,88	---	---	---	20:50	194,14	20,14
29.07.25	20,84	2.144	102,89	12:07	199,44	14,83	1:36	194,20	20,07
30.07.25	24,00	2.468	102,83	---	---	---	15:17	194,15	20,12
31.07.25	24,00	2.465	102,71	---	---	---	23:46	194,14	20,14
Σ	556,55	56.992							
Mittelwert	17,95	1.838	102,40		199,20	15,07		194,13	20,14
Minimum	0,00	0	101,46		199,11	14,83		193,79	19,51
Maximum	24,00	2.481	103,38		199,44	15,17		194,76	20,48

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom Juli 2025
gedruckt am: 03.08.2025, 18:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.07.25	19,94	2.661	133,42	6:01	200,52	13,70	22:41	195,57	18,65
02.07.25	22,23	2.947	132,54	4:44	200,31	13,91	22:59	195,35	18,87
03.07.25	19,79	2.622	132,51	14:55	200,14	14,08	4:00	195,14	19,08
04.07.25	19,03	2.515	132,14	6:01	199,90	14,32	1:47	195,09	19,13
05.07.25	13,67	1.831	133,93	23:58	200,12	14,10	1:19	195,14	19,08
06.07.25	8,13	1.109	136,43	9:47	200,63	13,59	16:38	195,84	18,38
07.07.25	10,09	1.383	137,13	9:22	200,92	13,31	12:30	195,92	18,30
08.07.25	16,04	2.198	137,03	14:23	200,72	13,50	8:29	195,58	18,64
09.07.25	12,30	1.661	135,09	8:11	200,66	13,57	0:32	195,60	18,62
10.07.25	16,41	2.199	134,04	5:49	200,44	13,78	18:37	195,40	18,82
11.07.25	14,45	1.934	133,88	9:17	200,39	13,83	22:44	195,45	18,77
12.07.25	11,20	1.512	134,96	23:58	200,67	13,55	2:04	195,58	18,64
13.07.25	8,21	1.117	135,98	12:38	201,05	13,17	22:56	195,68	18,54
14.07.25	15,03	2.020	134,42	7:05	200,77	13,45	23:55	195,48	18,74
15.07.25	18,88	2.577	136,50	4:52	200,46	13,76	23:44	195,44	18,78
16.07.25	24,00	3.292	137,17	---	---	---	23:58	195,37	18,85
17.07.25	23,10	3.164	136,95	---	---	---	4:51	195,27	18,95
18.07.25	24,00	3.274	136,42	---	---	---	21:59	195,30	18,92
19.07.25	24,00	3.264	136,00	---	---	---	20:02	195,28	18,94
20.07.25	24,00	3.312	138,00	---	---	---	0:53	195,30	18,93
21.07.25	23,18	3.204	138,24	---	---	---	14:06	195,26	18,96
22.07.25	21,66	2.971	137,14	10:13	200,30	13,93	7:08	195,26	18,96
23.07.25	15,58	2.112	135,59	13:38	200,59	13,63	6:33	195,27	18,95
24.07.25	13,76	1.845	134,12	18:12	200,38	13,84	12:17	195,57	18,65
25.07.25	15,61	2.092	133,99	7:55	200,52	13,70	15:40	195,37	18,85
26.07.25	11,11	1.502	135,22	22:37	200,54	13,68	3:32	195,50	18,72
27.07.25	5,31	725	136,41	12:19	200,91	13,31	0:30	195,79	18,43
28.07.25	12,25	1.662	135,67	4:53	201,04	13,19	20:46	195,69	18,53
29.07.25	10,20	1.396	136,90	12:12	201,05	13,18	8:39	195,96	18,26
30.07.25	12,73	1.729	135,80	6:03	200,84	13,38	15:09	195,69	18,54
31.07.25	12,77	1.729	135,43	9:23	200,79	13,43	23:41	195,68	18,54
Σ	498,65	67.559							
Mittelwert	16,09	2.179	135,48		200,59	13,63		195,48	18,74
Minimum	5,31	725	132,14		199,90	13,17		195,09	18,26
Maximum	24,00	3.312	138,24		201,05	14,32		195,96	19,13

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom Juli 2025
gedruckt am: 03.08.2025, 18:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.07.25	6,58	592	89,97	6:01	200,60	19,53	22:34	197,85	22,27
02.07.25	10,49	941	89,73	4:45	200,41	19,71	23:06	197,53	22,59
03.07.25	16,94	1.528	90,21	14:53	200,21	19,92	23:44	197,39	22,73
04.07.25	18,79	1.699	90,40	6:03	199,95	20,17	1:43	197,36	22,77
05.07.25	13,31	1.211	90,96	23:58	200,17	19,95	1:18	197,42	22,71
06.07.25	7,75	710	91,63	9:46	200,68	19,44	16:37	198,18	21,94
07.07.25	5,05	461	91,25	9:25	200,98	19,14	12:29	198,27	21,85
08.07.25	9,72	891	91,70	14:24	200,81	19,31	23:57	198,00	22,13
09.07.25	11,90	1.084	91,08	8:13	200,74	19,38	0:27	197,95	22,17
10.07.25	16,09	1.463	90,93	5:50	200,53	19,59	18:27	197,73	22,39
11.07.25	14,15	1.283	90,70	9:18	200,47	19,65	22:35	197,77	22,35
12.07.25	10,81	985	91,10	23:55	200,73	19,39	2:03	197,90	22,22
13.07.25	8,05	736	91,37	12:36	201,13	18,99	22:51	198,06	22,06
14.07.25	14,79	1.345	90,96	7:05	200,85	19,27	23:49	197,83	22,29
15.07.25	18,59	1.706	91,79	4:52	200,53	19,59	23:53	197,77	22,35
16.07.25	24,00	2.211	92,13	---	---	---	23:54	197,71	22,42
17.07.25	23,00	2.118	92,07	---	---	---	23:51	197,67	22,45
18.07.25	24,00	2.207	91,96	---	---	---	21:58	197,63	22,49
19.07.25	24,00	2.202	91,75	---	---	---	20:02	197,61	22,51
20.07.25	24,00	2.222	92,58	---	---	---	1:20	197,61	22,51
21.07.25	23,08	2.140	92,72	---	---	---	6:58	197,64	22,48
22.07.25	21,52	1.980	92,03	10:15	200,38	19,75	6:58	197,68	22,44
23.07.25	15,03	1.374	91,42	13:34	200,66	19,47	4:05	197,71	22,42
24.07.25	13,39	1.218	90,94	18:17	200,46	19,66	15:48	197,87	22,25
25.07.25	15,34	1.396	91,02	7:53	200,59	19,53	15:34	197,69	22,43
26.07.25	10,78	985	91,37	22:39	200,62	19,50	3:25	197,83	22,29
27.07.25	5,11	468	91,66	12:14	200,99	19,14	0:30	198,14	21,98
28.07.25	11,97	1.096	91,59	5:00	201,13	18,99	20:40	198,06	22,07
29.07.25	9,42	865	91,81	13:09	201,07	19,05	23:58	198,28	21,84
30.07.25	12,36	1.132	91,59	6:05	200,93	19,19	15:02	198,09	22,03
31.07.25	12,42	1.136	91,44	9:22	200,88	19,24	23:39	198,05	22,07
Σ	452,43	41.385							
Mittelwert	14,59	1.335	91,47		200,66	19,46		197,81	22,31
Minimum	5,05	461	89,73		199,95	18,99		197,36	21,84
Maximum	24,00	2.222	92,72		201,13	20,17		198,28	22,77

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom Juli 2025
gedruckt am: 03.08.2025, 18:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.07.25	24,00	2.211	92,13	---	---	---	2:37	197,02	24,36
02.07.25	24,00	2.169	90,38	---	---	---	3:19	196,80	24,58
03.07.25	24,00	2.251	93,79	---	---	---	4:22	196,58	24,80
04.07.25	24,00	2.265	94,38	---	---	---	2:02	196,67	24,71
05.07.25	24,00	2.359	98,29	---	---	---	1:44	196,76	24,63
06.07.25	23,32	2.385	102,27	---	---	---	0:00	197,15	24,24
07.07.25	22,94	2.349	102,39	6:02	202,31	19,07	23:05	197,44	23,94
08.07.25	20,98	2.087	99,47	11:33	202,56	18,82	8:25	197,41	23,97
09.07.25	23,23	2.337	100,60	---	---	---	23:44	197,43	23,95
10.07.25	24,00	2.349	97,88	---	---	---	18:50	197,24	24,15
11.07.25	24,00	2.369	98,71	---	---	---	22:55	197,27	24,11
12.07.25	24,00	2.415	100,63	---	---	---	2:18	197,32	24,06
13.07.25	22,38	2.314	103,39	---	---	---	23:13	197,60	23,78
14.07.25	23,04	2.286	99,20	---	---	---	23:59	197,44	23,94
15.07.25	18,54	1.835	98,99	10:46	202,56	18,82	0:09	197,40	23,99
16.07.25	14,82	1.486	100,25	5:31	202,65	18,73	22:40	198,64	22,74
17.07.25	12,30	1.224	99,49	9:58	202,93	18,45	23:49	198,91	22,47
18.07.25	16,33	1.632	99,93	9:57	202,70	18,68	20:35	198,60	22,79
19.07.25	15,76	1.552	98,48	7:09	202,71	18,67	14:49	198,60	22,79
20.07.25	8,69	882	101,44	23:55	202,91	18,47	2:27	199,05	22,34
21.07.25	7,84	803	102,43	16:18	203,27	18,11	23:59	199,40	21,98
22.07.25	12,51	1.267	101,31	10:21	203,28	18,10	3:08	199,21	22,17
23.07.25	20,06	2.071	103,23	4:06	202,93	18,45	23:59	198,05	23,34
24.07.25	24,00	2.409	100,38	---	---	---	16:03	197,77	23,61
25.07.25	24,00	2.383	99,29	---	---	---	15:58	197,44	23,94
26.07.25	23,54	2.395	101,73	---	---	---	3:46	197,47	23,91
27.07.25	23,53	2.482	105,47	---	---	---	0:50	197,69	23,69
28.07.25	22,71	2.314	101,88	3:44	202,70	18,68	20:55	197,74	23,64
29.07.25	19,81	2.034	102,65	12:25	203,09	18,29	1:47	197,81	23,57
30.07.25	22,59	2.297	101,67	10:17	202,48	18,90	22:45	197,86	23,53
31.07.25	24,00	2.432	101,33	---	---	---	23:55	197,66	23,72
Σ	638,95	63.644							
Mittelwert	20,61	2.053	99,61		202,79	18,59		197,72	23,66
Minimum	7,84	803	90,38		202,31	18,10		196,58	21,98
Maximum	24,00	2.482	105,47		203,28	19,07		199,40	24,80

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom Juli 2025
gedruckt am: 03.08.2025, 18:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.07.25	19,74	1.782	90,29	9:27	202,56	23,28	10:38	199,03	26,81
02.07.25	22,25	2.011	90,37	4:45	202,18	23,67	0:00	199,04	26,80
03.07.25	19,86	1.832	92,26	14:54	202,33	23,51	0:00	199,04	26,80
04.07.25	19,12	1.770	92,59	6:01	202,31	23,53	0:00	199,04	26,80
05.07.25	13,80	1.285	93,15	23:55	202,64	23,20	6:59	199,03	26,81
06.07.25	8,27	776	93,89	23:58	203,32	22,53	5:06	199,04	26,80
07.07.25	10,17	953	93,72	6:58	203,75	22,09	17:30	199,04	26,80
08.07.25	15,93	1.499	94,11	14:15	203,80	22,04	21:37	199,02	26,82
09.07.25	12,44	1.163	93,49	7:51	203,54	22,30	12:16	199,02	26,82
10.07.25	16,52	1.539	93,19	5:46	203,17	22,67	2:20	199,02	26,82
11.07.25	14,56	1.353	92,95	9:14	203,11	22,73	10:29	199,03	26,81
12.07.25	11,34	1.059	93,38	23:49	203,39	22,45	1:44	199,03	26,81
13.07.25	8,27	776	93,79	12:21	203,97	21,87	22:19	199,02	26,82
14.07.25	15,18	1.416	93,28	7:01	203,64	22,20	1:03	199,03	26,81
15.07.25	18,43	1.749	94,89	9:52	204,00	21,84	6:35	199,02	26,82
16.07.25	24,00	2.306	96,08	---	---	---	23:08	199,66	26,19
17.07.25	23,13	2.224	96,13	---	---	---	23:54	199,65	26,19
18.07.25	24,00	2.302	95,92	---	---	---	20:51	199,57	26,27
19.07.25	24,00	2.292	95,50	---	---	---	15:05	199,42	26,42
20.07.25	24,00	2.328	97,00	---	---	---	0:00	199,71	26,13
21.07.25	23,21	2.261	97,41	---	---	---	2:16	200,15	25,69
22.07.25	21,38	2.055	96,11	10:12	204,96	20,88	3:36	199,99	25,85
23.07.25	15,65	1.487	95,00	7:34	204,36	21,48	23:46	199,12	26,72
24.07.25	13,88	1.298	93,49	5:58	203,44	22,40	12:17	199,03	26,81
25.07.25	15,72	1.472	93,64	7:52	203,45	22,39	0:47	199,02	26,82
26.07.25	11,23	1.055	93,94	10:31	203,47	22,37	17:38	199,02	26,82
27.07.25	5,39	507	94,04	12:08	203,86	21,98	0:31	199,07	26,77
28.07.25	12,35	1.162	94,07	3:53	204,19	21,65	20:46	199,02	26,82
29.07.25	10,23	966	94,39	12:27	204,81	21,03	1:26	199,15	26,69
30.07.25	12,86	1.211	94,13	10:34	203,88	21,96	15:10	199,08	26,76
31.07.25	12,90	1.211	93,91	9:18	203,69	22,15	23:39	199,02	26,83
Σ	499,81	47.100							
Mittelwert	16,12	1.519	94,24		203,51	22,33		199,20	26,64
Minimum	5,39	507	90,29		202,18	20,88		199,02	25,69
Maximum	24,00	2.328	97,41		204,96	23,67		200,15	26,83

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom Juli 2025
gedruckt am: 03.08.2025, 18:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.07.25	24,00	2.329	97,04	---	---	---	2:37	193,06	38,36
02.07.25	24,00	2.323	96,79	---	---	---	3:18	192,84	38,57
03.07.25	24,00	2.441	101,71	---	---	---	4:09	192,92	38,50
04.07.25	22,21	2.264	101,93	9:51	202,98	28,44	2:04	193,16	38,25
05.07.25	24,00	2.496	104,00	---	---	---	1:27	193,45	37,96
06.07.25	24,00	2.540	105,83	---	---	---	1:09	193,83	37,58
07.07.25	23,82	2.518	105,71	---	---	---	22:59	193,91	37,50
08.07.25	20,65	2.148	104,03	11:32	204,50	26,91	2:14	193,88	37,53
09.07.25	24,00	2.517	104,88	---	---	---	23:51	193,99	37,43
10.07.25	24,00	2.480	103,33	---	---	---	18:46	193,76	37,66
11.07.25	24,00	2.491	103,79	---	---	---	22:53	193,77	37,64
12.07.25	24,00	2.517	104,88	---	---	---	2:16	193,85	37,57
13.07.25	24,00	2.547	106,13	---	---	---	23:09	193,99	37,43
14.07.25	24,00	2.495	103,96	---	---	---	23:59	193,83	37,58
15.07.25	9,00	924	102,67	16:39	204,41	27,00	0:06	193,79	37,63
16.07.25	0,00	0	---	11:20	204,67	26,74	---	---	---
17.07.25	1,84	177	96,36	10:18	204,96	26,45	---	---	---
18.07.25	0,98	95	96,61	10:39	204,69	26,73	---	---	---
19.07.25	2,39	230	96,39	8:16	204,69	26,73	13:51	196,09	35,32
20.07.25	0,00	0	---	23:54	204,87	26,55	---	---	---
21.07.25	0,00	0	---	16:29	205,23	26,18	---	---	---
22.07.25	2,07	208	100,63	10:08	205,43	25,98	11:51	196,86	34,56
23.07.25	17,39	1.837	105,64	1:03	204,91	26,50	23:57	194,26	37,15
24.07.25	24,00	2.502	104,25	---	---	---	16:03	194,08	37,34
25.07.25	24,00	2.493	103,88	---	---	---	22:27	193,85	37,57
26.07.25	24,00	2.523	105,13	---	---	---	3:43	193,88	37,53
27.07.25	24,00	2.564	106,83	---	---	---	0:41	194,14	37,28
28.07.25	24,00	2.521	105,04	---	---	---	21:05	194,06	37,35
29.07.25	21,08	2.215	105,06	12:07	204,91	26,50	1:36	194,17	37,24
30.07.25	24,00	2.517	104,88	---	---	---	22:38	194,19	37,23
31.07.25	24,00	2.512	104,67	---	---	---	23:53	194,05	37,37
Σ	553,42	57.424							
Mittelwert	17,85	1.852	103,76		204,69	26,72		193,98	37,43
Minimum	0,00	0	96,36		202,98	25,98		192,84	34,56
Maximum	24,00	2.564	106,83		205,43	28,44		196,86	38,57

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom Juli 2025
gedruckt am: 03.08.2025, 18:09 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.07.25	19,33	1.672	86,50	9:27	210,24	21,82	0:00	203,00	29,05
02.07.25	16,82	1.454	86,44	23:07	210,39	21,67	0:00	203,00	29,05
03.07.25	1,55	134	86,47	15:15	211,74	20,32	0:35	204,24	27,82
04.07.25	3,32	298	89,81	8:53	211,97	20,09	10:06	205,80	26,25
05.07.25	0,27	22	82,59	23:53	212,18	19,88	---	---	---
06.07.25	0,00	0	---	23:28	212,42	19,63	---	---	---
07.07.25	0,83	73	88,13	9:06	212,61	19,45	---	---	---
08.07.25	1,27	113	89,31	16:32	212,58	19,48	8:04	205,71	26,35
09.07.25	0,00	0	---	7:43	212,52	19,54	---	---	---
10.07.25	0,59	53	89,58	3:04	212,47	19,59	---	---	---
11.07.25	0,51	45	88,28	8:44	212,44	19,62	---	---	---
12.07.25	0,00	0	---	23:06	212,53	19,52	---	---	---
13.07.25	0,00	0	---	13:07	212,76	19,29	---	---	---
14.07.25	0,00	0	---	7:33	212,65	19,40	---	---	---
15.07.25	16,51	1.517	91,86	4:57	212,52	19,54	23:55	203,49	28,56
16.07.25	24,00	2.196	91,50	---	---	---	23:58	203,43	28,62
17.07.25	24,00	2.189	91,21	---	---	---	5:06	203,25	28,81
18.07.25	24,00	2.183	90,96	---	---	---	21:31	203,31	28,75
19.07.25	24,00	2.176	90,67	---	---	---	15:45	203,25	28,81
20.07.25	24,00	2.199	91,63	---	---	---	0:49	203,28	28,78
21.07.25	24,00	2.202	91,75	---	---	---	15:59	203,34	28,72
22.07.25	21,67	1.983	91,49	10:05	211,08	20,98	7:38	203,29	28,76
23.07.25	6,60	604	91,52	22:02	212,42	19,63	6:34	203,43	28,62
24.07.25	0,74	65	87,87	5:24	212,47	19,59	---	---	---
25.07.25	0,00	0	---	8:03	212,50	19,56	---	---	---
26.07.25	0,00	0	---	21:48	212,55	19,51	---	---	---
27.07.25	0,00	0	---	19:22	212,70	19,35	---	---	---
28.07.25	0,00	0	---	4:41	212,78	19,28	---	---	---
29.07.25	4,19	396	94,48	6:19	212,62	19,43	11:51	204,29	27,77
30.07.25	0,00	0	---	10:17	212,70	19,35	---	---	---
31.07.25	0,00	0	---	9:10	212,68	19,37	---	---	---
Σ	238,20	21.574							
Mittelwert	7,68	696	90,57		212,26	19,79		203,74	28,31
Minimum	0,00	0	82,59		210,24	19,28		203,00	26,25
Maximum	24,00	2.202	94,48		212,78	21,82		205,80	29,05

Meßpunkthöhe (MP): 232,05 m üNN