

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.08.25	24,00	1.214	50,58	---	---	---	0:21	193,99	15,77
02.08.25	24,00	1.214	50,58	---	---	---	2:35	193,99	15,77
03.08.25	19,04	981	51,51	19:24	196,25	13,52	6:37	193,99	15,77
04.08.25	20,07	1.016	50,62	3:15	196,29	13,47	23:14	193,75	16,01
05.08.25	23,88	1.194	49,99	---	---	---	23:35	193,10	16,67
06.08.25	24,00	1.190	49,58	---	---	---	23:54	192,89	16,87
07.08.25	24,00	1.173	48,88	---	---	---	23:24	192,35	17,42
08.08.25	24,00	1.185	49,38	---	---	---	5:41	192,24	17,52
09.08.25	24,00	1.205	50,21	---	---	---	0:00	193,47	16,29
10.08.25	24,00	1.213	50,54	---	---	---	9:24	193,72	16,04
11.08.25	24,00	1.203	50,13	---	---	---	23:47	193,51	16,25
12.08.25	24,00	1.172	48,83	---	---	---	23:55	192,81	16,95
13.08.25	24,00	1.175	48,96	---	---	---	3:31	192,57	17,19
14.08.25	24,00	1.173	48,88	---	---	---	1:44	192,97	16,79
15.08.25	24,00	1.171	48,79	---	---	---	21:17	193,03	16,73
16.08.25	24,00	1.201	50,04	---	---	---	0:55	193,08	16,68
17.08.25	24,00	1.207	50,29	---	---	---	0:12	193,57	16,19
18.08.25	24,00	1.199	49,96	---	---	---	23:50	193,60	16,16
19.08.25	22,44	1.116	49,74	11:23	195,05	14,71	15:34	193,44	16,32
20.08.25	24,00	1.197	49,88	---	---	---	21:29	193,54	16,22
21.08.25	24,00	1.201	50,04	---	---	---	23:55	193,58	16,19
22.08.25	24,00	1.200	50,00	---	---	---	11:46	193,56	16,20
23.08.25	24,00	1.215	50,63	---	---	---	0:00	193,67	16,09
24.08.25	24,00	1.214	50,58	---	---	---	0:00	193,78	15,98
25.08.25	24,00	1.208	50,33	---	---	---	0:03	193,85	15,91
26.08.25	24,00	1.204	50,17	---	---	---	19:27	193,77	16,00
27.08.25	24,00	1.197	49,88	---	---	---	20:33	193,67	16,09
28.08.25	24,00	1.206	50,25	---	---	---	0:39	193,64	16,12
29.08.25	24,00	1.202	50,08	---	---	---	19:30	193,67	16,09
30.08.25	24,00	1.212	50,50	---	---	---	0:54	193,74	16,03
31.08.25	24,00	1.215	50,63	---	---	---	0:00	193,82	15,94
Σ	733,44	36.673							
Mittelwert	23,66	1.183	50,00		195,86	13,90		193,43	16,33
Minimum	19,04	981	48,79		195,05	13,47		192,24	15,77
Maximum	24,00	1.215	51,51		196,29	14,71		193,99	17,52

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.08.25	0,00	0	---	9:49	200,02	7,81	---	---	---
02.08.25	0,00	0	---	16:01	200,02	7,81	---	---	---
03.08.25	5,08	1.259	247,66	18:53	201,25	6,57	23:56	193,54	14,28
04.08.25	21,29	5.101	239,60	2:43	201,27	6,55	20:01	193,02	14,80
05.08.25	23,73	5.570	234,77	---	---	---	23:22	191,51	16,31
06.08.25	24,00	5.587	232,79	---	---	---	23:08	190,96	16,86
07.08.25	24,00	5.466	227,75	---	---	---	0:00	190,96	16,86
08.08.25	6,54	1.487	227,46	23:49	199,28	8,54	0:00	190,97	16,85
09.08.25	0,00	0	---	23:40	199,70	8,12	---	---	---
10.08.25	0,00	0	---	10:16	199,83	7,99	---	---	---
11.08.25	5,08	1.173	231,01	7:53	199,73	8,09	23:59	192,36	15,46
12.08.25	23,76	5.450	229,36	---	---	---	23:12	190,97	16,85
13.08.25	10,17	2.301	226,17	19:46	198,92	8,91	0:00	190,97	16,85
14.08.25	6,97	1.544	221,43	11:33	199,08	8,74	1:28	191,12	16,70
15.08.25	7,28	1.613	221,67	8:04	198,85	8,97	20:47	191,71	16,11
16.08.25	0,37	78	212,24	23:51	199,43	8,39	---	---	---
17.08.25	0,00	0	---	19:21	199,62	8,20	---	---	---
18.08.25	1,80	402	223,06	10:53	199,67	8,15	---	---	---
19.08.25	5,11	1.143	223,89	7:53	199,56	8,26	11:41	191,81	16,01
20.08.25	1,95	436	223,72	9:15	199,57	8,25	---	---	---
21.08.25	0,89	198	222,68	11:13	199,55	8,27	---	---	---
22.08.25	0,75	167	222,50	23:53	199,50	8,32	---	---	---
23.08.25	0,00	0	---	19:29	199,79	8,03	---	---	---
24.08.25	0,00	0	---	10:44	199,89	7,93	---	---	---
25.08.25	0,00	0	---	10:45	199,92	7,91	---	---	---
26.08.25	1,66	374	225,38	7:01	199,82	8,00	---	---	---
27.08.25	2,33	521	223,98	7:02	199,70	8,12	---	---	---
28.08.25	0,75	167	222,75	17:09	199,70	8,13	---	---	---
29.08.25	1,63	364	223,39	7:26	199,67	8,15	---	---	---
30.08.25	0,00	0	---	14:02	199,76	8,07	---	---	---
31.08.25	0,00	0	---	18:53	199,87	7,95	---	---	---
Σ	175,13	40.401							
Mittelwert	5,65	1.303	230,69		199,74	8,08		191,66	16,16
Minimum	0,00	0	212,24		198,85	6,55		190,96	14,28
Maximum	24,00	5.587	247,66		201,27	8,97		193,54	16,86

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.08.25	24,00	3.477	144,88	---	---	---	0:04	191,02	21,81
02.08.25	24,00	3.481	145,04	---	---	---	1:19	191,07	21,77
03.08.25	14,10	2.057	145,90	18:54	196,21	16,63	6:29	191,13	21,71
04.08.25	0,00	0	---	2:43	196,33	16,50	---	---	---
05.08.25	5,22	727	139,39	7:45	194,11	18,72	12:16	189,01	23,82
06.08.25	1,83	252	137,66	0:00	191,98	20,85	23:53	187,55	25,29
07.08.25	24,00	3.319	138,29	---	---	---	23:54	186,53	26,30
08.08.25	24,00	3.396	141,50	---	---	---	5:44	186,38	26,45
09.08.25	24,00	3.462	144,25	---	---	---	1:42	190,50	22,34
10.08.25	24,00	3.481	145,04	---	---	---	22:59	190,85	21,98
11.08.25	20,28	2.917	143,85	21:15	193,26	19,58	13:24	189,90	22,93
12.08.25	6,92	931	134,60	0:00	192,61	20,22	23:56	187,45	25,38
13.08.25	21,42	3.000	140,05	5:06	191,08	21,75	2:27	186,92	25,92
14.08.25	24,00	3.360	140,00	---	---	---	1:28	187,65	25,18
15.08.25	24,00	3.352	139,67	---	---	---	20:47	188,11	24,72
16.08.25	24,00	3.447	143,63	---	---	---	0:22	188,59	24,25
17.08.25	24,00	3.465	144,38	---	---	---	0:03	190,59	22,24
18.08.25	24,00	3.440	143,33	---	---	---	23:03	189,49	23,35
19.08.25	23,88	3.388	141,86	---	---	---	11:29	188,60	24,23
20.08.25	24,00	3.431	142,96	---	---	---	20:13	189,32	23,51
21.08.25	24,00	3.442	143,42	---	---	---	19:48	189,60	23,24
22.08.25	24,00	3.443	143,46	---	---	---	10:31	189,64	23,19
23.08.25	24,00	3.481	145,04	---	---	---	0:01	190,65	22,18
24.08.25	24,00	3.481	145,04	---	---	---	1:48	190,91	21,92
25.08.25	24,00	3.471	144,63	---	---	---	20:56	190,90	21,94
26.08.25	24,00	3.448	143,67	---	---	---	18:16	189,79	23,04
27.08.25	24,00	3.431	142,96	---	---	---	18:38	189,60	23,24
28.08.25	24,00	3.456	144,00	---	---	---	23:33	189,86	22,98
29.08.25	24,00	3.442	143,42	---	---	---	18:10	189,70	23,13
30.08.25	24,00	3.472	144,67	---	---	---	1:20	190,61	22,23
31.08.25	24,00	3.482	145,08	---	---	---	0:11	190,88	21,95
Σ	645,64	92.432							
Mittelwert	20,83	2.982	143,16		193,65	19,18		189,42	23,41
Minimum	0,00	0	134,60		191,08	16,50		186,38	21,71
Maximum	24,00	3.482	145,90		196,33	21,75		191,13	26,45

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.08.25	0,00	0	---	4:35	194,74	15,37	---	---	---
02.08.25	0,00	0	---	15:34	194,74	15,37	---	---	---
03.08.25	0,84	75	89,17	18:53	196,10	14,01	---	---	---
04.08.25	0,00	0	---	2:46	196,38	13,74	---	---	---
05.08.25	12,65	2.393	189,16	0:00	194,35	15,77	14:41	177,00	33,11
06.08.25	24,00	4.521	188,38	---	---	---	9:37	177,00	33,11
07.08.25	24,00	4.424	184,33	---	---	---	---	---	---
08.08.25	6,53	1.202	184,07	23:08	193,78	16,33	0:00	177,00	33,11
09.08.25	0,00	0	---	23:33	194,41	15,71	---	---	---
10.08.25	0,00	0	---	10:11	194,64	15,48	---	---	---
11.08.25	4,96	929	187,36	7:27	194,23	15,89	22:10	177,29	32,82
12.08.25	23,82	4.412	185,24	---	---	---	3:19	177,00	33,11
13.08.25	9,95	1.818	182,76	19:37	193,22	16,90	0:00	177,02	33,10
14.08.25	6,74	1.205	178,72	10:16	193,45	16,67	1:24	177,19	32,93
15.08.25	6,95	1.242	178,83	8:03	193,08	17,03	20:45	178,04	32,07
16.08.25	0,36	62	169,99	23:54	194,01	16,10	---	---	---
17.08.25	0,00	0	---	6:16	194,29	15,83	---	---	---
18.08.25	1,69	305	180,53	5:57	194,29	15,83	---	---	---
19.08.25	4,40	794	180,53	8:07	194,16	15,95	11:41	177,69	32,42
20.08.25	1,84	332	180,68	9:16	194,23	15,89	---	---	---
21.08.25	0,83	150	180,36	10:52	194,12	16,00	---	---	---
22.08.25	0,69	125	180,36	23:55	194,01	16,10	---	---	---
23.08.25	0,00	0	---	9:33	194,56	15,55	---	---	---
24.08.25	0,00	0	---	10:09	194,68	15,43	---	---	---
25.08.25	0,00	0	---	10:49	194,71	15,40	---	---	---
26.08.25	1,59	293	183,73	6:55	194,52	15,60	---	---	---
27.08.25	2,17	391	180,02	6:37	194,30	15,81	---	---	---
28.08.25	0,69	126	182,24	8:22	194,36	15,75	---	---	---
29.08.25	1,52	274	180,23	6:37	194,29	15,83	---	---	---
30.08.25	0,00	0	---	11:32	194,44	15,68	---	---	---
31.08.25	0,00	0	---	11:39	194,61	15,51	---	---	---
Σ	136,23	25.073							
Mittelwert	4,39	809	184,05		194,38	15,73		177,25	32,86
Minimum	0,00	0	89,17		193,08	13,74		177,00	32,07
Maximum	24,00	4.521	189,16		196,38	17,03		178,04	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt			Zeitpunkt		
				Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
	h	m³	m³/h						
01.08.25	10,98	1.318	119,99	4:26	194,75	20,03	17:00	184,76	30,01
02.08.25	9,68	1.160	119,89	4:01	194,70	20,07	18:32	184,88	29,89
03.08.25	4,22	507	120,15	23:54	196,29	18,49	11:43	185,36	29,42
04.08.25	20,38	2.507	123,01	3:25	196,79	17,98	19:21	184,85	29,92
05.08.25	23,57	2.848	120,84	---	---	---	19:31	183,65	31,13
06.08.25	22,71	2.722	119,87	8:12	193,39	21,39	20:02	183,39	31,39
07.08.25	22,37	2.654	118,64	---	---	---	22:53	183,05	31,72
08.08.25	18,06	2.150	119,05	8:32	193,43	21,34	0:00	183,07	31,71
09.08.25	13,29	1.587	119,42	23:25	194,33	20,44	0:57	184,39	30,38
10.08.25	14,00	1.692	120,87	10:03	194,76	20,01	22:29	184,49	30,29
11.08.25	24,00	2.889	120,38	---	---	---	21:59	183,66	31,11
12.08.25	22,27	2.625	117,85	9:20	193,25	21,53	15:51	183,05	31,72
13.08.25	21,81	2.572	117,94	---	---	---	2:43	182,58	32,20
14.08.25	22,53	2.644	117,37	---	---	---	1:30	183,13	31,65
15.08.25	24,00	2.811	117,13	---	---	---	20:55	183,02	31,75
16.08.25	13,04	1.550	118,88	23:59	193,88	20,90	0:35	183,14	31,63
17.08.25	12,91	1.543	119,55	6:08	194,30	20,47	11:58	184,52	30,26
18.08.25	16,84	2.004	118,98	5:48	194,09	20,69	23:38	184,03	30,75
19.08.25	16,92	1.994	117,82	6:16	193,98	20,79	11:57	183,34	31,43
20.08.25	17,30	2.057	118,93	8:58	194,07	20,70	20:27	183,86	30,92
21.08.25	16,94	2.013	118,81	10:39	193,88	20,90	0:00	183,94	30,84
22.08.25	17,98	2.141	119,05	23:58	193,74	21,04	11:10	183,98	30,79
23.08.25	8,99	1.076	119,63	9:25	194,75	20,03	21:59	184,72	30,06
24.08.25	9,30	1.114	119,85	10:06	194,75	20,03	18:07	184,91	29,86
25.08.25	13,44	1.611	119,91	10:30	194,72	20,06	23:54	184,56	30,21
26.08.25	14,44	1.716	118,82	6:47	194,44	20,33	22:43	184,27	30,50
27.08.25	18,35	2.181	118,86	6:32	194,12	20,65	23:56	184,07	30,70
28.08.25	14,23	1.699	119,36	7:59	194,35	20,43	0:00	184,07	30,70
29.08.25	15,70	1.867	118,92	6:31	194,20	20,58	18:30	184,20	30,58
30.08.25	10,88	1.299	119,42	8:10	194,41	20,36	0:50	184,35	30,43
31.08.25	8,83	1.059	119,98	11:28	194,56	20,21	13:34	184,96	29,81
Σ	499,95	59.610							
Mittelwert	16,13	1.923	119,23		194,39	20,38		184,01	30,76
Minimum	4,22	507	117,13		193,25	17,98		182,58	29,42
Maximum	24,00	2.889	123,01		196,79	21,53		185,36	32,20

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.08.25	11,20	620	55,36	4:22	194,48	18,80	17:07	189,07	24,21
02.08.25	9,93	549	55,28	3:59	194,43	18,85	18:41	189,19	24,09
03.08.25	4,33	247	57,01	23:56	197,57	15,71	11:45	189,72	23,56
04.08.25	20,40	1.197	58,66	3:29	198,05	15,23	19:00	189,66	23,62
05.08.25	23,55	1.341	56,94	---	---	---	18:44	189,26	24,02
06.08.25	22,74	1.289	56,69	8:11	195,43	17,85	18:52	189,07	24,21
07.08.25	22,47	1.258	55,99	---	---	---	22:10	189,26	24,02
08.08.25	18,28	1.011	55,32	7:29	194,72	18,56	22:14	188,93	24,35
09.08.25	13,53	744	54,98	23:22	194,12	19,16	1:13	188,93	24,35
10.08.25	14,16	797	56,29	9:55	194,87	18,41	18:43	189,22	24,06
11.08.25	24,00	1.339	55,79	---	---	---	21:28	188,71	24,57
12.08.25	22,24	1.208	54,32	9:20	195,05	18,23	22:23	188,66	24,62
13.08.25	21,89	1.175	53,67	---	---	---	2:36	188,26	25,02
14.08.25	22,59	1.191	52,73	---	---	---	23:27	188,11	25,17
15.08.25	24,00	1.251	52,13	---	---	---	21:54	187,92	25,36
16.08.25	13,27	719	54,19	23:55	193,55	19,73	0:54	187,91	25,37
17.08.25	13,12	718	54,73	6:01	194,02	19,26	15:58	188,79	24,49
18.08.25	17,04	921	54,04	5:47	193,80	19,48	20:26	188,59	24,69
19.08.25	17,17	912	53,13	6:12	193,72	19,56	22:04	188,33	24,95
20.08.25	21,06	1.137	53,99	5:24	193,40	19,88	23:07	188,37	24,91
21.08.25	17,11	923	53,95	6:02	193,55	19,73	1:55	188,31	24,97
22.08.25	15,63	839	53,69	23:58	193,43	19,85	17:13	188,44	24,84
23.08.25	9,20	508	55,20	7:38	194,84	18,44	1:06	188,96	24,32
24.08.25	9,52	525	55,13	10:10	194,50	18,78	23:14	189,24	24,04
25.08.25	12,58	690	54,84	10:30	194,48	18,80	20:24	188,91	24,37
26.08.25	14,55	786	54,03	6:40	194,15	19,13	22:51	188,64	24,64
27.08.25	18,54	997	53,79	6:28	193,82	19,46	20:31	188,53	24,75
28.08.25	14,45	784	54,27	8:04	194,10	19,18	0:03	188,59	24,69
29.08.25	15,92	859	53,96	6:27	193,90	19,38	22:42	188,64	24,64
30.08.25	11,08	605	54,60	8:11	194,12	19,16	0:52	188,66	24,62
31.08.25	9,07	501	55,26	11:27	194,30	18,98	13:40	189,24	24,04
Σ	504,60	27.641							
Mittelwert	16,28	892	54,78		194,50	18,78		188,78	24,50
Minimum	4,33	247	52,13		193,40	15,23		187,91	23,56
Maximum	24,00	1.341	58,66		198,05	19,88		189,72	25,37

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.08.25	24,00	2.592	108,00	---	---	---	17:34	193,50	23,30
02.08.25	24,00	2.595	108,13	---	---	---	19:06	193,54	23,26
03.08.25	11,46	1.245	108,59	23:54	202,62	14,18	1:17	193,64	23,16
04.08.25	15,24	1.688	110,72	3:34	202,93	13,87	18:03	194,15	22,65
05.08.25	11,91	1.291	108,41	23:45	201,36	15,44	2:11	194,19	22,61
06.08.25	9,83	1.062	108,08	8:35	201,73	15,07	18:01	194,24	22,56
07.08.25	5,59	593	106,13	8:38	201,66	15,14	21:52	194,69	22,11
08.08.25	18,45	1.990	107,87	6:19	201,40	15,40	22:27	193,55	23,25
09.08.25	24,00	2.585	107,71	---	---	---	1:23	193,50	23,30
10.08.25	18,93	2.048	108,18	23:26	200,78	16,02	1:28	193,58	23,22
11.08.25	17,06	1.827	107,09	6:27	201,33	15,47	19:33	193,78	23,02
12.08.25	16,27	1.719	105,64	9:40	201,44	15,36	22:26	193,77	23,03
13.08.25	21,79	2.323	106,61	4:17	200,47	16,33	19:35	193,40	23,40
14.08.25	24,00	2.527	105,29	---	---	---	23:55	193,21	23,59
15.08.25	24,00	2.502	104,25	---	---	---	23:08	193,06	23,74
16.08.25	24,00	2.571	107,13	---	---	---	1:04	192,91	23,89
17.08.25	24,00	2.579	107,46	---	---	---	2:42	193,29	23,51
18.08.25	24,00	2.559	106,63	---	---	---	20:35	193,24	23,56
19.08.25	23,88	2.528	105,87	---	---	---	22:09	193,10	23,70
20.08.25	24,00	2.557	106,54	---	---	---	1:58	193,12	23,68
21.08.25	24,00	2.558	106,58	---	---	---	2:00	193,08	23,72
22.08.25	24,00	2.557	106,54	---	---	---	17:25	193,10	23,70
23.08.25	22,34	2.412	107,97	7:23	200,36	16,44	0:00	193,27	23,53
24.08.25	24,00	2.592	108,00	---	---	---	23:38	193,45	23,35
25.08.25	24,00	2.579	107,46	---	---	---	20:35	193,39	23,41
26.08.25	24,00	2.563	106,79	---	---	---	23:10	193,24	23,56
27.08.25	24,00	2.546	106,08	---	---	---	20:45	193,20	23,60
28.08.25	24,00	2.566	106,92	---	---	---	0:19	193,22	23,58
29.08.25	24,00	2.557	106,54	---	---	---	22:54	193,21	23,59
30.08.25	24,00	2.578	107,42	---	---	---	1:08	193,21	23,59
31.08.25	24,00	2.587	107,79	---	---	---	0:00	193,46	23,34
Σ	648,75	69.476							
Mittelwert	20,93	2.241	107,09		201,46	15,34		193,46	23,34
Minimum	5,59	593	104,25		200,36	13,87		192,91	22,11
Maximum	24,00	2.595	110,72		202,93	16,44		194,69	23,89

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Abtutung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.08.25	24,00	4.315	179,79	---	---	---	18:01	179,96	41,19
02.08.25	24,00	4.324	180,17	---	---	---	19:02	180,01	41,14
03.08.25	11,50	2.090	181,67	23:57	198,58	22,57	6:28	179,64	41,51
04.08.25	15,14	2.883	190,38	3:54	198,99	22,16	18:04	180,19	40,96
05.08.25	11,65	2.132	182,95	23:49	197,30	23,85	13:47	180,26	40,89
06.08.25	9,89	1.810	183,02	9:04	197,72	23,43	12:27	180,56	40,59
07.08.25	5,64	988	175,23	9:23	197,66	23,49	21:57	181,89	39,26
08.08.25	18,46	3.333	180,57	6:18	197,35	23,80	13:44	179,59	41,56
09.08.25	24,00	4.310	179,58	---	---	---	1:39	180,01	41,14
10.08.25	19,10	3.447	180,49	23:29	196,54	24,61	8:43	179,66	41,49
11.08.25	16,17	2.851	176,36	6:29	197,25	23,90	21:23	180,54	40,61
12.08.25	15,62	2.685	171,89	9:39	197,32	23,83	0:33	180,68	40,47
13.08.25	17,79	3.113	175,03	4:20	196,27	24,88	11:58	180,04	41,11
14.08.25	22,46	3.877	172,61	1:16	195,52	25,63	9:45	179,84	41,31
15.08.25	24,00	4.077	169,88	---	---	---	22:43	180,14	41,01
16.08.25	24,00	4.275	178,13	---	---	---	1:06	179,44	41,71
17.08.25	24,00	4.294	178,92	---	---	---	0:00	179,68	41,47
18.08.25	24,00	4.235	176,46	---	---	---	15:16	179,69	41,46
19.08.25	23,89	4.163	174,24	---	---	---	11:56	179,14	42,01
20.08.25	24,00	4.245	176,88	---	---	---	14:08	179,34	41,81
21.08.25	24,00	4.230	176,25	---	---	---	2:27	179,56	41,59
22.08.25	24,00	4.233	176,38	---	---	---	17:33	179,48	41,67
23.08.25	22,33	4.027	180,33	7:22	195,72	25,43	4:41	179,24	41,91
24.08.25	24,00	4.328	180,33	---	---	---	23:40	179,76	41,39
25.08.25	24,00	4.296	179,00	---	---	---	0:10	179,76	41,39
26.08.25	24,00	4.247	176,96	---	---	---	11:04	179,64	41,51
27.08.25	24,00	4.200	175,00	---	---	---	16:28	179,59	41,56
28.08.25	24,00	4.255	177,29	---	---	---	0:44	179,62	41,53
29.08.25	24,00	4.234	176,42	---	---	---	14:54	179,64	41,51
30.08.25	24,00	4.289	178,71	---	---	---	1:29	179,59	41,56
31.08.25	24,00	4.320	180,00	---	---	---	14:03	179,79	41,36
Σ	641,64	114.106							
Mittelwert	20,70	3.681	177,83		197,19	23,96		179,87	41,28
Minimum	5,64	988	169,88		195,52	22,16		179,14	39,26
Maximum	24,00	4.328	190,38		198,99	25,63		181,89	42,01

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.08.25	0,00	0	---	---	---	---	---	---	---
02.08.25	0,00	0	---	5:37	188,02	39,51	---	---	---
03.08.25	0,00	0	---	0:00	188,01	39,51	---	---	---
04.08.25	0,00	0	---	3:48	188,02	39,51	---	---	---
05.08.25	0,00	0	---	0:00	188,01	39,51	---	---	---
06.08.25	0,00	0	---	0:00	188,01	39,51	---	---	---
07.08.25	0,00	0	---	0:00	188,01	39,51	---	---	---
08.08.25	0,00	0	---	---	---	---	---	---	---
09.08.25	0,00	0	---	0:00	188,01	39,51	---	---	---
10.08.25	0,00	0	---	16:52	188,02	39,51	---	---	---
11.08.25	0,00	0	---	17:16	188,02	39,51	---	---	---
12.08.25	0,00	0	---	2:03	188,02	39,51	---	---	---
13.08.25	0,00	0	---	0:00	188,01	39,51	---	---	---
14.08.25	0,00	0	---	0:00	188,01	39,51	---	---	---
15.08.25	0,00	0	---	0:00	188,01	39,51	---	---	---
16.08.25	0,00	0	---	12:12	188,02	39,51	---	---	---
17.08.25	0,00	0	---	---	---	---	---	---	---
18.08.25	0,00	0	---	14:39	188,02	39,51	---	---	---
19.08.25	0,00	0	---	4:38	188,02	39,51	---	---	---
20.08.25	0,00	0	---	0:53	188,02	39,51	---	---	---
21.08.25	0,00	0	---	2:32	188,02	39,51	---	---	---
22.08.25	0,00	0	---	3:30	188,02	39,51	---	---	---
23.08.25	0,00	0	---	19:30	188,02	39,51	---	---	---
24.08.25	0,00	0	---	6:16	188,02	39,51	---	---	---
25.08.25	0,00	0	---	3:18	188,02	39,51	---	---	---
26.08.25	0,00	0	---	5:10	188,02	39,51	---	---	---
27.08.25	0,00	0	---	6:46	188,02	39,51	---	---	---
28.08.25	0,00	0	---	9:59	188,02	39,51	---	---	---
29.08.25	0,00	0	---	15:25	188,02	39,51	---	---	---
30.08.25	0,00	0	---	18:45	188,02	39,51	---	---	---
31.08.25	0,00	0	---	23:48	188,02	39,51	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,01	39,51		---	---
Minimum	0,00	0	---		188,01	39,51		---	---
Maximum	0,00	0	---		188,02	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.08.25	24,00	1.530	63,75	---	---	---	23:58	192,90	42,56
02.08.25	24,00	1.542	64,25	---	---	---	0:40	192,75	42,72
03.08.25	11,62	754	64,87	23:56	198,97	36,50	9:06	192,95	42,51
04.08.25	17,10	1.197	70,01	5:36	199,28	36,18	23:56	193,25	42,21
05.08.25	24,00	1.637	68,21	---	---	---	13:12	193,08	42,38
06.08.25	24,00	1.633	68,04	---	---	---	18:44	193,15	42,31
07.08.25	24,00	1.624	67,67	---	---	---	21:57	193,19	42,27
08.08.25	21,72	1.479	68,10	13:43	198,09	37,37	23:55	192,89	42,57
09.08.25	24,00	1.502	62,58	---	---	---	4:30	193,27	42,19
10.08.25	19,24	1.260	65,49	23:24	198,03	37,43	18:32	192,87	42,59
11.08.25	16,46	1.146	69,64	6:17	198,45	37,01	23:58	192,96	42,50
12.08.25	16,30	1.162	71,31	9:42	198,48	36,99	0:32	192,90	42,56
13.08.25	21,87	1.410	64,48	4:14	197,98	37,48	2:07	192,95	42,51
14.08.25	24,00	1.589	66,21	---	---	---	12:36	192,80	42,66
15.08.25	24,00	1.612	67,17	---	---	---	23:26	192,65	42,81
16.08.25	24,00	1.500	62,50	---	---	---	0:26	192,69	42,77
17.08.25	24,00	1.508	62,83	---	---	---	15:57	193,00	42,46
18.08.25	24,00	1.522	63,42	---	---	---	17:57	192,75	42,72
19.08.25	24,00	1.576	65,67	---	---	---	22:04	192,65	42,81
20.08.25	24,00	1.592	66,33	---	---	---	15:42	192,56	42,91
21.08.25	24,00	1.528	63,67	---	---	---	1:39	192,72	42,74
22.08.25	24,00	1.510	62,92	---	---	---	10:30	192,76	42,71
23.08.25	24,00	1.542	64,25	---	---	---	6:13	192,76	42,70
24.08.25	24,00	1.514	63,08	---	---	---	17:02	192,84	42,62
25.08.25	24,00	1.509	62,88	---	---	---	23:58	192,80	42,66
26.08.25	24,00	1.546	64,42	---	---	---	1:22	192,72	42,74
27.08.25	24,00	1.558	64,92	---	---	---	20:30	192,79	42,68
28.08.25	24,00	1.554	64,75	---	---	---	20:28	192,72	42,75
29.08.25	24,00	1.544	64,33	---	---	---	18:11	192,88	42,59
30.08.25	24,00	1.566	65,25	---	---	---	3:32	192,72	42,74
31.08.25	24,00	1.538	64,08	---	---	---	13:40	192,79	42,68
Σ	700,30	45.684							
Mittelwert	22,59	1.474	65,23		198,47	36,99		192,86	42,60
Minimum	11,62	754	62,50		197,98	36,18		192,56	42,19
Maximum	24,00	1.637	71,31		199,28	37,48		193,27	42,91

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom August 2025
gedruckt am: 04.09.2025, 17:05 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.08.25	24,00	3.894	162,25	---	---	---	0:16	192,25	52,57
02.08.25	24,00	3.877	161,54	---	---	---	0:41	192,27	52,55
03.08.25	14,33	2.346	163,71	23:49	197,10	47,72	1:54	192,28	52,54
04.08.25	0,00	0	---	5:03	197,40	47,42	---	---	---
05.08.25	2,78	468	168,13	9:06	197,01	47,81	12:18	193,38	51,45
06.08.25	0,68	115	169,12	9:25	197,03	47,79	---	---	---
07.08.25	0,00	0	---	9:58	197,06	47,76	---	---	---
08.08.25	17,53	2.897	165,26	6:20	196,99	47,83	22:22	192,46	52,36
09.08.25	24,00	3.908	162,83	---	---	---	22:24	192,34	52,48
10.08.25	24,00	3.928	163,67	---	---	---	16:47	192,34	52,48
11.08.25	20,33	3.338	164,20	23:53	196,11	48,71	20:15	192,33	52,49
12.08.25	5,10	848	166,20	9:39	196,70	48,12	14:01	192,81	52,01
13.08.25	18,91	3.069	162,33	4:55	196,48	48,35	20:49	192,25	52,57
14.08.25	24,00	3.832	159,67	---	---	---	23:35	192,05	52,77
15.08.25	24,00	3.779	157,46	---	---	---	23:36	191,92	52,91
16.08.25	24,00	3.812	158,83	---	---	---	1:18	191,90	52,92
17.08.25	24,00	3.833	159,71	---	---	---	0:00	192,08	52,74
18.08.25	24,00	3.833	159,71	---	---	---	22:00	192,05	52,77
19.08.25	24,00	3.829	159,54	---	---	---	22:39	192,00	52,82
20.08.25	24,00	3.812	158,83	---	---	---	2:07	192,01	52,81
21.08.25	24,00	3.816	159,00	---	---	---	0:39	191,97	52,85
22.08.25	24,00	3.816	159,00	---	---	---	3:30	191,96	52,86
23.08.25	24,00	3.859	160,79	---	---	---	0:00	192,01	52,81
24.08.25	24,00	3.850	160,42	---	---	---	0:00	192,13	52,69
25.08.25	24,00	3.832	159,67	---	---	---	21:09	192,13	52,69
26.08.25	24,00	3.817	159,04	---	---	---	22:50	192,10	52,72
27.08.25	24,00	3.812	158,83	---	---	---	21:52	192,04	52,78
28.08.25	24,00	3.818	159,08	---	---	---	1:31	192,02	52,80
29.08.25	24,00	3.810	158,75	---	---	---	11:18	192,05	52,77
30.08.25	24,00	3.810	158,75	---	---	---	4:11	192,02	52,80
31.08.25	24,00	3.834	159,75	---	---	---	0:00	192,08	52,74
Σ	607,66	97.492							
Mittelwert	19,60	3.145	160,44		196,88	47,95		192,19	52,63
Minimum	0,00	0	157,46		196,11	47,42		191,90	51,45
Maximum	24,00	3.928	169,12		197,40	48,71		193,38	52,92

Meßpunkthöhe (MP): 244,82 m üNN