

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.09.25	24,00	2.459	102,46	---	---	---	19:05	193,85	20,42
02.09.25	24,00	2.453	102,21	---	---	---	11:50	193,75	20,53
03.09.25	21,74	2.225	102,35	11:55	198,87	15,40	0:07	193,73	20,54
04.09.25	20,55	2.104	102,38	12:30	199,22	15,05	5:29	193,78	20,49
05.09.25	24,00	2.465	102,71	---	---	---	21:04	193,86	20,41
06.09.25	24,00	2.463	102,63	---	---	---	1:07	193,79	20,48
07.09.25	6,36	655	103,01	17:45	198,96	15,31	0:00	193,98	20,30
08.09.25	0,00	0	---	12:09	199,08	15,20	---	---	---
09.09.25	9,18	943	102,68	6:08	198,96	15,31	12:47	193,98	20,30
10.09.25	24,00	2.460	102,50	---	---	---	18:45	193,95	20,32
11.09.25	24,00	2.445	101,88	---	---	---	17:38	193,93	20,34
12.09.25	23,18	2.361	101,84	---	---	---	23:14	193,93	20,34
13.09.25	10,13	1.039	102,55	10:49	198,76	15,51	0:41	193,95	20,33
14.09.25	6,66	684	102,67	9:51	198,84	15,43	22:13	194,21	20,06
15.09.25	9,89	1.011	102,22	16:56	198,78	15,49	23:54	193,97	20,30
16.09.25	12,11	1.235	101,97	14:50	198,81	15,46	23:44	193,83	20,44
17.09.25	18,55	1.887	101,71	10:41	198,30	15,98	22:42	193,67	20,60
18.09.25	20,72	2.096	101,16	7:59	197,95	16,33	19:43	193,59	20,68
19.09.25	15,18	1.539	101,41	5:02	198,30	15,97	0:00	193,70	20,57
20.09.25	23,24	2.349	101,07	---	---	---	21:52	193,52	20,75
21.09.25	20,70	2.093	101,12	8:12	197,96	16,31	21:54	193,48	20,79
22.09.25	18,49	1.868	101,02	2:01	197,95	16,33	20:24	193,55	20,72
23.09.25	21,73	2.188	100,70	11:56	197,82	16,46	23:27	193,43	20,84
24.09.25	20,04	2.026	101,09	6:23	198,06	16,21	23:46	193,40	20,88
25.09.25	24,00	2.432	101,33	---	---	---	6:32	193,32	20,95
26.09.25	24,00	2.443	101,79	---	---	---	0:44	193,43	20,85
27.09.25	24,00	2.449	102,04	---	---	---	1:23	193,62	20,66
28.09.25	24,00	2.453	102,21	---	---	---	0:00	193,76	20,51
29.09.25	6,68	681	101,98	14:29	199,17	15,10	0:54	193,72	20,56
30.09.25	3,74	384	102,63	5:20	199,22	15,05	10:36	194,11	20,17
Σ	528,88	53.890							
Mittelwert	17,63	1.796	101,89		198,61	15,66		193,75	20,52
Minimum	0,00	0	100,70		197,82	15,05		193,32	20,06
Maximum	24,00	2.465	103,01		199,22	16,46		194,21	20,95

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.09.25	15,51	2.084	134,38	3:56	200,44	13,78	19:00	195,41	18,81
02.09.25	17,35	2.306	132,95	4:38	200,17	14,05	11:46	195,28	18,94
03.09.25	13,72	1.820	132,64	12:08	200,46	13,76	0:03	195,22	19,00
04.09.25	13,24	1.758	132,76	12:33	200,76	13,46	5:23	195,29	18,93
05.09.25	11,70	1.568	133,98	11:13	200,57	13,65	1:27	195,38	18,84
06.09.25	13,06	1.751	134,05	9:14	200,33	13,89	1:04	195,36	18,86
07.09.25	18,30	2.538	138,72	6:11	200,52	13,70	23:53	195,33	18,89
08.09.25	23,28	3.194	137,20	---	---	---	11:34	195,19	19,03
09.09.25	21,32	2.910	136,49	14:51	200,21	14,01	11:39	195,04	19,19
10.09.25	12,16	1.622	133,34	9:14	200,53	13,70	18:41	195,44	18,78
11.09.25	14,44	1.942	134,51	9:25	200,43	13,79	17:32	195,44	18,78
12.09.25	20,52	2.807	136,80	5:43	200,25	13,97	22:58	195,59	18,64
13.09.25	24,00	3.313	138,04	---	---	---	5:16	195,15	19,07
14.09.25	24,00	3.285	136,88	---	---	---	22:26	195,01	19,22
15.09.25	24,00	3.251	135,46	---	---	---	6:02	194,92	19,31
16.09.25	22,06	2.970	134,62	10:27	200,01	14,22	8:20	194,69	19,54
17.09.25	24,00	3.160	131,67	---	---	---	8:56	194,65	19,57
18.09.25	24,00	3.126	130,25	---	---	---	7:02	194,64	19,58
19.09.25	24,00	3.181	132,54	---	---	---	0:10	194,66	19,57
20.09.25	24,00	3.112	129,67	---	---	---	3:47	194,66	19,57
21.09.25	24,00	3.131	130,46	---	---	---	22:29	194,50	19,72
22.09.25	24,00	3.126	130,25	---	---	---	20:38	194,52	19,70
23.09.25	24,00	3.084	128,50	---	---	---	10:52	194,40	19,82
24.09.25	24,00	3.122	130,08	---	---	---	1:13	194,50	19,72
25.09.25	20,63	2.702	130,99	---	---	---	6:29	194,43	19,80
26.09.25	13,77	1.813	131,63	23:37	199,69	14,54	0:31	194,85	19,37
27.09.25	11,94	1.583	132,63	7:55	199,98	14,24	16:40	195,18	19,04
28.09.25	11,08	1.480	133,62	7:22	200,14	14,09	18:51	195,43	18,79
29.09.25	12,83	1.743	135,87	11:00	200,37	13,86	0:50	195,31	18,91
30.09.25	17,51	2.389	136,48	5:17	200,36	13,86	10:38	195,11	19,11
Σ	568,41	75.871							
Mittelwert	18,95	2.529	133,48		200,31	13,91		195,02	19,20
Minimum	11,08	1.480	128,50		199,69	13,46		194,40	18,64
Maximum	24,00	3.313	138,72		200,76	14,54		195,59	19,82

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	15,17	1.384	91,24	3:58	200,54	19,59	23:58	197,66	22,46
02.09.25	17,11	1.554	90,83	4:39	200,25	19,88	23:53	197,51	22,61
03.09.25	13,45	1.216	90,42	12:24	200,46	19,66	0:00	197,51	22,61
04.09.25	13,02	1.181	90,72	12:30	200,73	19,39	5:16	197,59	22,53
05.09.25	11,46	1.044	91,13	11:13	200,65	19,47	1:18	197,71	22,42
06.09.25	12,71	1.158	91,08	9:16	200,41	19,71	0:59	197,68	22,45
07.09.25	18,17	1.690	93,02	6:14	200,60	19,52	23:53	197,67	22,45
08.09.25	23,19	2.144	92,47	---	---	---	23:56	197,59	22,53
09.09.25	21,25	1.962	92,33	14:52	200,22	19,90	11:39	197,43	22,69
10.09.25	11,88	1.078	90,78	9:14	200,61	19,51	18:30	197,77	22,35
11.09.25	8,52	772	90,66	9:25	200,56	19,56	17:28	197,77	22,35
12.09.25	1,10	106	95,98	5:43	200,41	19,71	---	---	---
13.09.25	14,21	1.322	93,02	14:56	200,22	19,90	23:39	197,58	22,55
14.09.25	24,00	2.233	93,04	---	---	---	22:26	197,35	22,77
15.09.25	24,00	2.220	92,50	---	---	---	20:08	197,29	22,83
16.09.25	21,83	2.013	92,20	10:29	199,99	20,13	8:14	197,16	22,96
17.09.25	24,00	2.187	91,13	---	---	---	8:56	197,05	23,07
18.09.25	24,00	2.171	90,46	---	---	---	20:44	196,95	23,17
19.09.25	24,00	2.194	91,42	---	---	---	0:03	196,96	23,16
20.09.25	24,00	2.165	90,21	---	---	---	23:17	196,95	23,17
21.09.25	24,00	2.171	90,46	---	---	---	22:27	196,80	23,32
22.09.25	24,00	2.170	90,42	---	---	---	20:32	196,79	23,33
23.09.25	24,00	2.155	89,79	---	---	---	10:52	196,73	23,39
24.09.25	24,00	2.171	90,46	---	---	---	1:06	196,77	23,35
25.09.25	20,39	1.853	90,86	---	---	---	2:27	196,74	23,38
26.09.25	13,23	1.200	90,73	23:36	199,74	20,38	0:29	197,05	23,07
27.09.25	11,55	1.050	90,94	8:02	200,04	20,08	16:37	197,42	22,70
28.09.25	10,71	978	91,29	7:25	200,21	19,92	23:58	197,69	22,43
29.09.25	12,44	1.143	91,90	14:27	200,40	19,72	0:49	197,58	22,54
30.09.25	15,12	1.396	92,34	5:17	200,32	19,80	10:34	197,59	22,53
Σ	526,49	48.081							
Mittelwert	17,55	1.603	91,32		200,35	19,77		197,32	22,80
Minimum	1,10	106	89,79		199,74	19,39		196,73	22,35
Maximum	24,00	2.233	95,98		200,73	20,38		197,77	23,39

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	2.365	98,54	---	---	---	19:12	197,22	24,16
02.09.25	24,00	2.320	96,67	---	---	---	11:57	197,05	24,33
03.09.25	23,34	2.281	97,75	---	---	---	0:20	196,99	24,39
04.09.25	19,93	1.952	97,94	12:34	202,86	18,52	5:32	197,08	24,30
05.09.25	23,39	2.353	100,59	---	---	---	1:40	197,37	24,02
06.09.25	24,00	2.393	99,71	---	---	---	1:21	197,24	24,15
07.09.25	13,23	1.354	102,35	20:39	202,64	18,75	0:00	197,35	24,03
08.09.25	13,36	1.351	101,13	5:27	202,79	18,59	23:48	198,76	22,63
09.09.25	8,86	882	99,60	14:58	203,06	18,33	10:58	198,49	22,89
10.09.25	21,66	2.200	101,57	12:04	202,65	18,73	21:40	197,83	23,55
11.09.25	24,00	2.398	99,92	---	---	---	23:17	197,45	23,93
12.09.25	23,05	2.263	98,19	---	---	---	23:14	197,30	24,08
13.09.25	5,51	567	102,95	17:30	202,61	18,78	23:55	198,27	23,11
14.09.25	22,46	2.286	101,77	---	---	---	23:28	197,82	23,57
15.09.25	22,38	2.236	99,92	---	---	---	4:12	197,80	23,58
16.09.25	18,87	1.854	98,27	13:17	202,76	18,62	1:05	197,60	23,78
17.09.25	23,63	2.245	95,03	---	---	---	15:45	197,40	23,99
18.09.25	19,36	1.787	92,30	23:33	201,78	19,60	7:39	196,99	24,39
19.09.25	0,61	61	100,23	22:24	202,28	19,11	---	---	---
20.09.25	24,00	2.231	92,96	---	---	---	23:25	197,34	24,05
21.09.25	24,00	2.222	92,58	---	---	---	22:50	196,69	24,69
22.09.25	24,00	2.227	92,79	---	---	---	21:07	196,71	24,67
23.09.25	18,89	1.691	89,51	23:54	201,50	19,88	2:39	196,68	24,70
24.09.25	15,06	1.375	91,30	6:28	201,87	19,51	23:59	197,13	24,25
25.09.25	15,22	1.441	94,71	11:14	201,71	19,68	21:37	196,90	24,48
26.09.25	24,00	2.331	97,13	---	---	---	11:59	196,81	24,57
27.09.25	24,00	2.365	98,54	---	---	---	1:27	196,92	24,46
28.09.25	24,00	2.390	99,58	---	---	---	0:08	197,12	24,27
29.09.25	23,29	2.352	100,97	---	---	---	1:01	197,10	24,28
30.09.25	21,97	2.219	101,02	10:42	202,61	18,78	0:00	197,66	23,72
Σ	594,04	57.992							
Mittelwert	19,80	1.933	97,62		202,39	18,99		197,35	24,03
Minimum	0,61	61	89,51		201,50	18,33		196,68	22,63
Maximum	24,00	2.398	102,95		203,06	19,88		198,76	24,70

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	15,62	1.463	93,64	3:57	203,24	22,60	7:17	199,03	26,81
02.09.25	17,43	1.625	93,22	4:36	202,96	22,89	0:12	199,03	26,81
03.09.25	14,26	1.317	92,35	12:04	203,69	22,15	7:29	199,03	26,81
04.09.25	13,32	1.238	92,98	12:32	204,63	21,21	2:20	199,03	26,81
05.09.25	11,79	1.103	93,57	11:09	203,51	22,34	0:05	199,03	26,81
06.09.25	13,19	1.234	93,54	9:17	203,19	22,65	0:16	199,03	26,81
07.09.25	18,34	1.778	96,96	6:16	203,39	22,45	7:52	199,37	26,48
08.09.25	23,31	2.255	96,73	---	---	---	23:55	199,76	26,08
09.09.25	21,34	2.064	96,70	14:50	204,71	21,14	11:13	199,38	26,46
10.09.25	12,26	1.147	93,54	12:14	204,05	21,79	18:42	199,04	26,80
11.09.25	14,54	1.358	93,39	6:24	203,45	22,40	15:38	199,03	26,81
12.09.25	20,71	1.952	94,25	0:24	202,97	22,87	1:36	199,03	26,81
13.09.25	24,00	2.307	96,13	---	---	---	0:43	199,03	26,81
14.09.25	24,00	2.332	97,17	---	---	---	22:23	199,03	26,81
15.09.25	24,00	2.316	96,50	---	---	---	23:45	199,03	26,81
16.09.25	21,65	2.078	95,97	10:28	204,38	21,46	0:01	199,03	26,81
17.09.25	24,00	2.256	94,00	---	---	---	17:50	199,02	26,82
18.09.25	24,00	2.222	92,58	---	---	---	15:15	199,02	26,83
19.09.25	24,00	2.256	94,00	---	---	---	0:22	199,02	26,83
20.09.25	24,00	2.218	92,42	---	---	---	5:40	199,02	26,82
21.09.25	24,00	2.226	92,75	---	---	---	18:13	199,02	26,83
22.09.25	24,00	2.231	92,96	---	---	---	0:07	199,02	26,83
23.09.25	24,00	2.192	91,33	---	---	---	5:14	199,02	26,83
24.09.25	24,00	2.227	92,79	---	---	---	0:11	199,02	26,83
25.09.25	20,80	1.946	93,57	---	---	---	0:04	199,05	26,80
26.09.25	14,08	1.309	92,97	6:20	202,60	23,24	0:00	199,05	26,80
27.09.25	12,22	1.137	93,04	7:55	202,89	22,96	0:38	199,05	26,80
28.09.25	11,33	1.058	93,37	7:25	203,06	22,78	10:55	199,04	26,80
29.09.25	13,12	1.240	94,52	18:04	203,91	21,93	0:05	199,04	26,80
30.09.25	15,79	1.504	95,25	10:56	204,48	21,37	8:33	199,36	26,48
Σ	569,11	53.589							
Mittelwert	18,97	1.786	94,16		203,59	22,25		199,09	26,75
Minimum	11,33	1.058	91,33		202,60	21,14		199,02	26,08
Maximum	24,00	2.332	97,17		204,71	23,24		199,76	26,83

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:30 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	2.476	103,17	---	---	---	19:11	193,76	37,66
02.09.25	24,00	2.450	102,08	---	---	---	18:01	193,62	37,79
03.09.25	21,53	2.177	101,10	11:53	204,09	27,32	0:17	193,58	37,84
04.09.25	20,66	2.110	102,12	12:26	204,99	26,42	5:34	193,73	37,69
05.09.25	24,00	2.495	103,96	---	---	---	1:40	193,96	37,46
06.09.25	24,00	2.482	103,42	---	---	---	1:14	193,85	37,57
07.09.25	6,38	674	105,59	21:19	204,72	26,70	0:00	194,00	37,41
08.09.25	0,00	0	---	5:57	204,85	26,56	---	---	---
09.09.25	5,64	567	100,62	15:12	205,13	26,29	23:51	194,92	36,50
10.09.25	24,00	2.501	104,21	---	---	---	21:43	194,17	37,24
11.09.25	24,00	2.482	103,42	---	---	---	23:10	193,85	37,57
12.09.25	23,17	2.370	102,30	---	---	---	4:36	193,82	37,60
13.09.25	10,53	1.036	98,36	22:31	204,00	27,42	0:52	194,77	36,65
14.09.25	6,97	718	103,08	10:16	204,90	26,52	22:18	195,45	35,96
15.09.25	10,17	1.042	102,45	17:17	204,85	26,56	23:58	195,15	36,27
16.09.25	11,50	1.160	100,88	14:17	205,36	26,06	23:38	194,96	36,45
17.09.25	18,79	1.886	100,35	10:39	203,75	27,66	22:56	194,44	36,97
18.09.25	20,91	2.062	98,61	7:58	202,85	28,56	17:01	194,17	37,24
19.09.25	15,46	1.498	96,91	5:00	203,63	27,78	23:54	194,77	36,65
20.09.25	23,29	2.319	99,57	---	---	---	22:55	193,97	37,44
21.09.25	20,89	2.088	99,96	8:11	202,67	28,74	2:01	193,94	37,47
22.09.25	18,78	1.877	99,95	1:58	202,78	28,64	16:09	194,17	37,24
23.09.25	21,85	2.118	96,92	11:54	202,53	28,88	19:31	193,83	37,58
24.09.25	20,14	1.994	99,03	6:23	203,14	28,27	23:56	193,85	37,57
25.09.25	24,00	2.453	102,21	---	---	---	6:40	193,42	37,99
26.09.25	24,00	2.478	103,25	---	---	---	0:43	193,65	37,76
27.09.25	24,00	2.496	104,00	---	---	---	1:25	193,80	37,61
28.09.25	24,00	2.503	104,29	---	---	---	0:00	193,96	37,46
29.09.25	6,75	700	103,75	14:30	204,64	26,78	1:51	193,83	37,58
30.09.25	1,53	149	97,33	13:31	205,02	26,39	8:17	195,68	35,73
Σ	524,93	53.361							
Mittelwert	17,50	1.779	101,65		204,10	27,31		194,17	37,24
Minimum	0,00	0	96,91		202,53	26,06		193,42	35,73
Maximum	24,00	2.503	105,59		205,36	28,88		195,68	37,99

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:30 Uhr in Stadtallendorf

Tag	Förderdaten			Abtutung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	0,00	0	---	1:05	212,52	19,54	---	---	---
02.09.25	0,73	64	88,24	4:46	212,42	19,63	---	---	---
03.09.25	5,63	492	87,35	5:55	212,36	19,69	9:20	205,01	27,05
04.09.25	4,38	392	89,54	11:35	212,62	19,43	15:39	205,66	26,39
05.09.25	0,71	62	87,26	17:55	212,47	19,59	---	---	---
06.09.25	0,00	0	---	21:19	212,42	19,63	---	---	---
07.09.25	17,66	1.625	92,01	6:05	212,50	19,56	23:53	203,52	28,53
08.09.25	24,00	2.198	91,58	---	---	---	12:03	203,31	28,75
09.09.25	18,80	1.729	91,98	23:57	211,35	20,70	1:27	203,40	28,65
10.09.25	1,24	109	87,69	12:46	212,56	19,49	14:21	206,26	25,80
11.09.25	1,03	92	89,10	8:47	212,56	19,49	20:48	206,26	25,80
12.09.25	1,00	92	92,08	14:06	212,39	19,66	---	---	---
13.09.25	18,52	1.673	90,34	23:56	211,80	20,26	13:57	203,17	28,89
14.09.25	0,00	0	---	14:56	212,93	19,13	---	---	---
15.09.25	0,00	0	---	17:07	213,13	18,93	---	---	---
16.09.25	2,02	178	87,91	14:41	213,11	18,94	---	---	---
17.09.25	2,86	250	87,43	10:43	212,67	19,39	20:17	205,95	26,10
18.09.25	8,74	769	87,99	8:25	212,26	19,80	23:59	203,83	28,23
19.09.25	23,38	2.063	88,24	---	---	---	13:11	203,00	29,05
20.09.25	3,63	316	87,15	13:21	211,83	20,23	5:39	205,31	26,74
21.09.25	2,41	214	88,64	22:53	212,04	20,01	4:40	205,80	26,25
22.09.25	2,71	237	87,44	11:11	212,22	19,83	23:45	205,79	26,27
23.09.25	12,83	1.114	86,84	7:32	211,97	20,09	23:58	203,35	28,70
24.09.25	10,12	894	88,33	22:04	211,49	20,56	1:07	203,00	29,05
25.09.25	0,00	0	---	18:55	212,10	19,95	---	---	---
26.09.25	0,00	0	---	16:20	212,19	19,86	---	---	---
27.09.25	0,00	0	---	7:57	212,29	19,77	---	---	---
28.09.25	0,00	0	---	10:02	212,38	19,68	---	---	---
29.09.25	18,24	1.676	91,90	4:15	212,38	19,68	23:56	203,32	28,73
30.09.25	21,37	1.948	91,15	10:42	211,06	20,99	5:02	203,25	28,81
Σ	202,01	18.187							
Mittelwert	6,73	606	90,03		212,28	19,77		204,40	27,65
Minimum	0,00	0	86,84		211,06	18,93		203,00	25,80
Maximum	24,00	2.198	92,08		213,13	20,99		206,26	29,05

Meßpunkthöhe (MP): 232,05 m üNN