

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	1.208	50,33	---	---	---	19:59	193,88	15,88
02.09.25	24,00	1.204	50,17	---	---	---	18:26	193,75	16,01
03.09.25	21,64	1.082	50,00	13:33	195,27	14,49	20:29	193,60	16,16
04.09.25	21,69	1.084	49,98	11:30	195,66	14,10	0:29	193,58	16,18
05.09.25	24,00	1.207	50,29	---	---	---	1:39	193,61	16,15
06.09.25	24,00	1.210	50,42	---	---	---	1:13	193,74	16,03
07.09.25	24,00	1.203	50,13	---	---	---	23:56	192,96	16,80
08.09.25	24,00	1.185	49,38	---	---	---	19:45	192,72	17,04
09.09.25	24,00	1.193	49,71	---	---	---	20:24	192,50	17,26
10.09.25	24,00	1.201	50,04	---	---	---	0:00	192,81	16,95
11.09.25	24,00	1.202	50,08	---	---	---	0:12	193,55	16,21
12.09.25	24,00	1.198	49,92	---	---	---	0:00	193,56	16,20
13.09.25	24,00	1.196	49,83	---	---	---	18:49	192,57	17,19
14.09.25	24,00	1.221	50,88	---	---	---	0:00	193,16	16,61
15.09.25	24,00	1.218	50,75	---	---	---	20:09	193,85	15,91
16.09.25	24,00	1.206	50,25	---	---	---	13:08	193,36	16,40
17.09.25	24,00	1.207	50,29	---	---	---	21:13	193,53	16,23
18.09.25	24,00	1.204	50,17	---	---	---	23:55	193,00	16,76
19.09.25	24,00	1.178	49,08	---	---	---	20:53	192,35	17,42
20.09.25	24,00	1.203	50,13	---	---	---	0:00	192,35	17,42
21.09.25	21,33	1.079	50,59	4:30	195,20	14,56	0:06	193,29	16,48
22.09.25	24,00	1.215	50,63	---	---	---	0:55	193,50	16,26
23.09.25	24,00	1.204	50,17	---	---	---	23:57	192,74	17,03
24.09.25	24,00	1.200	50,00	---	---	---	6:27	192,54	17,22
25.09.25	24,00	1.207	50,29	---	---	---	0:29	193,21	16,55
26.09.25	24,00	1.203	50,13	---	---	---	0:59	193,63	16,13
27.09.25	24,00	1.207	50,29	---	---	---	1:29	193,72	16,04
28.09.25	24,00	1.208	50,33	---	---	---	0:17	193,75	16,01
29.09.25	24,00	1.189	49,54	---	---	---	23:57	192,94	16,82
30.09.25	10,66	519	48,69	23:23	194,87	14,89	6:48	192,81	16,95
Σ	699,32	35.041							
Mittelwert	23,31	1.168	50,11		195,25	14,51		193,22	16,54
Minimum	10,66	519	48,69		194,87	14,10		192,35	15,88
Maximum	24,00	1.221	50,88		195,66	14,89		193,88	17,42

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	0,00	0	---	4:12	199,87	7,95	---	---	---
02.09.25	0,75	168	223,42	5:06	199,75	8,07	---	---	---
03.09.25	5,51	1.236	224,15	7:20	200,24	7,58	14:14	192,18	15,64
04.09.25	4,45	1.016	228,19	11:36	200,54	7,28	15:41	192,71	15,12
05.09.25	0,77	170	220,06	11:37	199,74	8,08	---	---	---
06.09.25	0,00	0	---	21:38	199,70	8,12	---	---	---
07.09.25	17,65	4.148	234,97	6:06	199,82	8,00	23:53	191,32	16,50
08.09.25	24,00	5.564	231,83	---	---	---	11:53	191,08	16,74
09.09.25	19,19	4.485	233,67	23:58	198,12	9,70	16:20	190,96	16,86
10.09.25	1,27	283	222,88	13:02	199,53	8,29	14:24	192,87	14,95
11.09.25	1,06	237	223,82	9:49	199,69	8,13	20:51	193,04	14,78
12.09.25	0,92	217	235,37	12:18	199,89	7,93	---	---	---
13.09.25	18,56	4.311	232,33	23:58	199,31	8,51	9:54	190,97	16,85
14.09.25	0,00	0	---	20:19	200,60	7,22	---	---	---
15.09.25	0,00	0	---	10:22	200,76	7,07	---	---	---
16.09.25	6,46	1.502	232,35	6:14	200,66	7,16	12:54	192,09	15,73
17.09.25	2,95	674	228,80	10:42	200,24	7,58	20:19	192,50	15,32
18.09.25	8,82	2.026	229,75	8:01	199,95	7,88	23:58	190,98	16,84
19.09.25	23,42	5.366	229,16	---	---	---	16:31	190,96	16,86
20.09.25	2,54	579	228,00	13:19	199,14	8,68	14:51	192,17	15,65
21.09.25	2,46	568	230,97	23:00	199,92	7,91	4:42	192,64	15,19
22.09.25	2,82	644	228,05	10:32	200,27	7,56	23:48	192,87	14,95
23.09.25	13,05	3.031	232,33	7:44	199,90	7,92	21:55	190,97	16,85
24.09.25	10,26	2.373	231,19	22:09	199,11	8,71	0:22	190,97	16,85
25.09.25	0,00	0	---	19:32	199,71	8,11	---	---	---
26.09.25	0,00	0	---	6:46	199,79	8,04	---	---	---
27.09.25	0,00	0	---	8:21	199,85	7,97	---	---	---
28.09.25	0,00	0	---	7:34	199,87	7,95	---	---	---
29.09.25	18,23	4.213	231,11	4:35	199,86	7,97	23:59	191,54	16,29
30.09.25	23,44	5.373	229,21	---	---	---	10:40	191,09	16,74
Σ	208,59	48.184							
Mittelwert	6,95	1.606	231,00		199,84	7,98		191,78	16,04
Minimum	0,00	0	220,06		198,12	7,07		190,96	14,78
Maximum	24,00	5.564	235,37		200,76	9,70		193,04	16,86

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.09.25	24,00	3.463	144,29	---	---	---	19:31	190,87	21,97
02.09.25	24,00	3.448	143,67	---	---	---	17:19	189,86	22,98
03.09.25	22,83	3.247	142,20	---	---	---	14:15	188,65	24,19
04.09.25	20,49	2.921	142,53	11:35	195,43	17,41	15:43	189,28	23,56
05.09.25	24,00	3.460	144,17	---	---	---	0:05	189,57	23,27
06.09.25	24,00	3.465	144,38	---	---	---	1:11	190,67	22,17
07.09.25	6,38	926	145,04	7:22	193,85	18,98	0:00	190,85	21,98
08.09.25	0,00	0	---	0:00	191,77	21,06	---	---	---
09.09.25	8,64	1.215	140,67	11:50	192,51	20,33	19:42	187,07	25,76
10.09.25	24,00	3.450	143,75	---	---	---	0:00	189,37	23,47
11.09.25	24,00	3.449	143,71	---	---	---	20:52	189,58	23,25
12.09.25	23,38	3.345	143,07	---	---	---	23:58	189,46	23,38
13.09.25	10,28	1.422	138,30	22:32	193,96	18,88	18:32	187,22	25,61
14.09.25	6,75	966	143,19	10:30	195,52	17,32	22:11	191,33	21,51
15.09.25	15,85	2.286	144,19	10:18	195,66	17,18	15:43	190,99	21,84
16.09.25	11,94	1.690	141,55	6:05	195,53	17,30	20:59	189,60	23,24
17.09.25	18,63	2.664	142,96	10:38	195,08	17,76	20:21	189,08	23,76
18.09.25	20,79	2.960	142,36	7:58	194,77	18,07	23:56	187,71	25,12
19.09.25	15,27	2.096	137,29	2:32	191,60	21,23	23:24	186,81	26,02
20.09.25	23,26	3.339	143,56	---	---	---	0:00	187,78	25,06
21.09.25	20,76	2.994	144,20	8:14	194,68	18,16	4:43	189,31	23,53
22.09.25	18,59	2.678	144,07	8:17	195,12	17,71	23:50	189,54	23,30
23.09.25	21,32	3.034	142,29	11:56	193,64	19,20	23:59	187,42	25,41
24.09.25	20,07	2.870	142,98	3:18	191,43	21,40	0:58	187,30	25,53
25.09.25	24,00	3.467	144,46	---	---	---	0:01	190,01	22,82
26.09.25	24,00	3.456	144,00	---	---	---	0:57	190,96	21,88
27.09.25	24,00	3.464	144,33	---	---	---	2:10	190,97	21,86
28.09.25	24,00	3.468	144,50	---	---	---	0:42	191,01	21,83
29.09.25	6,71	959	142,82	6:47	193,94	18,89	1:54	190,90	21,94
30.09.25	2,71	363	134,09	7:12	192,69	20,15	10:39	187,90	24,94
Σ	534,67	76.565							
Mittelwert	17,82	2.552	143,20		193,95	18,88		189,34	23,49
Minimum	0,00	0	134,09		191,43	17,18		186,81	21,51
Maximum	24,00	3.468	145,04		195,66	21,40		191,33	26,02

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Abtutung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	0,00	0	---	4:00	194,55	15,57	---	---	---
02.09.25	0,70	126	180,72	4:49	194,35	15,77	---	---	---
03.09.25	5,34	969	181,63	7:23	194,78	15,34	12:01	177,92	32,20
04.09.25	4,24	786	185,58	11:37	195,16	14,96	12:43	179,23	30,88
05.09.25	0,71	126	176,64	11:23	194,53	15,58	---	---	---
06.09.25	0,00	0	---	9:25	194,38	15,74	---	---	---
07.09.25	17,60	3.360	190,89	6:22	194,58	15,54	13:20	177,00	33,11
08.09.25	24,00	4.508	187,83	---	---	---	0:56	177,00	33,11
09.09.25	18,44	3.489	189,21	23:58	192,64	17,48	0:00	177,00	33,11
10.09.25	1,22	220	180,78	12:40	194,36	15,75	14:22	179,58	30,53
11.09.25	1,01	182	180,74	6:31	194,39	15,72	20:51	179,60	30,52
12.09.25	0,82	156	191,41	12:21	194,20	15,92	---	---	---
13.09.25	18,55	3.499	188,61	23:59	193,62	16,50	2:16	177,00	33,11
14.09.25	0,00	0	---	10:23	194,96	15,16	---	---	---
15.09.25	0,00	0	---	10:17	195,07	15,05	---	---	---
16.09.25	6,70	1.266	188,96	6:13	194,93	15,19	13:00	177,02	33,10
17.09.25	2,78	516	185,67	10:40	194,44	15,68	20:18	178,55	31,57
18.09.25	8,60	1.606	186,82	8:05	194,23	15,89	20:38	177,00	33,11
19.09.25	23,41	4.356	186,07	---	---	---	0:00	177,00	33,11
20.09.25	2,43	450	185,52	13:20	193,68	16,44	14:48	178,42	31,69
21.09.25	2,30	432	187,67	23:02	194,35	15,77	4:41	178,79	31,33
22.09.25	2,66	492	185,10	10:32	194,73	15,39	23:47	179,17	30,94
23.09.25	12,13	2.294	189,15	7:53	194,39	15,72	21:44	177,00	33,11
24.09.25	8,62	1.622	188,11	22:13	193,75	16,36	0:00	177,00	33,11
25.09.25	0,00	0	---	19:12	194,49	15,63	---	---	---
26.09.25	0,00	0	---	6:31	194,61	15,51	---	---	---
27.09.25	0,00	0	---	8:05	194,65	15,46	---	---	---
28.09.25	0,00	0	---	7:28	194,67	15,45	---	---	---
29.09.25	18,18	3.414	187,80	4:26	194,64	15,48	23:48	177,02	33,10
30.09.25	22,67	4.210	185,71	7:59	192,79	17,32	0:16	177,00	33,11
Σ	203,08	38.079							
Mittelwert	6,77	1.269	187,51		194,35	15,76		177,80	32,31
Minimum	0,00	0	176,64		192,64	14,96		177,00	30,52
Maximum	24,00	4.508	191,41		195,16	17,48		179,60	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	15,50	1.855	119,64	3:58	194,38	20,40	23:59	184,45	30,32
02.09.25	17,34	2.067	119,17	4:38	194,11	20,67	17:47	184,20	30,58
03.09.25	14,46	1.702	117,69	8:38	194,70	20,07	14:33	183,87	30,90
04.09.25	13,23	1.567	118,42	11:50	194,99	19,78	5:05	184,20	30,58
05.09.25	11,70	1.395	119,21	11:10	194,62	20,15	0:58	184,24	30,53
06.09.25	13,09	1.560	119,15	9:16	194,30	20,47	0:58	184,39	30,38
07.09.25	18,29	2.203	120,48	6:17	194,56	20,21	23:53	183,31	31,46
08.09.25	23,27	2.774	119,19	---	---	---	23:58	183,02	31,75
09.09.25	21,33	2.564	120,20	14:51	193,26	21,51	0:39	182,96	31,82
10.09.25	12,17	1.447	118,94	12:34	194,69	20,09	2:19	184,47	30,31
11.09.25	14,43	1.721	119,28	6:28	194,38	20,40	21:56	184,32	30,46
12.09.25	21,21	2.530	119,28	5:44	193,77	21,01	22:37	184,18	30,60
13.09.25	24,00	2.886	120,25	---	---	---	13:47	183,20	31,57
14.09.25	24,00	2.928	122,00	---	---	---	0:00	183,98	30,79
15.09.25	24,00	2.912	121,33	---	---	---	6:00	184,32	30,46
16.09.25	24,00	2.884	120,17	---	---	---	13:02	183,51	31,27
17.09.25	24,00	2.887	120,29	---	---	---	8:57	183,72	31,05
18.09.25	24,00	2.896	120,67	---	---	---	21:23	183,68	31,10
19.09.25	24,00	2.860	119,17	---	---	---	21:29	183,16	31,62
20.09.25	24,00	2.907	121,13	---	---	---	0:00	183,36	31,42
21.09.25	24,00	2.923	121,79	---	---	---	2:14	184,30	30,47
22.09.25	24,00	2.930	122,08	---	---	---	0:42	184,45	30,32
23.09.25	24,00	2.906	121,08	---	---	---	23:59	184,03	30,75
24.09.25	24,00	2.914	121,42	---	---	---	6:26	183,63	31,14
25.09.25	20,63	2.499	121,15	---	---	---	0:00	184,50	30,27
26.09.25	13,77	1.644	119,41	6:24	194,61	20,17	19:46	184,88	29,89
27.09.25	11,95	1.425	119,23	7:58	194,69	20,09	16:37	184,90	29,88
28.09.25	11,07	1.324	119,61	2:52	194,72	20,06	23:58	185,05	29,72
29.09.25	12,85	1.507	117,27	4:27	194,72	20,06	23:36	183,57	31,21
30.09.25	13,51	1.575	116,60	8:04	193,46	21,31	17:45	183,29	31,48
Σ	567,81	68.192							
Mittelwert	18,93	2.273	120,10		194,37	20,40		183,97	30,80
Minimum	11,07	1.324	116,60		193,26	19,78		182,96	29,72
Maximum	24,00	2.930	122,08		194,99	21,51		185,05	31,82

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.09.25	15,73	859	54,62	3:55	194,10	19,18	23:45	188,84	24,44
02.09.25	17,51	945	53,97	4:36	193,80	19,48	23:57	188,64	24,64
03.09.25	14,54	775	53,29	8:21	194,60	18,68	0:05	188,59	24,69
04.09.25	13,38	719	53,75	12:31	195,68	17,60	5:24	188,54	24,74
05.09.25	11,86	644	54,30	11:14	194,48	18,80	1:29	188,86	24,42
06.09.25	13,30	725	54,51	9:09	194,03	19,25	1:05	188,79	24,49
07.09.25	18,37	1.036	56,40	6:14	194,30	18,98	13:07	189,07	24,21
08.09.25	23,34	1.299	55,65	---	---	---	23:57	188,64	24,64
09.09.25	21,37	1.210	56,63	14:50	194,68	18,60	0:00	188,64	24,64
10.09.25	12,37	675	54,56	12:28	195,27	18,01	18:43	189,16	24,12
11.09.25	14,62	794	54,30	6:25	194,25	19,03	23:03	188,81	24,47
12.09.25	21,32	1.153	54,07	0:21	193,60	19,68	22:38	188,54	24,74
13.09.25	24,00	1.358	56,58	---	---	---	23:54	188,94	24,34
14.09.25	24,00	1.354	56,42	---	---	---	4:45	188,59	24,69
15.09.25	24,00	1.337	55,71	---	---	---	6:03	188,59	24,69
16.09.25	23,33	1.283	55,00	---	---	---	3:45	188,62	24,66
17.09.25	24,00	1.320	55,00	---	---	---	8:57	188,19	25,09
18.09.25	24,00	1.353	56,38	---	---	---	2:29	189,19	24,09
19.09.25	24,00	1.352	56,33	---	---	---	0:24	190,09	23,19
20.09.25	24,00	1.368	57,00	---	---	---	3:51	189,66	23,62
21.09.25	24,00	1.377	57,38	---	---	---	2:13	189,86	23,42
22.09.25	24,00	1.382	57,58	---	---	---	1:45	190,07	23,21
23.09.25	24,00	1.380	57,50	---	---	---	2:35	190,12	23,16
24.09.25	24,00	1.385	57,71	---	---	---	23:40	190,36	22,92
25.09.25	20,70	1.177	56,85	---	---	---	23:58	189,94	23,34
26.09.25	13,90	761	54,77	6:20	194,65	18,63	19:51	189,38	23,90
27.09.25	12,07	659	54,62	7:57	194,55	18,73	16:41	189,34	23,94
28.09.25	11,16	613	54,91	2:47	194,53	18,75	23:58	189,47	23,81
29.09.25	12,94	694	53,63	4:27	194,60	18,68	23:45	188,81	24,47
30.09.25	16,34	867	53,07	8:04	193,83	19,45	17:47	188,52	24,76
Σ	572,15	31.854							
Mittelwert	19,07	1.062	55,67		194,43	18,85		189,10	24,18
Minimum	11,16	613	53,07		193,60	17,60		188,19	22,92
Maximum	24,00	1.385	57,71		195,68	19,68		190,36	25,09

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	2.567	106,96	---	---	---	19:17	193,30	23,50
02.09.25	24,00	2.553	106,38	---	---	---	11:55	193,22	23,58
03.09.25	22,74	2.413	106,11	7:22	200,10	16,70	0:21	193,17	23,63
04.09.25	19,81	2.109	106,43	12:43	201,25	15,55	5:32	193,15	23,65
05.09.25	23,33	2.503	107,27	---	---	---	1:44	193,37	23,43
06.09.25	24,00	2.571	107,13	---	---	---	1:26	193,24	23,56
07.09.25	12,98	1.394	107,41	20:46	201,02	15,78	0:02	193,37	23,43
08.09.25	13,02	1.386	106,49	5:53	201,25	15,55	23:48	193,94	22,86
09.09.25	6,51	705	108,36	20:11	201,36	15,44	23:52	194,03	22,77
10.09.25	21,48	2.309	107,48	12:06	200,84	15,96	21:42	193,60	23,20
11.09.25	24,00	2.566	106,92	---	---	---	23:10	193,40	23,40
12.09.25	23,31	2.471	105,99	---	---	---	11:57	193,22	23,58
13.09.25	5,46	598	109,61	18:14	201,40	15,40	23:52	193,71	23,09
14.09.25	22,35	2.428	108,66	---	---	---	23:39	193,40	23,40
15.09.25	22,21	2.395	107,83	---	---	---	1:15	193,39	23,41
16.09.25	20,48	2.193	107,06	13:23	200,69	16,11	5:44	193,28	23,52
17.09.25	23,57	2.571	109,10	---	---	---	15:26	192,84	23,96
18.09.25	19,35	2.215	114,45	23:48	201,36	15,44	2:51	194,27	22,53
19.09.25	0,56	66	118,33	15:15	201,57	15,23	---	---	---
20.09.25	24,00	2.766	115,25	---	---	---	3:47	194,79	22,01
21.09.25	24,00	2.774	115,58	---	---	---	2:39	194,79	22,01
22.09.25	24,00	2.778	115,75	---	---	---	1:41	194,95	21,85
23.09.25	7,66	887	115,81	22:49	201,98	14,82	2:22	194,97	21,83
24.09.25	12,82	1.475	115,04	10:58	202,14	14,66	21:47	195,22	21,58
25.09.25	15,96	1.749	109,62	8:05	201,94	14,86	21:58	194,21	22,59
26.09.25	24,00	2.577	107,38	---	---	---	20:06	193,75	23,05
27.09.25	24,00	2.578	107,42	---	---	---	17:02	193,65	23,15
28.09.25	24,00	2.581	107,54	---	---	---	22:21	193,68	23,12
29.09.25	23,18	2.469	106,53	---	---	---	23:52	193,56	23,24
30.09.25	23,86	2.526	105,86	---	---	---	18:00	193,38	23,42
Σ	580,63	63.173							
Mittelwert	19,35	2.106	108,80		201,30	15,50		193,75	23,05
Minimum	0,56	66	105,86		200,10	14,66		192,84	21,58
Maximum	24,00	2.778	118,33		202,14	16,70		195,22	23,96

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Abtutung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.09.25	24,00	4.260	177,50	---	---	---	19:19	179,69	41,46
02.09.25	24,00	4.222	175,92	---	---	---	11:56	179,59	41,56
03.09.25	22,97	4.025	175,24	---	---	---	6:23	178,27	42,88
04.09.25	19,79	3.492	176,43	12:47	196,87	24,28	6:47	179,04	42,11
05.09.25	23,34	4.172	178,74	---	---	---	3:30	179,41	41,74
06.09.25	24,00	4.285	178,54	---	---	---	6:55	179,62	41,53
07.09.25	13,07	2.338	178,84	20:43	196,90	24,25	0:00	179,66	41,49
08.09.25	13,09	2.317	177,00	5:44	197,20	23,95	23:51	180,63	40,52
09.09.25	9,81	1.809	184,40	20:20	197,37	23,78	12:56	180,41	40,74
10.09.25	21,54	3.866	179,51	12:06	196,42	24,73	5:33	179,88	41,27
11.09.25	24,00	4.265	177,71	---	---	---	23:14	179,91	41,24
12.09.25	23,34	4.091	175,31	---	---	---	12:07	179,41	41,74
13.09.25	5,45	1.016	186,44	17:51	197,47	23,68	23:53	180,04	41,11
14.09.25	22,38	4.101	183,26	---	---	---	4:42	179,24	41,91
15.09.25	22,25	4.019	180,66	---	---	---	5:59	179,16	41,99
16.09.25	20,51	3.658	178,39	13:24	196,33	24,82	4:56	179,46	41,69
17.09.25	15,03	2.668	177,52	23:54	195,90	25,25	8:56	178,85	42,30
18.09.25	0,00	0	---	23:43	197,42	23,73	---	---	---
19.09.25	0,00	0	---	20:53	197,79	23,36	---	---	---
20.09.25	0,00	0	---	0:00	197,37	23,78	---	---	---
21.09.25	0,00	0	---	23:42	196,92	24,23	---	---	---
22.09.25	0,00	0	---	13:51	197,04	24,11	---	---	---
23.09.25	0,00	0	---	23:55	198,20	22,95	---	---	---
24.09.25	0,00	0	---	11:07	198,41	22,74	---	---	---
25.09.25	12,46	2.252	180,80	8:14	198,13	23,02	21:57	180,77	40,38
26.09.25	24,00	4.306	179,42	---	---	---	20:10	180,22	40,93
27.09.25	24,00	4.304	179,33	---	---	---	17:00	180,02	41,13
28.09.25	24,00	4.313	179,71	---	---	---	22:26	180,00	41,15
29.09.25	23,21	4.097	176,53	---	---	---	1:49	179,52	41,63
30.09.25	23,87	4.181	175,13	---	---	---	6:48	179,41	41,74
Σ	460,09	82.057							
Mittelwert	15,34	2.735	178,35		197,23	23,92		179,66	41,49
Minimum	0,00	0	175,13		195,90	22,74		178,27	40,38
Maximum	24,00	4.313	186,44		198,41	25,25		180,77	42,88

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	0,00	0	---	---	---	---	---	---	---
02.09.25	0,00	0	---	2:07	188,02	39,51	---	---	---
03.09.25	0,00	0	---	5:30	188,02	39,51	---	---	---
04.09.25	0,00	0	---	5:55	188,02	39,51	---	---	---
05.09.25	0,00	0	---	23:55	188,02	39,51	---	---	---
06.09.25	0,00	0	---	2:31	188,02	39,51	---	---	---
07.09.25	0,00	0	---	4:09	188,02	39,51	---	---	---
08.09.25	0,00	0	---	22:19	188,02	39,51	---	---	---
09.09.25	0,00	0	---	2:07	188,02	39,51	---	---	---
10.09.25	0,00	0	---	9:48	188,02	39,51	---	---	---
11.09.25	0,00	0	---	0:17	188,02	39,51	---	---	---
12.09.25	0,00	0	---	23:16	188,02	39,51	---	---	---
13.09.25	0,00	0	---	3:29	188,02	39,51	---	---	---
14.09.25	0,00	0	---	2:54	188,02	39,51	---	---	---
15.09.25	0,00	0	---	3:55	188,02	39,51	---	---	---
16.09.25	0,00	0	---	0:00	188,01	39,51	---	---	---
17.09.25	0,00	0	---	3:10	188,02	39,51	---	---	---
18.09.25	0,00	0	---	0:56	188,02	39,51	---	---	---
19.09.25	0,00	0	---	17:58	188,02	39,51	---	---	---
20.09.25	0,00	0	---	1:11	188,02	39,51	---	---	---
21.09.25	0,00	0	---	8:00	188,02	39,51	---	---	---
22.09.25	0,00	0	---	15:56	188,02	39,51	---	---	---
23.09.25	0,00	0	---	7:55	188,02	39,51	---	---	---
24.09.25	0,00	0	---	1:17	188,02	39,51	---	---	---
25.09.25	0,00	0	---	6:28	188,02	39,51	---	---	---
26.09.25	0,00	0	---	6:53	188,02	39,51	---	---	---
27.09.25	0,00	0	---	7:14	188,02	39,51	---	---	---
28.09.25	0,00	0	---	6:40	188,02	39,51	---	---	---
29.09.25	0,00	0	---	6:05	188,02	39,51	---	---	---
30.09.25	0,00	0	---	8:18	188,02	39,51	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,01	39,51		---	---
Minimum	0,00	0	---		188,01	39,51		---	---
Maximum	0,00	0	---		188,02	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.09.25	24,00	1.551	64,63	---	---	---	23:54	192,69	42,78
02.09.25	24,00	1.572	65,50	---	---	---	0:43	192,65	42,82
03.09.25	22,91	1.508	65,83	---	---	---	11:47	192,82	42,65
04.09.25	19,96	1.301	65,16	12:43	198,03	37,43	8:54	192,76	42,71
05.09.25	23,40	1.507	64,39	---	---	---	21:00	192,82	42,64
06.09.25	24,00	1.499	62,46	---	---	---	14:02	192,87	42,59
07.09.25	13,29	894	67,25	20:41	198,33	37,13	6:16	193,13	42,33
08.09.25	13,45	969	72,07	5:46	198,55	36,91	15:54	193,09	42,37
09.09.25	12,79	887	69,37	20:20	198,64	36,83	23:25	193,39	42,07
10.09.25	21,70	1.412	65,06	12:03	197,99	37,48	7:25	193,16	42,30
11.09.25	24,00	1.538	64,08	---	---	---	17:32	192,77	42,69
12.09.25	23,33	1.490	63,86	---	---	---	23:07	192,73	42,73
13.09.25	5,51	368	66,77	18:20	198,79	36,67	23:23	193,44	42,02
14.09.25	22,49	1.487	66,11	---	---	---	18:42	193,04	42,42
15.09.25	23,61	1.532	64,89	---	---	---	19:54	192,95	42,52
16.09.25	24,00	1.546	64,42	---	---	---	9:26	192,68	42,78
17.09.25	15,41	985	63,92	23:54	198,21	37,25	12:26	192,81	42,65
18.09.25	0,00	0	---	23:50	198,78	36,68	---	---	---
19.09.25	0,00	0	---	22:24	199,10	36,37	---	---	---
20.09.25	0,00	0	---	0:00	199,09	36,37	---	---	---
21.09.25	0,00	0	---	18:13	199,02	36,44	---	---	---
22.09.25	0,00	0	---	17:04	199,08	36,38	---	---	---
23.09.25	12,68	724	57,09	23:58	199,09	36,37	19:59	194,29	41,18
24.09.25	3,78	228	60,33	10:54	199,33	36,13	17:39	194,33	41,13
25.09.25	13,13	870	66,26	7:58	199,15	36,31	20:26	193,28	42,19
26.09.25	24,00	1.462	60,92	---	---	---	4:53	193,24	42,23
27.09.25	24,00	1.471	61,29	---	---	---	9:35	192,91	42,55
28.09.25	24,00	1.446	60,25	---	---	---	18:47	192,93	42,53
29.09.25	23,33	1.465	62,80	---	---	---	4:06	192,83	42,63
30.09.25	23,92	1.493	62,42	---	---	---	12:20	192,79	42,68
Σ	486,70	31.205							
Mittelwert	16,22	1.040	64,12		198,74	36,72		193,05	42,41
Minimum	0,00	0	57,09		197,99	36,13		192,65	41,13
Maximum	24,00	1.572	72,07		199,33	37,48		194,33	42,82

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:32 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	3.813	158,88	---	---	---	23:44	192,04	52,78
02.09.25	24,00	3.794	158,08	---	---	---	23:38	191,99	52,83
03.09.25	20,67	3.302	159,74	9:35	195,86	48,96	0:53	191,98	52,84
04.09.25	19,73	3.176	160,94	13:55	196,03	48,80	6:48	191,93	52,89
05.09.25	24,00	3.856	160,67	---	---	---	21:41	192,02	52,80
06.09.25	24,00	3.820	159,17	---	---	---	5:03	191,90	52,92
07.09.25	6,43	1.026	159,59	20:42	196,39	48,44	0:00	192,01	52,81
08.09.25	0,00	0	---	5:50	196,54	48,28	---	---	---
09.09.25	4,35	691	158,98	19:48	196,70	48,12	23:55	192,92	51,90
10.09.25	24,00	3.765	156,88	---	---	---	21:40	192,43	52,39
11.09.25	24,00	3.657	152,38	---	---	---	20:09	192,30	52,52
12.09.25	23,51	3.456	147,00	---	---	---	23:43	192,24	52,58
13.09.25	11,34	1.747	154,09	17:07	196,16	48,67	0:25	192,22	52,60
14.09.25	7,58	1.184	156,26	10:10	196,39	48,44	22:21	192,97	51,85
15.09.25	10,73	1.644	153,18	17:01	196,37	48,45	23:37	192,75	52,07
16.09.25	12,66	1.948	153,86	14:43	196,32	48,50	23:28	192,55	52,27
17.09.25	19,25	2.933	152,36	10:36	195,64	49,18	19:13	192,46	52,36
18.09.25	21,29	3.281	154,10	---	---	---	0:25	192,58	52,24
19.09.25	16,03	2.448	152,76	4:59	196,25	48,58	23:59	192,88	51,94
20.09.25	23,38	3.507	149,98	---	---	---	2:37	192,72	52,10
21.09.25	21,26	3.241	152,42	8:08	195,83	49,00	4:36	192,79	52,04
22.09.25	19,34	3.006	155,39	1:57	195,98	48,84	0:15	192,89	51,93
23.09.25	6,77	1.029	151,97	22:18	196,94	47,88	2:21	192,82	52,00
24.09.25	12,93	2.003	154,93	10:16	197,04	47,78	22:13	193,12	51,70
25.09.25	24,00	3.711	154,63	---	---	---	21:54	192,69	52,13
26.09.25	24,00	3.666	152,75	---	---	---	21:10	192,47	52,35
27.09.25	24,00	3.658	152,42	---	---	---	7:41	192,41	52,41
28.09.25	24,00	3.611	150,46	---	---	---	0:34	192,39	52,43
29.09.25	6,89	1.061	153,94	14:53	196,31	48,51	1:53	192,38	52,45
30.09.25	2,55	397	155,96	7:27	196,34	48,48	10:42	192,89	51,93
Σ	506,70	78.431							
Mittelwert	16,89	2.614	154,79		196,30	48,52		192,47	52,35
Minimum	0,00	0	147,00		195,64	47,78		191,90	51,70
Maximum	24,00	3.856	160,94		197,04	49,18		193,12	52,92

Meßpunkthöhe (MP): 244,82 m üNN