

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB02
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:27 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	1.736	72,33	---	---	---	1:08	197,74	17,35
02.09.25	24,00	1.730	72,08	---	---	---	1:29	197,73	17,37
03.09.25	21,69	1.563	72,05	13:48	198,72	16,37	6:39	197,69	17,40
04.09.25	21,72	1.564	72,00	11:26	198,71	16,38	9:12	197,70	17,40
05.09.25	24,00	1.738	72,42	---	---	---	3:43	197,71	17,38
06.09.25	24,00	1.741	72,54	---	---	---	5:16	197,71	17,38
07.09.25	24,00	1.747	72,79	---	---	---	8:41	197,71	17,38
08.09.25	24,00	1.732	72,17	---	---	---	11:39	197,71	17,38
09.09.25	24,00	1.745	72,71	---	---	---	13:12	197,70	17,39
10.09.25	24,00	1.733	72,21	---	---	---	6:02	197,68	17,41
11.09.25	24,00	1.715	71,46	---	---	---	6:06	197,72	17,37
12.09.25	24,00	1.711	71,29	---	---	---	11:50	197,72	17,37
13.09.25	24,00	1.741	72,54	---	---	---	19:34	197,69	17,40
14.09.25	24,00	1.758	73,25	---	---	---	4:56	197,69	17,40
15.09.25	24,00	1.746	72,75	---	---	---	6:02	197,73	17,37
16.09.25	24,00	1.736	72,33	---	---	---	13:10	197,72	17,37
17.09.25	24,00	1.733	72,21	---	---	---	9:08	197,68	17,41
18.09.25	24,00	1.724	71,83	---	---	---	7:16	197,67	17,42
19.09.25	24,00	1.713	71,38	---	---	---	18:15	197,67	17,43
20.09.25	24,00	1.730	72,08	---	---	---	3:57	197,63	17,47
21.09.25	21,41	1.551	72,45	4:36	198,67	16,43	2:12	197,65	17,44
22.09.25	24,00	1.731	72,13	---	---	---	0:54	197,67	17,43
23.09.25	24,00	1.721	71,71	---	---	---	11:50	197,65	17,44
24.09.25	24,00	1.726	71,92	---	---	---	9:29	197,63	17,47
25.09.25	24,00	1.726	71,92	---	---	---	3:45	197,64	17,45
26.09.25	24,00	1.719	71,63	---	---	---	1:10	197,67	17,43
27.09.25	24,00	1.723	71,79	---	---	---	4:49	197,67	17,43
28.09.25	24,00	1.726	71,92	---	---	---	1:35	197,67	17,42
29.09.25	24,00	1.712	71,33	---	---	---	2:08	197,67	17,43
30.09.25	24,00	1.706	71,08	---	---	---	10:43	197,69	17,40
Σ	712,83	51.377							
Mittelwert	23,76	1.713	72,07		198,70	16,39		197,68	17,41
Minimum	21,41	1.551	71,08		198,67	16,37		197,63	17,35
Maximum	24,00	1.758	73,25		198,72	16,43		197,74	17,47

Meßpunkthöhe (MP): 215,09 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB05
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:27 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	517	21,54	---	---	---	20:05	195,09	14,49
02.09.25	24,00	515	21,46	---	---	---	18:05	195,07	14,51
03.09.25	21,68	468	21,59	13:51	196,13	13,45	6:57	195,03	14,55
04.09.25	21,73	469	21,59	11:28	196,12	13,46	9:15	195,00	14,58
05.09.25	24,00	517	21,54	---	---	---	11:10	195,06	14,53
06.09.25	24,00	516	21,50	---	---	---	7:41	195,05	14,53
07.09.25	24,00	519	21,63	---	---	---	1:13	195,06	14,53
08.09.25	24,00	516	21,50	---	---	---	11:58	195,14	14,44
09.09.25	24,00	518	21,58	---	---	---	12:54	195,09	14,49
10.09.25	24,00	515	21,46	---	---	---	5:34	195,08	14,50
11.09.25	24,00	512	21,33	---	---	---	0:44	195,09	14,50
12.09.25	24,00	510	21,25	---	---	---	11:48	195,08	14,50
13.09.25	24,00	517	21,54	---	---	---	1:04	195,06	14,53
14.09.25	24,00	521	21,71	---	---	---	4:44	195,09	14,49
15.09.25	24,00	517	21,54	---	---	---	6:00	195,11	14,47
16.09.25	24,00	515	21,46	---	---	---	0:45	195,09	14,49
17.09.25	24,00	514	21,42	---	---	---	9:06	195,02	14,57
18.09.25	24,00	512	21,33	---	---	---	7:02	195,00	14,58
19.09.25	24,00	510	21,25	---	---	---	0:35	195,02	14,57
20.09.25	24,00	513	21,38	---	---	---	3:45	195,00	14,58
21.09.25	21,39	460	21,50	4:44	196,06	13,53	2:07	194,97	14,61
22.09.25	24,00	515	21,46	---	---	---	0:49	194,97	14,61
23.09.25	24,00	512	21,33	---	---	---	2:29	194,95	14,63
24.09.25	24,00	513	21,38	---	---	---	10:45	194,94	14,64
25.09.25	24,00	513	21,38	---	---	---	6:40	194,92	14,66
26.09.25	24,00	511	21,29	---	---	---	0:35	194,95	14,63
27.09.25	24,00	511	21,29	---	---	---	1:20	194,99	14,60
28.09.25	24,00	513	21,38	---	---	---	2:41	194,99	14,60
29.09.25	24,00	511	21,29	---	---	---	1:50	194,99	14,60
30.09.25	24,00	509	21,21	---	---	---	10:41	195,09	14,49
Σ	712,80	15.279							
Mittelwert	23,76	509	21,44		196,10	13,48		195,03	14,55
Minimum	21,39	460	21,21		196,06	13,45		194,92	14,44
Maximum	24,00	521	21,71		196,13	13,53		195,14	14,66

Meßpunkthöhe (MP): 209,58 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB06
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:27 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	671	27,96	---	---	---	12:21	194,95	12,04
02.09.25	24,00	665	27,71	---	---	---	12:27	194,92	12,07
03.09.25	21,67	605	27,92	13:47	196,60	10,39	7:01	194,82	12,17
04.09.25	21,70	603	27,79	11:32	196,60	10,39	9:13	194,79	12,20
05.09.25	24,00	673	28,04	---	---	---	3:34	194,88	12,11
06.09.25	24,00	674	28,08	---	---	---	7:42	194,90	12,09
07.09.25	24,00	681	28,38	---	---	---	8:40	194,87	12,12
08.09.25	24,00	671	27,96	---	---	---	11:54	194,94	12,05
09.09.25	24,00	680	28,33	---	---	---	13:14	194,95	12,05
10.09.25	24,00	672	28,00	---	---	---	11:59	194,87	12,12
11.09.25	24,00	664	27,67	---	---	---	0:46	194,94	12,05
12.09.25	24,00	655	27,29	---	---	---	11:51	194,90	12,09
13.09.25	24,00	677	28,21	---	---	---	1:44	194,90	12,09
14.09.25	24,00	689	28,71	---	---	---	4:45	194,87	12,12
15.09.25	24,00	679	28,29	---	---	---	9:25	194,87	12,12
16.09.25	24,00	671	27,96	---	---	---	13:01	194,91	12,08
17.09.25	24,00	666	27,75	---	---	---	9:07	194,81	12,18
18.09.25	24,00	662	27,58	---	---	---	7:15	194,81	12,18
19.09.25	24,00	658	27,42	---	---	---	8:55	194,86	12,13
20.09.25	24,00	667	27,79	---	---	---	3:49	194,82	12,17
21.09.25	21,38	600	28,07	4:40	196,52	10,47	2:11	194,76	12,23
22.09.25	24,00	668	27,83	---	---	---	1:23	194,81	12,18
23.09.25	24,00	660	27,50	---	---	---	11:20	194,76	12,23
24.09.25	24,00	665	27,71	---	---	---	10:24	194,78	12,21
25.09.25	24,00	664	27,67	---	---	---	6:31	194,76	12,23
26.09.25	24,00	658	27,42	---	---	---	0:41	194,84	12,15
27.09.25	24,00	662	27,58	---	---	---	2:08	194,85	12,14
28.09.25	24,00	666	27,75	---	---	---	1:25	194,85	12,14
29.09.25	24,00	660	27,50	---	---	---	1:52	194,81	12,18
30.09.25	24,00	655	27,29	---	---	---	10:43	194,87	12,12
Σ	712,74	19.841							
Mittelwert	23,76	661	27,84		196,57	10,42		194,85	12,14
Minimum	21,38	600	27,29		196,52	10,39		194,76	12,04
Maximum	24,00	689	28,71		196,60	10,47		194,95	12,23

Meßpunkthöhe (MP): 206,99 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB07
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:27 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.09.25	24,00	1.283	53,46	---	---	---	19:57	194,19	8,48
02.09.25	24,00	1.279	53,29	---	---	---	12:22	194,16	8,51
03.09.25	21,66	1.157	53,43	13:50	196,27	6,40	6:25	194,11	8,56
04.09.25	21,67	1.157	53,40	11:28	196,29	6,38	9:12	194,14	8,53
05.09.25	24,00	1.281	53,38	---	---	---	7:58	194,16	8,51
06.09.25	24,00	1.282	53,42	---	---	---	8:00	194,13	8,54
07.09.25	24,00	1.285	53,54	---	---	---	0:00	194,16	8,51
08.09.25	24,00	1.281	53,38	---	---	---	17:29	194,20	8,47
09.09.25	24,00	1.284	53,50	---	---	---	23:39	194,16	8,51
10.09.25	24,00	1.280	53,33	---	---	---	5:34	194,14	8,53
11.09.25	24,00	1.276	53,17	---	---	---	23:18	194,16	8,51
12.09.25	24,00	1.272	53,00	---	---	---	11:48	194,14	8,53
13.09.25	24,00	1.283	53,46	---	---	---	4:56	194,14	8,53
14.09.25	24,00	1.287	53,63	---	---	---	5:12	194,16	8,51
15.09.25	24,00	1.283	53,46	---	---	---	9:25	194,16	8,51
16.09.25	24,00	1.281	53,38	---	---	---	8:04	194,16	8,51
17.09.25	24,00	1.279	53,29	---	---	---	10:28	194,08	8,59
18.09.25	24,00	1.276	53,17	---	---	---	7:41	194,07	8,60
19.09.25	24,00	1.274	53,08	---	---	---	1:28	194,11	8,57
20.09.25	24,00	1.277	53,21	---	---	---	4:15	194,11	8,56
21.09.25	21,36	1.138	53,28	4:50	196,28	6,39	2:11	194,10	8,57
22.09.25	24,00	1.276	53,17	---	---	---	23:55	194,08	8,59
23.09.25	24,00	1.273	53,04	---	---	---	11:41	194,02	8,65
24.09.25	24,00	1.276	53,17	---	---	---	10:34	194,13	8,54
25.09.25	24,00	1.276	53,17	---	---	---	2:28	194,11	8,56
26.09.25	24,00	1.274	53,08	---	---	---	0:52	194,13	8,54
27.09.25	24,00	1.276	53,17	---	---	---	1:19	194,14	8,53
28.09.25	24,00	1.277	53,21	---	---	---	11:53	194,08	8,59
29.09.25	24,00	1.275	53,13	---	---	---	2:09	194,07	8,60
30.09.25	23,46	1.246	53,11	---	---	---	21:37	194,13	8,54
Σ	712,14	37.944							
Mittelwert	23,74	1.265	53,28		196,28	6,39		194,13	8,54
Minimum	21,36	1.138	53,00		196,27	6,38		194,02	8,47
Maximum	24,00	1.287	53,63		196,29	6,40		194,20	8,65

Meßpunkthöhe (MP): 202,67 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB08
Monatsbericht vom September 2025
gedruckt am: 02.10.2025, 08:27 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.09.25	24,00	1.157	48,21	---	---	---	11:59	194,71	10,58
02.09.25	24,00	1.153	48,04	---	---	---	11:52	194,69	10,61
03.09.25	21,65	1.043	48,19	13:51	196,76	8,53	7:06	194,64	10,65
04.09.25	21,59	1.040	48,17	11:24	196,78	8,51	6:48	194,71	10,58
05.09.25	24,00	1.159	48,29	---	---	---	21:11	194,71	10,58
06.09.25	24,00	1.160	48,33	---	---	---	1:33	194,69	10,60
07.09.25	24,00	1.161	48,38	---	---	---	8:39	194,69	10,61
08.09.25	24,00	1.157	48,21	---	---	---	11:37	194,75	10,55
09.09.25	24,00	1.162	48,42	---	---	---	13:13	194,72	10,57
10.09.25	24,00	1.156	48,17	---	---	---	5:36	194,70	10,59
11.09.25	24,00	1.146	47,75	---	---	---	0:15	194,72	10,57
12.09.25	24,00	1.143	47,63	---	---	---	12:10	194,69	10,60
13.09.25	24,00	1.159	48,29	---	---	---	5:34	194,69	10,60
14.09.25	24,00	1.165	48,54	---	---	---	5:06	194,69	10,60
15.09.25	24,00	1.159	48,29	---	---	---	9:08	194,70	10,59
16.09.25	24,00	1.156	48,17	---	---	---	2:50	194,70	10,59
17.09.25	24,00	1.153	48,04	---	---	---	9:00	194,64	10,65
18.09.25	24,00	1.146	47,75	---	---	---	7:41	194,62	10,67
19.09.25	24,00	1.144	47,67	---	---	---	8:51	194,66	10,64
20.09.25	24,00	1.149	47,88	---	---	---	3:52	194,64	10,65
21.09.25	21,34	1.024	47,98	4:47	196,72	8,57	22:54	194,63	10,66
22.09.25	24,00	1.147	47,79	---	---	---	20:46	194,62	10,67
23.09.25	24,00	1.141	47,54	---	---	---	11:17	194,59	10,70
24.09.25	24,00	1.146	47,75	---	---	---	9:39	194,59	10,70
25.09.25	24,00	1.146	47,75	---	---	---	6:31	194,58	10,71
26.09.25	24,00	1.144	47,67	---	---	---	2:35	194,61	10,68
27.09.25	24,00	1.147	47,79	---	---	---	21:49	194,63	10,66
28.09.25	24,00	1.148	47,83	---	---	---	0:08	194,64	10,65
29.09.25	24,00	1.147	47,79	---	---	---	1:50	194,62	10,67
30.09.25	23,29	1.110	47,66	---	---	---	6:46	194,70	10,59
Σ	711,87	34.168							
Mittelwert	23,73	1.139	48,00		196,75	8,54		194,67	10,62
Minimum	21,34	1.024	47,54		196,72	8,51		194,58	10,55
Maximum	24,00	1.165	48,54		196,78	8,57		194,75	10,71

Meßpunkthöhe (MP): 205,29 m üNN