

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom Oktober 2025
gedruckt am: 16.11.2025, 10:00 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.10.25	15,51	1.584	102,12	8:28	199,32	14,95	22:33	193,85	20,43
02.10.25	24,00	2.451	102,13	---	---	---	23:37	193,69	20,59
03.10.25	16,00	1.644	102,73	23:53	199,24	15,04	0:00	193,75	20,53
04.10.25	0,00	0	---	23:32	199,69	14,58	---	---	---
05.10.25	0,00	0	---	8:58	199,83	14,44	---	---	---
06.10.25	18,14	1.862	102,66	3:57	199,77	14,50	23:58	193,98	20,30
07.10.25	23,39	2.408	102,94	---	---	---	11:50	193,93	20,34
08.10.25	24,00	2.462	102,58	---	---	---	23:18	193,81	20,46
09.10.25	8,87	912	102,79	16:06	198,89	15,39	1:42	193,87	20,40
10.10.25	16,89	1.725	102,15	5:43	199,28	14,99	21:59	193,72	20,55
11.10.25	24,00	2.447	101,96	---	---	---	23:13	193,50	20,77
12.10.25	24,00	2.449	102,04	---	---	---	23:10	193,43	20,85
13.10.25	24,00	2.446	101,92	---	---	---	23:31	193,39	20,88
14.10.25	9,14	934	102,17	19:00	198,89	15,38	0:33	193,34	20,93
15.10.25	18,71	1.910	102,11	4:02	199,13	15,14	19:51	193,72	20,56
16.10.25	24,00	2.448	102,00	---	---	---	19:53	193,63	20,65
17.10.25	24,00	2.454	102,25	---	---	---	17:45	193,62	20,66
18.10.25	7,55	770	101,95	22:58	198,69	15,59	4:05	193,72	20,56
19.10.25	0,79	81	102,07	8:47	199,08	15,19	---	---	---
20.10.25	1,42	145	101,77	6:31	198,89	15,39	---	---	---
21.10.25	1,97	202	102,74	11:44	199,18	15,10	8:59	194,42	19,85
22.10.25	4,06	413	101,67	0:09	198,90	15,37	20:08	194,44	19,84
23.10.25	18,78	1.907	101,54	4:43	198,85	15,43	18:33	193,86	20,41
24.10.25	23,07	2.348	101,78	---	---	---	22:56	193,72	20,56
25.10.25	24,00	2.457	102,38	---	---	---	2:00	193,72	20,56
26.10.25	7,35	753	102,47	12:21	198,87	15,40	0:14	193,87	20,40
27.10.25	4,33	443	102,36	5:53	199,18	15,10	22:58	194,20	20,07
28.10.25	20,97	2.134	101,75	12:01	198,85	15,43	23:32	193,95	20,33
29.10.25	24,00	2.445	101,88	---	---	---	23:58	193,85	20,43
30.10.25	24,00	2.441	101,71	---	---	---	23:21	193,70	20,57
31.10.25	24,00	2.448	102,00	---	---	---	17:12	193,69	20,59
Σ	480,95	49.123							
Mittelwert	15,51	1.585	102,14		199,14	15,13		193,79	20,48
Minimum	0,00	0	101,54		198,69	14,44		193,34	19,84
Maximum	24,00	2.462	102,94		199,83	15,59		194,44	20,93

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom Oktober 2025
gedruckt am: 16.11.2025, 10:00 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.10.25	14,61	1.963	134,32	8:51	200,52	13,70	22:24	195,33	18,90
02.10.25	15,83	2.102	132,80	8:53	200,15	14,07	23:29	195,19	19,03
03.10.25	11,06	1.496	135,31	23:57	200,51	13,71	5:05	195,40	18,83
04.10.25	8,56	1.194	139,50	23:30	201,05	13,18	17:27	196,03	18,19
05.10.25	7,68	1.076	140,08	9:35	201,27	12,96	11:40	196,24	17,98
06.10.25	14,62	1.973	134,95	3:55	201,14	13,08	23:56	195,49	18,74
07.10.25	10,53	1.437	136,41	19:32	200,58	13,64	11:56	195,16	19,06
08.10.25	14,63	1.953	133,53	7:20	200,67	13,55	23:10	195,38	18,84
09.10.25	18,46	2.527	136,90	8:16	200,40	13,83	23:56	195,26	18,96
10.10.25	20,87	2.793	133,83	5:44	200,47	13,75	21:59	195,01	19,22
11.10.25	24,00	3.180	132,50	---	---	---	23:23	194,79	19,44
12.10.25	24,00	3.190	132,92	---	---	---	21:59	194,71	19,51
13.10.25	24,00	3.162	131,75	---	---	---	23:59	194,66	19,57
14.10.25	17,27	2.316	134,09	18:57	199,97	14,25	0:30	194,56	19,67
15.10.25	16,16	2.141	132,53	3:59	200,25	13,97	19:43	195,18	19,04
16.10.25	16,19	2.134	131,77	6:02	199,98	14,24	14:15	195,14	19,09
17.10.25	13,93	1.851	132,85	9:44	199,95	14,28	17:35	195,13	19,09
18.10.25	20,82	2.828	135,86	5:36	199,99	14,23	21:52	195,08	19,15
19.10.25	21,45	2.948	137,44	---	---	---	3:50	194,98	19,24
20.10.25	24,00	3.242	135,08	---	---	---	11:40	195,17	19,05
21.10.25	20,99	2.852	135,89	11:45	200,37	13,86	8:46	194,92	19,31
22.10.25	24,00	3.213	133,88	---	---	---	22:42	195,06	19,16
23.10.25	19,77	2.626	132,80	9:00	199,85	14,37	1:43	195,11	19,12
24.10.25	15,88	2.104	132,48	5:25	199,97	14,25	10:16	195,01	19,22
25.10.25	9,84	1.310	133,12	14:25	200,41	13,81	1:57	195,24	18,99
26.10.25	18,47	2.537	137,36	6:13	200,47	13,76	23:17	195,26	18,96
27.10.25	21,15	2.873	135,85	5:50	200,22	14,00	4:23	195,15	19,07
28.10.25	16,26	2.188	134,53	6:38	200,23	13,99	1:10	195,35	18,87
29.10.25	14,94	2.002	133,98	8:37	200,50	13,72	23:51	195,40	18,83
30.10.25	14,95	1.975	132,09	4:42	200,09	14,13	23:16	195,29	18,93
31.10.25	14,96	1.984	132,64	2:59	199,98	14,25	17:09	195,24	18,99
Σ	529,88	71.170							
Mittelwert	17,09	2.296	134,31		200,36	13,86		195,19	19,03
Minimum	7,68	1.076	131,75		199,85	12,96		194,56	17,98
Maximum	24,00	3.242	140,08		201,27	14,37		196,24	19,67

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom Oktober 2025
gedruckt am: 16.11.2025, 10:00 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.10.25	13,10	1.198	91,44	8:58	200,53	19,59	22:22	197,61	22,51
02.10.25	15,53	1.417	91,22	8:52	200,23	19,89	23:24	197,47	22,65
03.10.25	10,66	982	92,11	23:58	200,48	19,64	5:03	197,69	22,43
04.10.25	8,25	771	93,44	10:41	201,00	19,12	17:26	198,34	21,78
05.10.25	7,41	692	93,42	9:41	201,23	18,89	0:41	198,58	21,54
06.10.25	14,38	1.322	91,95	3:52	201,12	19,01	23:53	197,81	22,31
07.10.25	10,20	947	92,83	19:36	200,70	19,43	11:51	197,72	22,40
08.10.25	14,38	1.315	91,48	7:15	200,77	19,35	23:08	197,70	22,42
09.10.25	18,28	1.700	92,99	8:17	200,50	19,63	23:11	197,58	22,55
10.10.25	20,73	1.906	91,94	5:45	200,47	19,66	22:13	197,32	22,81
11.10.25	24,00	2.202	91,75	---	---	---	23:22	197,07	23,05
12.10.25	24,00	2.207	91,96	---	---	---	23:23	196,99	23,13
13.10.25	24,00	2.196	91,50	---	---	---	23:43	196,92	23,20
14.10.25	16,62	1.525	91,77	18:58	199,94	20,18	0:03	196,92	23,20
15.10.25	15,81	1.439	91,01	4:00	200,21	19,91	19:37	197,46	22,66
16.10.25	15,91	1.447	90,95	5:59	200,06	20,06	19:40	197,39	22,73
17.10.25	13,53	1.235	91,27	12:04	200,03	20,09	17:27	197,39	22,73
18.10.25	20,72	1.918	92,56	5:37	200,07	20,05	19:11	197,36	22,76
19.10.25	21,27	1.980	93,10	---	---	---	0:00	197,36	22,76
20.10.25	24,00	2.212	92,17	---	---	---	19:58	197,46	22,66
21.10.25	20,96	1.937	92,43	11:46	200,33	19,79	8:27	197,37	22,75
22.10.25	24,00	2.201	91,71	---	---	---	22:11	197,36	22,77
23.10.25	16,78	1.529	91,11	23:02	199,96	20,16	1:37	197,38	22,74
24.10.25	13,07	1.188	90,86	5:25	200,08	20,04	22:47	197,45	22,67
25.10.25	9,61	876	91,15	14:26	200,50	19,63	1:55	197,51	22,61
26.10.25	18,33	1.704	92,96	6:05	200,55	19,57	22:42	197,56	22,56
27.10.25	21,01	1.940	92,35	5:51	200,22	19,90	22:28	197,51	22,61
28.10.25	6,39	576	90,15	6:38	200,31	19,81	1:09	197,61	22,51
29.10.25	8,74	795	90,97	8:47	200,61	19,51	23:45	197,68	22,45
30.10.25	14,46	1.312	90,74	4:43	200,18	19,95	23:14	197,57	22,55
31.10.25	14,56	1.328	91,23	2:59	200,07	20,05	17:02	197,52	22,61
Σ	500,68	45.997							
Mittelwert	16,15	1.484	91,87		200,40	19,72		197,50	22,62
Minimum	6,39	576	90,15		199,94	18,89		196,92	21,54
Maximum	24,00	2.212	93,44		201,23	20,18		198,58	23,20

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom Oktober 2025
gedruckt am: 16.11.2025, 10:00 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.10.25	24,00	2.402	100,08	---	---	---	22:42	197,31	24,08
02.10.25	24,00	2.344	97,67	---	---	---	23:45	197,04	24,34
03.10.25	24,00	2.427	101,13	---	---	---	0:00	197,07	24,31
04.10.25	24,00	2.544	106,00	---	---	---	0:00	197,84	23,54
05.10.25	24,00	2.577	107,38	---	---	---	1:04	198,37	23,01
06.10.25	24,00	2.434	101,42	---	---	---	23:59	197,57	23,81
07.10.25	21,88	2.250	102,83	12:44	202,65	18,73	0:10	197,50	23,89
08.10.25	23,62	2.351	99,52	---	---	---	23:27	197,38	24,00
09.10.25	17,28	1.737	100,52	18:06	202,35	19,03	0:00	197,44	23,94
10.10.25	12,46	1.197	96,03	5:48	203,09	18,30	20:48	198,28	23,10
11.10.25	11,45	1.102	96,27	10:10	202,10	19,28	20:07	198,13	23,25
12.10.25	7,19	693	96,45	12:09	202,12	19,27	0:40	198,16	23,22
13.10.25	12,05	1.157	96,05	10:19	202,13	19,25	22:48	198,05	23,33
14.10.25	18,05	1.815	100,55	10:57	202,71	18,67	6:20	197,57	23,81
15.10.25	24,00	2.367	98,63	---	---	---	19:55	197,37	24,02
16.10.25	24,00	2.323	96,79	---	---	---	23:42	197,12	24,27
17.10.25	24,00	2.353	98,04	---	---	---	17:45	197,07	24,31
18.10.25	13,96	1.372	98,30	22:16	202,48	18,90	0:59	197,21	24,17
19.10.25	6,70	672	100,32	9:59	203,01	18,37	21:40	199,00	22,38
20.10.25	17,62	1.751	99,38	3:56	202,73	18,65	15:15	198,73	22,66
21.10.25	14,14	1.408	99,60	11:44	203,09	18,29	8:26	198,31	23,07
22.10.25	19,08	1.860	97,47	8:20	202,53	18,85	21:56	198,30	23,08
23.10.25	20,60	2.004	97,26	4:59	202,55	18,84	22:27	197,41	23,97
24.10.25	23,08	2.245	97,28	---	---	---	23:08	197,21	24,17
25.10.25	23,34	2.353	100,83	---	---	---	2:10	197,21	24,17
26.10.25	13,95	1.419	101,76	23:29	202,61	18,78	0:22	197,48	23,90
27.10.25	11,82	1.178	99,68	7:29	203,13	18,26	23:13	198,37	23,01
28.10.25	20,86	2.079	99,67	11:50	202,64	18,75	23:41	197,56	23,82
29.10.25	24,00	2.385	99,38	---	---	---	23:58	197,44	23,94
30.10.25	24,00	2.338	97,42	---	---	---	23:27	197,24	24,14
31.10.25	24,00	2.345	97,71	---	---	---	17:23	197,17	24,21
Σ	597,11	59.482							
Mittelwert	19,26	1.919	99,62		202,62	18,76		197,67	23,71
Minimum	6,70	672	96,03		202,10	18,26		197,04	22,38
Maximum	24,00	2.577	107,38		203,13	19,28		199,00	24,34

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom Oktober 2025
gedruckt am: 16.11.2025, 10:00 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.10.25	14,88	1.398	93,95	8:35	204,25	21,59	16:33	199,05	26,80
02.10.25	16,05	1.497	93,28	8:47	203,07	22,77	3:40	199,04	26,80
03.10.25	11,32	1.068	94,31	23:56	204,02	21,83	16:43	199,04	26,80
04.10.25	8,77	846	96,42	23:25	204,73	21,11	17:28	200,08	25,77
05.10.25	7,88	760	96,40	9:31	205,05	20,79	0:44	200,34	25,50
06.10.25	14,80	1.395	94,24	3:50	204,93	20,92	22:14	199,04	26,80
07.10.25	8,79	829	94,29	12:48	204,52	21,32	2:21	199,05	26,80
08.10.25	14,81	1.385	93,55	7:17	203,83	22,01	21:02	199,04	26,80
09.10.25	18,58	1.781	95,88	6:11	203,38	22,46	1:29	199,05	26,80
10.10.25	20,97	1.989	94,85	5:41	204,85	20,99	19:01	199,04	26,80
11.10.25	24,00	2.274	94,75	---	---	---	14:35	199,04	26,80
12.10.25	24,00	2.285	95,21	---	---	---	0:00	199,05	26,80
13.10.25	24,00	2.272	94,67	---	---	---	0:00	199,05	26,80
14.10.25	16,81	1.599	95,11	10:58	204,42	21,43	0:00	199,05	26,80
15.10.25	16,41	1.534	93,51	3:55	204,25	21,59	13:12	199,05	26,80
16.10.25	16,39	1.526	93,09	5:58	203,03	22,81	7:30	199,04	26,80
17.10.25	14,22	1.329	93,48	9:41	202,91	22,93	6:45	199,04	26,80
18.10.25	20,88	2.000	95,78	5:31	202,94	22,90	0:39	199,05	26,80
19.10.25	21,59	2.098	97,18	---	---	---	0:01	199,73	26,11
20.10.25	24,00	2.298	95,75	---	---	---	23:59	199,64	26,20
21.10.25	20,60	1.978	96,03	11:42	204,90	20,94	1:34	199,52	26,32
22.10.25	24,00	2.277	94,88	---	---	---	22:16	199,33	26,51
23.10.25	19,91	1.870	93,91	8:57	203,46	22,38	12:39	199,05	26,80
24.10.25	16,18	1.507	93,11	16:34	202,93	22,92	14:49	199,04	26,80
25.10.25	10,01	934	93,31	10:39	203,51	22,34	0:54	199,05	26,80
26.10.25	18,57	1.790	96,39	6:15	203,64	22,20	0:00	199,05	26,80
27.10.25	21,25	2.042	96,11	5:50	204,77	21,07	22:37	199,52	26,32
28.10.25	16,09	1.510	93,85	10:26	204,06	21,79	20:12	199,04	26,80
29.10.25	15,07	1.410	93,55	8:46	203,49	22,35	15:45	199,04	26,80
30.10.25	15,22	1.412	92,78	4:39	203,02	22,82	16:03	199,04	26,80
31.10.25	15,24	1.422	93,29	2:55	202,93	22,92	10:58	199,04	26,80
Σ	531,30	50.315							
Mittelwert	17,14	1.623	94,70		203,87	21,97		199,20	26,64
Minimum	7,88	760	92,78		202,91	20,79		199,04	25,50
Maximum	24,00	2.298	97,18		205,05	22,93		200,34	26,80

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom Oktober 2025
gedruckt am: 16.11.2025, 10:00 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.10.25	15,53	1.612	103,77	8:25	204,82	26,59	22:39	194,05	37,37
02.10.25	24,00	2.484	103,50	---	---	---	23:42	193,80	37,61
03.10.25	16,03	1.677	104,63	23:52	204,58	26,84	0:00	193,83	37,58
04.10.25	0,00	0	---	23:39	205,31	26,10	---	---	---
05.10.25	0,00	0	---	9:36	205,59	25,83	---	---	---
06.10.25	18,16	1.895	104,34	3:56	205,45	25,97	23:59	194,19	37,23
07.10.25	19,79	2.089	105,55	12:30	204,95	26,47	0:13	194,09	37,32
08.10.25	24,00	2.495	103,96	---	---	---	23:22	193,94	37,47
09.10.25	8,94	938	104,90	20:53	204,49	26,93	0:00	194,00	37,41
10.10.25	16,91	1.724	101,94	5:50	205,22	26,20	21:27	194,26	37,15
11.10.25	24,00	2.470	102,92	---	---	---	21:13	194,09	37,32
12.10.25	24,00	2.481	103,38	---	---	---	1:21	194,09	37,32
13.10.25	24,00	2.467	102,79	---	---	---	23:27	194,03	37,38
14.10.25	7,25	739	101,88	10:59	204,88	26,53	0:39	193,67	37,75
15.10.25	18,73	1.932	103,15	4:01	204,87	26,55	19:52	194,00	37,41
16.10.25	24,00	2.476	103,17	---	---	---	23:42	193,74	37,67
17.10.25	24,00	2.494	103,92	---	---	---	17:45	193,74	37,67
18.10.25	7,57	786	103,77	22:43	204,53	26,88	0:58	193,91	37,50
19.10.25	0,84	81	96,24	10:08	205,17	26,24	---	---	---
20.10.25	1,52	146	96,30	4:11	204,76	26,65	---	---	---
21.10.25	1,21	119	98,03	11:43	205,46	25,95	---	---	---
22.10.25	4,21	404	96,04	0:03	204,76	26,65	20:08	196,03	35,38
23.10.25	18,81	1.940	103,16	5:08	204,50	26,91	22:30	194,00	37,41
24.10.25	23,12	2.386	103,22	---	---	---	4:15	193,91	37,50
25.10.25	24,00	2.526	105,25	---	---	---	2:10	193,99	37,43
26.10.25	7,37	787	106,74	23:54	204,70	26,71	0:26	194,20	37,21
27.10.25	4,40	454	103,16	7:42	205,28	26,13	23:12	194,89	36,53
28.10.25	20,89	2.169	103,82	11:58	204,55	26,87	23:39	194,08	37,34
29.10.25	24,00	2.504	104,33	---	---	---	23:59	194,02	37,40
30.10.25	24,00	2.480	103,33	---	---	---	23:24	193,91	37,50
31.10.25	24,00	2.487	103,63	---	---	---	17:24	193,83	37,58
Σ	475,29	49.242							
Mittelwert	15,33	1.588	103,60		204,94	26,47		194,09	37,32
Minimum	0,00	0	96,04		204,49	25,83		193,67	35,38
Maximum	24,00	2.526	106,74		205,59	26,93		196,03	37,75

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom Oktober 2025
gedruckt am: 16.11.2025, 10:00 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.10.25	9,08	831	91,53	20:40	212,13	19,92	3:52	203,26	28,79
02.10.25	0,03	3	86,40	14:02	212,30	19,75	---	---	---
03.10.25	8,02	748	93,30	15:15	212,41	19,65	23:46	203,68	28,38
04.10.25	24,00	2.212	92,17	---	---	---	13:11	203,52	28,53
05.10.25	24,00	2.209	92,04	---	---	---	19:23	203,55	28,50
06.10.25	5,83	536	91,98	20:18	212,35	19,71	3:12	203,52	28,53
07.10.25	1,56	139	88,90	16:12	212,75	19,31	---	---	---
08.10.25	1,07	95	88,56	8:38	212,61	19,45	---	---	---
09.10.25	15,70	1.439	91,68	8:16	212,45	19,60	23:26	203,45	28,61
10.10.25	9,87	898	91,00	23:41	212,12	19,94	4:21	203,21	28,84
11.10.25	0,00	0	---	14:29	212,32	19,74	---	---	---
12.10.25	0,00	0	---	16:29	212,39	19,66	---	---	---
13.10.25	0,00	0	---	9:22	212,39	19,66	---	---	---
14.10.25	15,17	1.397	92,09	2:10	212,35	19,71	23:11	203,45	28,61
15.10.25	6,71	615	91,61	17:32	212,22	19,83	3:32	203,34	28,72
16.10.25	0,95	84	87,96	15:28	212,30	19,75	---	---	---
17.10.25	0,00	0	---	14:13	212,33	19,72	---	---	---
18.10.25	16,47	1.513	91,87	3:31	212,35	19,71	21:53	203,43	28,62
19.10.25	24,00	2.197	91,54	---	---	---	3:59	203,29	28,76
20.10.25	24,00	2.170	90,42	---	---	---	19:59	203,42	28,64
21.10.25	20,42	1.846	90,38	11:42	211,61	20,44	2:00	203,45	28,61
22.10.25	24,00	2.154	89,75	---	---	---	22:38	203,17	28,89
23.10.25	6,72	607	90,39	15:53	212,12	19,94	1:49	203,23	28,82
24.10.25	1,31	113	86,42	21:55	212,22	19,83	---	---	---
25.10.25	0,00	0	---	14:00	212,48	19,57	---	---	---
26.10.25	17,67	1.611	91,16	5:51	212,50	19,56	23:23	203,61	28,44
27.10.25	20,50	1.860	90,72	23:57	211,25	20,81	4:53	203,43	28,62
28.10.25	4,22	381	90,33	23:58	212,24	19,82	12:00	204,58	27,48
29.10.25	0,00	0	---	10:09	212,42	19,63	---	---	---
30.10.25	1,48	129	87,13	1:12	212,41	19,65	---	---	---
31.10.25	0,27	26	95,41	23:02	212,32	19,74	---	---	---
Σ	283,06	25.813							
Mittelwert	9,13	833	91,19		212,28	19,77		203,48	28,58
Minimum	0,00	0	86,40		211,25	19,31		203,17	27,48
Maximum	24,00	2.212	95,41		212,75	20,81		204,58	28,89

Meßpunkthöhe (MP): 232,05 m üNN