

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom November 2025
gedruckt am: 03.12.2025, 06:46 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.11.25	0,40	34	83,95	23:30	212,41	19,65	---	---	---
02.11.25	0,00	0	---	13:37	212,56	19,49	---	---	---
03.11.25	0,98	87	88,73	5:35	212,53	19,52	---	---	---
04.11.25	4,16	364	87,42	19:02	212,29	19,77	8:59	204,87	27,19
05.11.25	1,83	160	87,51	9:07	212,36	19,69	---	---	---
06.11.25	0,00	0	---	8:47	212,32	19,74	---	---	---
07.11.25	1,57	138	87,62	7:52	212,35	19,71	16:24	205,79	26,27
08.11.25	0,00	0	---	8:36	212,30	19,75	---	---	---
09.11.25	0,00	0	---	12:42	212,53	19,52	---	---	---
10.11.25	0,00	0	---	7:21	212,56	19,49	---	---	---
11.11.25	2,91	255	87,77	6:30	212,45	19,60	9:44	205,42	26,64
12.11.25	1,07	95	88,88	12:44	212,50	19,56	14:30	206,32	25,74
13.11.25	0,00	0	---	8:33	212,45	19,60	---	---	---
14.11.25	0,59	51	87,01	8:32	212,41	19,65	---	---	---
15.11.25	0,00	0	---	22:49	212,38	19,68	---	---	---
16.11.25	10,22	945	92,44	5:58	212,45	19,60	22:16	203,57	28,49
17.11.25	24,00	2.203	91,79	---	---	---	8:58	203,34	28,72
18.11.25	22,55	2.057	91,20	11:09	210,42	21,64	9:37	203,29	28,76
19.11.25	24,00	2.195	91,46	---	---	---	6:34	203,35	28,70
20.11.25	24,00	2.184	91,00	---	---	---	21:43	203,42	28,64
21.11.25	16,08	1.437	89,35	9:03	211,80	20,26	21:33	203,17	28,89
22.11.25	0,00	0	---	23:47	212,39	19,66	---	---	---
23.11.25	0,00	0	---	15:14	212,62	19,43	---	---	---
24.11.25	1,43	125	87,67	7:39	212,67	19,39	---	---	---
25.11.25	2,28	204	89,63	6:17	212,53	19,52	9:40	205,22	26,84
26.11.25	0,61	54	88,52	5:18	212,39	19,66	---	---	---
27.11.25	0,00	0	---	10:40	212,35	19,71	---	---	---
28.11.25	0,00	0	---	18:17	212,35	19,71	---	---	---
29.11.25	20,94	1.917	91,54	0:00	212,35	19,71	17:40	203,43	28,62
30.11.25	24,00	2.200	91,67	---	---	---	3:20	203,34	28,72
Σ	183,63	16.705							
Mittelwert	6,12	557	90,97		212,33	19,72		204,19	27,86
Minimum	0,00	0	83,95		210,42	19,39		203,17	25,74
Maximum	24,00	2.203	92,44		212,67	21,64		206,32	28,89

Meßpunkthöhe (MP): 232,05 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom November 2025
gedruckt am: 03.12.2025, 06:46 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.11.25	24,00	2.464	102,67	---	---	---	0:47	193,71	20,56
02.11.25	24,00	2.475	103,13	---	---	---	22:07	193,85	20,43
03.11.25	24,00	2.459	102,46	---	---	---	20:00	193,71	20,56
04.11.25	23,74	2.417	101,79	---	---	---	22:15	193,67	20,60
05.11.25	24,00	2.445	101,88	---	---	---	22:37	193,64	20,63
06.11.25	24,00	2.446	101,92	---	---	---	22:27	193,56	20,71
07.11.25	24,00	2.448	102,00	---	---	---	2:44	193,58	20,69
08.11.25	24,00	2.460	102,50	---	---	---	2:11	193,59	20,68
09.11.25	24,00	2.475	103,13	---	---	---	1:28	193,72	20,55
10.11.25	24,00	2.459	102,46	---	---	---	19:45	193,74	20,53
11.11.25	23,66	2.412	101,96	---	---	---	23:24	193,68	20,59
12.11.25	24,00	2.453	102,21	---	---	---	23:43	193,72	20,56
13.11.25	24,00	2.461	102,54	---	---	---	22:57	193,66	20,62
14.11.25	24,00	2.452	102,17	---	---	---	23:56	193,59	20,68
15.11.25	24,00	2.459	102,46	---	---	---	0:00	193,61	20,66
16.11.25	13,80	1.416	102,62	22:43	198,82	15,45	1:05	193,72	20,55
17.11.25	0,00	0	---	10:39	199,08	15,19	---	---	---
18.11.25	3,16	327	103,39	0:10	198,76	15,51	11:05	194,09	20,18
19.11.25	0,00	0	---	7:09	198,98	15,29	---	---	---
20.11.25	0,00	0	---	0:15	198,85	15,42	---	---	---
21.11.25	21,13	2.173	102,84	0:00	198,73	15,54	19:34	193,77	20,50
22.11.25	24,00	2.466	102,75	---	---	---	5:21	193,79	20,49
23.11.25	24,00	2.472	103,00	---	---	---	0:00	193,95	20,33
24.11.25	24,00	2.464	102,67	---	---	---	20:39	193,86	20,41
25.11.25	24,00	2.460	102,50	---	---	---	21:44	193,71	20,56
26.11.25	24,00	2.454	102,25	---	---	---	18:59	193,56	20,71
27.11.25	24,00	2.453	102,21	---	---	---	19:43	193,55	20,72
28.11.25	24,00	2.456	102,33	---	---	---	2:05	193,56	20,71
29.11.25	3,08	314	102,01	21:24	198,70	15,57	1:51	193,61	20,66
30.11.25	0,00	0	---	5:35	199,13	15,14	---	---	---
Σ	568,57	58.240							
Mittelwert	18,95	1.941	102,43		198,88	15,39		193,70	20,57
Minimum	0,00	0	101,79		198,70	15,14		193,55	20,18
Maximum	24,00	2.475	103,39		199,13	15,57		194,09	20,72

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom November 2025
gedruckt am: 03.12.2025, 06:46 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.11.25	11,09	1.482	133,58	23:18	200,27	13,96	0:41	195,37	18,86
02.11.25	8,35	1.127	134,97	11:04	200,51	13,71	21:57	195,62	18,61
03.11.25	14,04	1.873	133,39	5:21	200,50	13,73	19:55	195,37	18,85
04.11.25	14,82	1.943	131,08	5:13	200,13	14,09	22:10	195,24	18,99
05.11.25	15,53	2.047	131,84	9:06	200,19	14,03	22:33	195,21	19,01
06.11.25	17,41	2.296	131,85	4:03	200,03	14,19	22:23	195,09	19,13
07.11.25	15,55	2.047	131,62	7:58	200,08	14,14	2:41	195,11	19,11
08.11.25	13,37	1.772	132,52	23:58	200,05	14,18	2:06	195,17	19,05
09.11.25	6,31	849	134,61	10:39	200,49	13,73	1:15	195,56	18,67
10.11.25	13,37	1.788	133,72	5:10	200,53	13,69	19:38	195,38	18,84
11.11.25	15,55	2.065	132,82	6:29	200,29	13,93	12:30	195,17	19,05
12.11.25	12,65	1.693	133,85	12:41	200,43	13,80	23:39	195,35	18,87
13.11.25	13,31	1.778	133,55	8:30	200,37	13,85	22:54	195,25	18,97
14.11.25	16,88	2.233	132,30	6:40	199,98	14,25	23:50	195,20	19,03
15.11.25	13,07	1.739	133,08	23:16	200,10	14,12	14:19	195,24	18,98
16.11.25	15,55	2.119	136,25	4:48	200,30	13,93	21:57	195,17	19,05
17.11.25	21,10	2.901	137,50	---	---	---	2:48	195,16	19,06
18.11.25	24,00	3.272	136,33	---	---	---	9:44	194,98	19,25
19.11.25	23,24	3.186	137,09	---	---	---	6:21	195,05	19,17
20.11.25	24,00	3.267	136,13	---	---	---	21:55	195,08	19,14
21.11.25	12,68	1.701	134,17	23:48	200,09	14,13	2:47	194,97	19,25
22.11.25	10,20	1.362	133,58	10:05	200,34	13,88	5:15	195,53	18,69
23.11.25	7,54	1.013	134,36	10:13	200,66	13,57	20:52	195,81	18,41
24.11.25	12,73	1.702	133,72	3:55	200,58	13,64	20:36	195,53	18,69
25.11.25	14,41	1.920	133,20	13:00	200,37	13,85	21:37	195,37	18,85
26.11.25	16,01	2.115	132,09	6:21	200,11	14,11	18:54	195,13	19,09
27.11.25	15,70	2.070	131,81	10:46	200,09	14,13	19:38	195,12	19,10
28.11.25	14,76	1.956	132,55	20:30	199,90	14,32	1:58	195,18	19,04
29.11.25	22,77	3.090	135,73	2:57	199,81	14,41	20:53	195,11	19,11
30.11.25	19,96	2.750	137,81	5:30	200,27	13,96	0:38	195,11	19,12
Σ	455,95	61.156							
Mittelwert	15,20	2.039	134,13		200,25	13,97		195,25	18,97
Minimum	6,31	849	131,08		199,81	13,57		194,97	18,41
Maximum	24,00	3.272	137,81		200,66	14,41		195,81	19,25

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom November 2025
gedruckt am: 03.12.2025, 06:46 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.11.25	10,73	982	91,55	23:19	200,35	19,77	0:38	197,67	22,45
02.11.25	8,02	736	91,75	10:54	200,61	19,51	21:56	197,95	22,17
03.11.25	13,69	1.254	91,58	5:25	200,60	19,53	14:20	197,68	22,45
04.11.25	17,42	1.588	91,15	5:15	200,22	19,90	22:01	197,50	22,62
05.11.25	14,52	1.319	90,83	9:04	200,28	19,85	22:28	197,48	22,64
06.11.25	17,18	1.563	90,97	4:05	200,11	20,01	22:10	197,35	22,77
07.11.25	15,27	1.389	90,96	8:01	200,15	19,97	2:35	197,38	22,74
08.11.25	13,07	1.193	91,25	23:57	200,12	20,01	2:04	197,44	22,68
09.11.25	6,08	558	91,83	10:34	200,57	19,55	1:14	197,83	22,29
10.11.25	13,06	1.197	91,65	5:08	200,63	19,50	19:37	197,68	22,45
11.11.25	12,45	1.128	90,60	6:28	200,38	19,75	23:19	197,57	22,55
12.11.25	8,43	771	91,43	12:41	200,53	19,59	23:35	197,65	22,47
13.11.25	13,00	1.192	91,71	8:32	200,47	19,66	22:49	197,54	22,58
14.11.25	16,53	1.507	91,15	8:41	200,08	20,04	23:41	197,46	22,66
15.11.25	12,70	1.162	91,46	23:14	200,17	19,95	14:15	197,52	22,61
16.11.25	15,21	1.410	92,69	4:45	200,38	19,75	21:53	197,57	22,55
17.11.25	20,86	1.945	93,25	---	---	---	23:21	197,48	22,65
18.11.25	21,79	2.022	92,79	11:08	199,76	20,37	8:54	197,41	22,71
19.11.25	23,19	2.165	93,34	---	---	---	0:22	197,42	22,70
20.11.25	24,00	2.229	92,88	---	---	---	23:41	197,34	22,78
21.11.25	12,30	1.132	92,05	23:46	200,21	19,92	0:25	197,34	22,78
22.11.25	9,84	901	91,54	10:10	200,45	19,67	5:13	197,84	22,29
23.11.25	7,29	670	91,92	10:11	200,76	19,36	16:56	198,14	21,98
24.11.25	12,41	1.139	91,76	3:56	200,68	19,44	20:32	197,84	22,28
25.11.25	14,03	1.284	91,49	13:02	200,47	19,65	21:36	197,67	22,45
26.11.25	15,70	1.434	91,33	6:23	200,21	19,91	18:44	197,39	22,74
27.11.25	15,37	1.402	91,23	10:47	200,18	19,95	19:25	197,38	22,74
28.11.25	14,33	1.310	91,41	20:30	199,99	20,13	1:57	197,44	22,68
29.11.25	22,72	2.107	92,75	2:58	199,90	20,22	21:59	197,37	22,75
30.11.25	19,78	1.850	93,51	5:32	200,22	19,90	0:21	197,37	22,75
Σ	441,00	40.539							
Mittelwert	14,70	1.351	91,93		200,31	19,81		197,55	22,57
Minimum	6,08	558	90,60		199,76	19,36		197,34	21,98
Maximum	24,00	2.229	93,51		200,76	20,37		198,14	22,78

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom November 2025
gedruckt am: 03.12.2025, 06:46 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt			Zeitpunkt		
				Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
	h	m³	m³/h						
01.11.25	24,00	2.405	100,21	---	---	---	0:58	197,23	24,15
02.11.25	22,57	2.313	102,49	10:10	202,32	19,06	0:47	197,44	23,94
03.11.25	24,00	2.375	98,96	---	---	---	20:07	197,31	24,08
04.11.25	21,16	2.035	96,16	11:58	202,12	19,27	1:23	197,28	24,11
05.11.25	22,60	2.188	96,80	8:06	202,06	19,33	22:45	197,15	24,23
06.11.25	24,00	2.311	96,29	---	---	---	22:38	196,96	24,42
07.11.25	24,00	2.320	96,67	---	---	---	22:52	196,95	24,44
08.11.25	24,00	2.364	98,50	---	---	---	2:23	196,95	24,44
09.11.25	22,61	2.331	103,10	8:54	202,26	19,12	1:28	197,20	24,18
10.11.25	24,00	2.387	99,46	---	---	---	21:52	197,25	24,13
11.11.25	22,57	2.210	97,93	12:53	202,19	19,20	1:17	197,23	24,15
12.11.25	23,58	2.347	99,55	---	---	---	23:52	197,20	24,18
13.11.25	24,00	2.382	99,25	---	---	---	23:11	197,12	24,26
14.11.25	24,00	2.323	96,79	---	---	---	23:57	197,04	24,34
15.11.25	24,00	2.370	98,75	---	---	---	0:02	197,02	24,36
16.11.25	17,64	1.762	99,88	23:47	202,48	18,91	1:25	197,20	24,18
17.11.25	7,85	796	101,36	12:35	203,04	18,34	22:35	199,03	22,35
18.11.25	10,26	1.027	100,14	11:10	203,01	18,37	8:36	199,04	22,34
19.11.25	7,13	725	101,68	7:07	203,09	18,29	22:27	199,25	22,13
20.11.25	10,89	1.104	101,35	5:45	202,95	18,43	19:51	199,16	22,22
21.11.25	8,00	837	104,61	21:31	202,86	18,52	7:37	198,50	22,88
22.11.25	23,60	2.432	103,03	---	---	---	23:46	197,92	23,46
23.11.25	23,71	2.460	103,76	---	---	---	0:00	197,93	23,45
24.11.25	24,00	2.411	100,46	---	---	---	20:50	197,60	23,78
25.11.25	20,48	2.024	98,84	11:42	202,19	19,19	21:50	197,48	23,90
26.11.25	24,00	2.343	97,63	---	---	---	19:09	197,14	24,24
27.11.25	24,00	2.342	97,58	---	---	---	22:45	197,07	24,31
28.11.25	24,00	2.352	98,00	---	---	---	2:19	197,08	24,31
29.11.25	14,43	1.417	98,19	22:25	202,45	18,94	1:56	197,11	24,28
30.11.25	7,75	809	104,33	10:35	202,92	18,46	4:41	198,60	22,79
Σ	598,84	59.502							
Mittelwert	19,96	1.983	99,36		202,57	18,81		197,58	23,80
Minimum	7,13	725	96,16		202,06	18,29		196,95	22,13
Maximum	24,00	2.460	104,61		203,09	19,33		199,25	24,44

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom November 2025
gedruckt am: 03.12.2025, 06:46 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.11.25	11,36	1.064	93,65	23:19	203,20	22,64	8:37	199,04	26,80
02.11.25	8,61	810	94,09	10:18	203,73	22,12	0:26	199,05	26,80
03.11.25	14,29	1.337	93,55	5:12	203,49	22,35	9:43	199,04	26,80
04.11.25	17,79	1.660	93,33	5:10	203,05	22,79	7:24	199,04	26,80
05.11.25	15,76	1.464	92,87	8:51	203,35	22,49	3:12	199,04	26,80
06.11.25	17,58	1.638	93,15	4:02	202,94	22,90	8:22	199,04	26,80
07.11.25	15,76	1.462	92,79	7:55	202,98	22,86	5:05	199,04	26,80
08.11.25	13,59	1.269	93,41	23:55	202,93	22,91	0:50	199,04	26,80
09.11.25	6,48	609	94,03	8:58	203,68	22,16	1:11	199,05	26,80
10.11.25	13,59	1.273	93,69	5:02	203,51	22,34	11:45	199,04	26,80
11.11.25	12,87	1.190	92,45	13:17	203,64	22,20	0:43	199,04	26,80
12.11.25	12,85	1.200	93,40	8:26	203,40	22,44	14:56	199,04	26,80
13.11.25	13,54	1.269	93,76	8:29	203,28	22,56	9:57	199,04	26,80
14.11.25	17,13	1.597	93,23	6:39	202,87	22,97	0:52	199,04	26,80
15.11.25	13,32	1.247	93,59	23:15	203,00	22,84	8:57	199,04	26,80
16.11.25	15,79	1.506	95,39	4:47	203,22	22,62	14:52	199,04	26,80
17.11.25	21,26	2.070	97,37	---	---	---	2:49	199,86	25,98
18.11.25	21,74	2.106	96,87	11:08	204,73	21,11	8:39	199,89	25,95
19.11.25	23,27	2.272	97,62	---	---	---	22:35	200,03	25,81
20.11.25	24,00	2.330	97,08	---	---	---	20:10	199,94	25,90
21.11.25	12,95	1.227	94,72	21:28	203,99	21,85	9:40	199,43	26,41
22.11.25	10,44	982	94,02	9:33	203,73	22,12	16:33	199,16	26,68
23.11.25	7,71	725	94,06	10:04	203,87	21,97	20:53	199,25	26,59
24.11.25	12,95	1.213	93,69	3:55	203,64	22,21	19:33	199,04	26,80
25.11.25	16,20	1.524	94,06	13:02	203,35	22,49	0:00	199,04	26,80
26.11.25	16,23	1.516	93,41	6:20	203,13	22,71	2:25	199,04	26,80
27.11.25	15,94	1.489	93,44	10:44	203,09	22,76	0:00	199,04	26,80
28.11.25	15,06	1.408	93,48	20:28	202,86	22,99	0:37	199,04	26,80
29.11.25	22,80	2.190	96,06	2:57	202,76	23,08	0:09	199,04	26,80
30.11.25	20,15	1.968	97,68	5:31	204,42	21,43	0:01	199,72	26,12
Σ	461,00	43.615							
Mittelwert	15,37	1.454	94,61		203,40	22,44		199,20	26,64
Minimum	6,48	609	92,45		202,76	21,11		199,04	25,81
Maximum	24,00	2.330	97,68		204,73	23,08		200,03	26,80

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom November 2025
gedruckt am: 03.12.2025, 06:46 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.11.25	24,00	2.512	104,67	---	---	---	0:55	193,93	37,49
02.11.25	24,00	2.541	105,88	---	---	---	0:46	194,16	37,26
03.11.25	24,00	2.491	103,79	---	---	---	20:13	193,91	37,50
04.11.25	20,80	2.122	102,03	12:20	204,06	27,35	1:28	193,88	37,53
05.11.25	24,00	2.478	103,25	---	---	---	22:43	193,82	37,60
06.11.25	24,00	2.472	103,00	---	---	---	22:37	193,68	37,73
07.11.25	24,00	2.473	103,04	---	---	---	22:45	193,62	37,79
08.11.25	24,00	2.498	104,08	---	---	---	2:16	193,68	37,73
09.11.25	24,00	2.551	106,29	---	---	---	1:27	193,96	37,46
10.11.25	24,00	2.506	104,42	---	---	---	19:50	193,90	37,52
11.11.25	23,70	2.453	103,49	---	---	---	1:20	193,88	37,53
12.11.25	24,00	2.505	104,38	---	---	---	23:51	193,88	37,53
13.11.25	24,00	2.499	104,13	---	---	---	23:08	193,82	37,60
14.11.25	24,00	2.469	102,88	---	---	---	23:59	193,73	37,69
15.11.25	24,00	2.498	104,08	---	---	---	0:05	193,71	37,70
16.11.25	13,82	1.446	104,63	23:58	204,53	26,88	1:17	193,94	37,47
17.11.25	0,00	0	---	12:35	205,20	26,21	---	---	---
18.11.25	1,42	138	97,41	11:27	205,23	26,18	---	---	---
19.11.25	0,00	0	---	7:15	205,14	26,27	---	---	---
20.11.25	0,00	0	---	5:51	204,96	26,45	---	---	---
21.11.25	21,15	2.170	102,58	2:28	204,76	26,65	22:41	194,52	36,89
22.11.25	24,00	2.527	105,29	---	---	---	5:30	194,31	37,11
23.11.25	24,00	2.545	106,04	---	---	---	0:00	194,38	37,03
24.11.25	24,00	2.502	104,25	---	---	---	20:50	194,11	37,31
25.11.25	24,00	2.482	103,42	---	---	---	21:55	193,93	37,49
26.11.25	24,00	2.477	103,21	---	---	---	19:07	193,70	37,72
27.11.25	24,00	2.480	103,33	---	---	---	19:57	193,68	37,73
28.11.25	24,00	2.486	103,58	---	---	---	2:08	193,71	37,70
29.11.25	3,10	320	103,14	22:50	204,50	26,91	1:54	193,76	37,66
30.11.25	0,00	0	---	8:16	205,10	26,32	---	---	---
Σ	564,00	58.641							
Mittelwert	18,80	1.955	103,97		204,83	26,58		193,90	37,51
Minimum	0,00	0	97,41		204,06	26,18		193,62	36,89
Maximum	24,00	2.551	106,29		205,23	27,35		194,52	37,79

Meßpunkthöhe (MP): 231,41 m üNN