

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:51 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.12.25	3,60	367	102,07	0:38	198,76	15,51	15:57	194,33	19,94
02.12.25	3,44	351	102,06	11:16	198,80	15,47	9:24	194,15	20,12
03.12.25	0,00	0	---	8:38	198,85	15,43	---	---	---
04.12.25	0,54	55	102,17	7:26	198,89	15,38	---	---	---
05.12.25	7,94	814	102,54	3:51	198,84	15,43	23:59	193,88	20,40
06.12.25	24,00	2.467	102,79	---	---	---	0:52	193,76	20,51
07.12.25	24,00	2.471	102,96	---	---	---	1:52	193,83	20,44
08.12.25	24,00	2.454	102,25	---	---	---	21:44	193,77	20,50
09.12.25	24,00	2.443	101,79	---	---	---	23:13	193,61	20,66
10.12.25	24,00	2.458	102,42	---	---	---	0:29	193,52	20,75
11.12.25	24,00	2.453	102,21	---	---	---	22:36	193,50	20,77
12.12.25	24,00	2.457	102,38	---	---	---	22:08	193,53	20,74
13.12.25	24,00	2.458	102,42	---	---	---	15:03	193,55	20,72
14.12.25	23,32	2.401	102,94	---	---	---	0:26	193,66	20,62
15.12.25	24,00	2.461	102,54	---	---	---	23:36	193,67	20,60
16.12.25	22,99	2.359	102,61	---	---	---	0:00	193,73	20,54
17.12.25	24,00	2.461	102,54	---	---	---	20:57	193,66	20,62
18.12.25	23,66	2.432	102,79	---	---	---	0:19	193,64	20,63
19.12.25	24,00	2.474	103,08	---	---	---	0:00	193,83	20,44
20.12.25	14,26	1.473	103,33	23:53	198,85	15,42	0:00	193,89	20,38
21.12.25	0,00	0	---	8:37	199,13	15,14	---	---	---
22.12.25	0,00	0	---	7:40	199,24	15,04	---	---	---
23.12.25	1,31	135	103,34	9:19	199,16	15,11	10:50	194,55	19,72
24.12.25	22,51	2.329	103,45	0:11	198,78	15,49	19:29	194,01	20,26
25.12.25	24,00	2.473	103,04	---	---	---	20:06	193,85	20,43
26.12.25	8,67	896	103,30	11:48	198,98	15,29	0:52	193,84	20,43
27.12.25	0,00	0	---	7:59	199,21	15,07	---	---	---
28.12.25	8,64	892	103,30	8:44	199,41	14,86	23:36	194,27	20,01
29.12.25	24,00	2.478	103,25	---	---	---	16:16	194,15	20,12
30.12.25	23,03	2.368	102,84	---	---	---	19:56	193,94	20,33
31.12.25	4,89	505	103,18	9:51	199,34	14,94	0:00	194,01	20,26
Σ	480,79	49.385							
Mittelwert	15,51	1.593	102,72		199,02	15,25		193,85	20,42
Minimum	0,00	0	101,79		198,76	14,86		193,50	19,72
Maximum	24,00	2.478	103,45		199,41	15,51		194,55	20,77

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:51 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.12.25	24,00	3.213	133,88	---	---	---	7:47	195,10	19,12
02.12.25	22,18	2.983	134,51	11:12	199,98	14,25	8:59	194,94	19,28
03.12.25	23,47	3.194	136,09	---	---	---	8:04	194,98	19,25
04.12.25	23,46	3.193	136,11	---	---	---	6:51	195,01	19,21
05.12.25	21,35	2.872	134,54	19:47	199,74	14,48	3:20	194,97	19,25
06.12.25	9,24	1.228	132,95	10:43	200,31	13,91	0:44	195,17	19,06
07.12.25	8,85	1.184	133,73	11:02	200,55	13,67	1:43	195,56	18,66
08.12.25	16,43	2.155	131,19	8:49	200,54	13,68	21:58	195,24	18,98
09.12.25	21,56	2.819	130,72	10:55	199,88	14,35	8:21	194,88	19,34
10.12.25	13,67	1.804	132,00	7:03	200,09	14,13	0:24	194,95	19,27
11.12.25	15,50	2.041	131,68	6:08	199,76	14,46	22:26	195,04	19,19
12.12.25	14,20	1.877	132,16	6:44	200,03	14,19	22:00	195,13	19,09
13.12.25	13,35	1.764	132,17	22:38	200,02	14,21	14:59	195,17	19,05
14.12.25	8,45	1.131	133,87	12:45	200,46	13,76	0:21	195,41	18,81
15.12.25	13,14	1.749	133,10	6:03	200,38	13,84	23:31	195,33	18,89
16.12.25	11,59	1.561	134,72	22:06	200,27	13,95	10:39	195,36	18,86
17.12.25	12,92	1.719	133,06	8:00	200,46	13,76	20:54	195,30	18,93
18.12.25	9,76	1.302	133,46	8:29	200,43	13,80	0:15	195,30	18,92
19.12.25	6,62	894	134,95	12:35	200,61	13,61	23:31	195,68	18,54
20.12.25	12,05	1.668	138,39	12:01	200,72	13,51	23:09	195,46	18,76
21.12.25	22,26	3.075	138,11	---	---	---	3:39	195,30	18,93
22.12.25	21,44	2.955	137,83	6:28	200,32	13,90	4:07	195,19	19,03
23.12.25	21,87	3.020	138,06	9:15	200,22	14,00	22:59	195,09	19,13
24.12.25	5,85	790	135,02	12:19	200,56	13,66	1:24	195,02	19,20
25.12.25	9,95	1.337	134,39	10:23	200,72	13,50	15:13	195,61	18,61
26.12.25	15,10	2.090	138,39	10:17	200,82	13,41	22:29	195,43	18,79
27.12.25	21,23	2.949	138,93	8:01	200,39	13,83	0:49	195,30	18,93
28.12.25	13,78	1.906	138,35	8:49	200,71	13,51	4:18	195,20	19,03
29.12.25	5,99	812	135,45	8:55	200,81	13,41	16:09	196,05	18,18
30.12.25	10,59	1.430	135,00	7:25	200,86	13,36	19:45	195,67	18,55
31.12.25	16,39	2.282	139,24	6:00	200,82	13,40	23:51	195,54	18,68
Σ	466,24	62.997							
Mittelwert	15,04	2.032	135,12		200,39	13,83		195,27	18,95
Minimum	5,85	790	130,72		199,74	13,36		194,88	18,18
Maximum	24,00	3.213	139,24		200,86	14,48		196,05	19,34

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:51 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.12.25	24,00	2.208	92,00	---	---	---	22:09	197,33	22,79
02.12.25	22,14	2.042	92,24	11:13	199,95	20,17	9:11	197,29	22,84
03.12.25	23,42	2.175	92,86	---	---	---	0:00	197,32	22,80
04.12.25	23,41	2.175	92,90	---	---	---	1:06	197,34	22,78
05.12.25	21,21	1.959	92,38	19:48	199,82	20,30	18:06	197,33	22,79
06.12.25	8,98	819	91,21	10:51	200,40	19,72	0:37	197,43	22,69
07.12.25	8,64	793	91,83	11:11	200,65	19,47	1:42	197,86	22,26
08.12.25	16,33	1.485	90,91	8:54	200,64	19,48	22:23	197,39	22,73
09.12.25	20,10	1.821	90,58	10:54	199,97	20,15	23:58	197,20	22,92
10.12.25	13,37	1.220	91,22	7:01	200,15	19,97	0:22	197,19	22,94
11.12.25	15,12	1.378	91,12	7:42	199,92	20,20	22:22	197,28	22,84
12.12.25	13,87	1.267	91,33	6:49	200,11	20,01	21:55	197,36	22,76
13.12.25	13,02	1.187	91,20	22:40	200,09	20,03	14:58	197,43	22,69
14.12.25	8,09	742	91,72	12:45	200,56	19,56	0:18	197,68	22,45
15.12.25	12,82	1.173	91,48	6:02	200,47	19,65	23:29	197,61	22,52
16.12.25	10,45	960	91,83	22:10	200,38	19,75	12:40	197,77	22,35
17.12.25	12,63	1.156	91,53	8:08	200,56	19,56	20:49	197,59	22,53
18.12.25	9,45	865	91,53	8:28	200,53	19,59	0:11	197,58	22,54
19.12.25	6,34	584	92,05	12:32	200,72	19,40	23:31	198,00	22,12
20.12.25	11,93	1.117	93,65	12:02	200,83	19,30	23:09	197,77	22,35
21.12.25	22,13	2.072	93,65	---	---	---	23:47	197,62	22,50
22.12.25	21,30	1.992	93,51	6:29	200,33	19,79	23:59	197,58	22,54
23.12.25	21,70	2.034	93,74	9:17	200,23	19,89	23:09	197,45	22,68
24.12.25	5,65	520	92,05	12:20	200,69	19,43	1:21	197,44	22,68
25.12.25	9,73	896	92,09	10:28	200,86	19,27	15:12	197,94	22,18
26.12.25	14,96	1.402	93,70	10:18	200,88	19,24	22:25	197,77	22,36
27.12.25	21,09	1.983	94,01	8:00	200,41	19,71	23:58	197,68	22,45
28.12.25	13,48	1.263	93,73	8:49	200,73	19,40	3:27	197,64	22,48
29.12.25	5,71	526	92,07	8:46	200,93	19,19	16:09	198,41	21,71
30.12.25	10,23	942	92,10	7:34	200,99	19,14	19:45	198,02	22,10
31.12.25	16,16	1.519	93,99	5:57	200,88	19,24	23:49	197,89	22,23
Σ	457,47	42.275							
Mittelwert	14,76	1.364	92,41		200,47	19,65		197,59	22,53
Minimum	5,65	520	90,58		199,82	19,14		197,19	21,71
Maximum	24,00	2.208	94,01		200,99	20,30		198,41	22,94

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:51 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.12.25	17,38	1.701	97,87	6:02	202,83	18,55	23:53	198,25	23,13
02.12.25	15,02	1.472	98,00	15:11	202,47	18,91	8:39	198,13	23,25
03.12.25	9,10	921	101,19	12:11	202,80	18,59	3:31	198,80	22,58
04.12.25	8,95	900	100,59	15:08	202,87	18,51	0:56	198,92	22,46
05.12.25	14,94	1.502	100,56	5:42	202,83	18,55	21:59	198,12	23,27
06.12.25	22,60	2.317	102,54	---	---	---	20:58	197,68	23,70
07.12.25	21,26	2.188	102,93	---	---	---	1:57	197,70	23,68
08.12.25	23,29	2.265	97,27	---	---	---	2:45	197,73	23,65
09.12.25	22,57	2.102	93,12	9:22	202,06	19,33	3:51	197,04	24,34
10.12.25	24,00	2.358	98,25	---	---	---	0:43	196,98	24,41
11.12.25	24,00	2.327	96,96	---	---	---	22:37	196,93	24,45
12.12.25	23,59	2.305	97,72	---	---	---	22:12	196,99	24,39
13.12.25	24,00	2.353	98,04	---	---	---	15:12	196,99	24,39
14.12.25	20,36	2.076	101,96	8:37	202,44	18,94	0:44	197,14	24,24
15.12.25	24,00	2.385	99,38	---	---	---	23:41	197,21	24,17
16.12.25	23,36	2.356	100,85	---	---	---	0:00	197,23	24,15
17.12.25	22,41	2.230	99,53	---	---	---	21:05	197,28	24,11
18.12.25	22,36	2.265	101,29	5:54	202,12	19,26	0:25	197,23	24,15
19.12.25	22,26	2.307	103,63	---	---	---	0:00	197,43	23,95
20.12.25	15,41	1.618	105,02	22:55	202,68	18,70	0:00	197,59	23,79
21.12.25	5,53	562	101,70	8:43	203,13	18,25	17:21	199,41	21,97
22.12.25	6,73	692	102,76	7:35	203,34	18,04	22:41	199,47	21,91
23.12.25	10,03	1.062	105,84	9:20	203,36	18,02	21:26	199,19	22,19
24.12.25	21,79	2.339	107,34	---	---	---	22:50	198,35	23,03
25.12.25	21,57	2.231	103,41	8:08	202,84	18,54	20:20	198,01	23,37
26.12.25	10,18	1.059	104,06	12:05	203,03	18,36	1:09	197,92	23,47
27.12.25	2,03	210	103,24	9:11	203,42	17,96	0:05	199,54	21,84
28.12.25	9,58	1.030	107,52	8:49	203,84	17,55	23:58	199,18	22,21
29.12.25	24,00	2.564	106,83	---	---	---	23:07	198,56	22,82
30.12.25	21,92	2.275	103,81	10:41	203,03	18,35	23:33	198,18	23,21
31.12.25	8,52	888	104,22	9:40	203,31	18,07	0:00	198,19	23,19
Σ	542,73	54.860							
Mittelwert	17,51	1.770	101,08		202,91	18,47		197,98	23,40
Minimum	2,03	210	93,12		202,06	17,55		196,93	21,84
Maximum	24,00	2.564	107,52		203,84	19,33		199,54	24,45

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:51 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.12.25	24,00	2.292	95,50	---	---	---	22:10	199,31	26,53
02.12.25	23,41	2.240	95,71	---	---	---	10:09	199,33	26,51
03.12.25	23,50	2.281	97,06	---	---	---	0:00	199,69	26,16
04.12.25	23,49	2.282	97,14	---	---	---	1:10	199,82	26,03
05.12.25	21,45	2.063	96,20	19:46	203,56	22,28	23:57	199,16	26,68
06.12.25	9,44	887	93,98	10:01	203,71	22,13	0:44	199,04	26,80
07.12.25	8,99	845	94,02	10:34	204,02	21,82	1:44	199,08	26,77
08.12.25	16,50	1.529	92,69	8:34	203,77	22,07	14:25	199,04	26,80
09.12.25	19,86	1.827	92,01	9:49	203,64	22,20	0:56	199,04	26,80
10.12.25	13,87	1.295	93,38	7:00	202,99	22,85	8:03	199,04	26,80
11.12.25	15,77	1.471	93,30	6:07	202,70	23,14	8:42	199,04	26,80
12.12.25	14,45	1.350	93,46	6:41	203,04	22,80	2:47	199,04	26,80
13.12.25	13,59	1.268	93,31	22:36	202,95	22,89	2:51	199,04	26,80
14.12.25	8,70	817	93,93	8:41	204,02	21,82	0:13	199,04	26,80
15.12.25	13,39	1.253	93,59	5:57	203,38	22,46	9:27	199,04	26,80
16.12.25	10,58	994	94,00	15:31	203,45	22,40	19:02	199,04	26,80
17.12.25	13,12	1.229	93,71	6:32	203,71	22,13	0:05	199,04	26,80
18.12.25	9,98	935	93,72	8:18	203,58	22,26	0:00	199,04	26,80
19.12.25	6,82	643	94,22	11:55	203,76	22,08	23:33	199,04	26,80
20.12.25	12,14	1.175	96,82	5:47	203,86	21,98	13:37	199,40	26,44
21.12.25	22,36	2.188	97,85	---	---	---	0:20	200,10	25,74
22.12.25	21,55	2.107	97,79	6:25	205,00	20,84	22:52	200,24	25,60
23.12.25	21,39	2.114	98,84	9:16	205,05	20,79	21:32	200,27	25,57
24.12.25	6,00	574	95,65	8:46	204,59	21,25	22:36	199,69	26,15
25.12.25	10,10	955	94,55	8:14	204,46	21,38	19:58	199,25	26,59
26.12.25	15,24	1.486	97,48	10:16	204,77	21,08	0:49	199,22	26,62
27.12.25	21,33	2.103	98,60	8:00	205,20	20,64	0:50	200,27	25,57
28.12.25	13,99	1.373	98,11	8:47	205,72	20,12	17:09	200,57	25,28
29.12.25	6,20	586	94,47	8:31	204,40	21,44	16:10	199,82	26,03
30.12.25	10,30	973	94,46	10:42	204,94	20,90	23:17	199,40	26,45
31.12.25	16,54	1.620	97,95	6:00	204,57	21,27	19:40	200,44	25,40
Σ	468,01	44.755							
Mittelwert	15,10	1.444	95,63		204,03	21,81		199,44	26,40
Minimum	6,00	574	92,01		202,70	20,12		199,04	25,28
Maximum	24,00	2.292	98,84		205,72	23,14		200,57	26,80

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:51 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.12.25	3,74	359	96,07	6:08	204,87	26,55	21:56	195,99	35,43
02.12.25	3,56	353	99,28	16:13	204,49	26,93	9:03	194,75	36,66
03.12.25	0,00	0	---	11:42	204,82	26,59	---	---	---
04.12.25	0,59	57	96,98	9:42	204,90	26,52	---	---	---
05.12.25	7,96	826	103,74	5:51	204,85	26,56	21:40	194,57	36,85
06.12.25	24,00	2.533	105,54	---	---	---	5:55	194,29	37,12
07.12.25	24,00	2.539	105,79	---	---	---	3:11	194,34	37,08
08.12.25	24,00	2.454	102,25	---	---	---	21:55	194,26	37,15
09.12.25	22,00	2.185	99,32	9:20	203,80	27,61	3:49	193,62	37,79
10.12.25	24,00	2.491	103,79	---	---	---	0:36	193,51	37,90
11.12.25	24,00	2.480	103,33	---	---	---	22:40	193,67	37,75
12.12.25	24,00	2.492	103,83	---	---	---	22:12	193,74	37,67
13.12.25	24,00	2.492	103,83	---	---	---	15:15	193,74	37,67
14.12.25	23,37	2.474	105,86	---	---	---	1:51	193,91	37,50
15.12.25	24,00	2.502	104,25	---	---	---	23:43	193,94	37,47
16.12.25	22,79	2.391	104,89	---	---	---	23:55	193,96	37,46
17.12.25	24,00	2.510	104,58	---	---	---	21:08	194,00	37,41
18.12.25	23,71	2.495	105,24	---	---	---	0:26	193,97	37,44
19.12.25	24,00	2.549	106,21	---	---	---	0:00	194,20	37,21
20.12.25	14,28	1.527	106,93	23:21	204,82	26,59	0:00	194,32	37,09
21.12.25	0,00	0	---	8:41	205,33	26,09	---	---	---
22.12.25	0,00	0	---	7:49	205,56	25,86	---	---	---
23.12.25	0,72	70	97,71	23:42	205,57	25,84	---	---	---
24.12.25	22,54	2.410	106,93	0:09	205,59	25,83	22:58	194,83	36,59
25.12.25	24,00	2.536	105,67	---	---	---	20:21	194,46	36,95
26.12.25	8,75	936	107,00	13:00	205,17	26,24	1:08	194,41	37,00
27.12.25	0,00	0	---	9:21	205,63	25,78	---	---	---
28.12.25	8,66	927	107,05	8:54	206,14	25,28	23:53	195,22	36,19
29.12.25	24,00	2.553	106,38	---	---	---	22:54	194,81	36,60
30.12.25	21,97	2.317	105,46	10:24	205,08	26,33	23:27	194,58	36,83
31.12.25	4,92	526	107,01	9:54	205,56	25,86	0:00	194,61	36,80
Σ	477,54	49.984							
Mittelwert	15,40	1.612	104,67		205,13	26,28		194,31	37,10
Minimum	0,00	0	96,07		203,80	25,28		193,51	35,43
Maximum	24,00	2.553	107,05		206,14	27,61		195,99	37,90

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:51 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.12.25	24,00	2.156	89,83	---	---	---	22:50	203,29	28,76
02.12.25	22,05	1.991	90,30	10:08	210,39	21,67	2:04	203,17	28,89
03.12.25	24,00	2.187	91,13	---	---	---	8:30	203,09	28,96
04.12.25	24,00	2.185	91,04	---	---	---	7:11	203,20	28,86
05.12.25	16,72	1.518	90,79	23:58	211,78	20,27	3:34	203,23	28,82
06.12.25	0,00	0	---	13:50	212,41	19,65	---	---	---
07.12.25	0,00	0	---	11:15	212,59	19,46	---	---	---
08.12.25	4,30	374	87,00	8:35	212,56	19,49	23:59	205,59	26,47
09.12.25	8,82	761	86,30	13:30	212,24	19,82	23:51	204,04	28,01
10.12.25	0,00	0	---	16:32	212,13	19,92	---	---	---
11.12.25	0,00	0	---	11:10	212,19	19,86	---	---	---
12.12.25	0,00	0	---	9:50	212,27	19,78	---	---	---
13.12.25	0,51	45	88,52	6:45	212,24	19,82	---	---	---
14.12.25	0,00	0	---	11:30	212,55	19,51	---	---	---
15.12.25	0,00	0	---	5:46	212,48	19,57	---	---	---
16.12.25	0,27	24	89,26	14:18	212,52	19,54	---	---	---
17.12.25	0,00	0	---	8:21	212,56	19,49	---	---	---
18.12.25	0,00	0	---	16:52	212,56	19,49	---	---	---
19.12.25	0,00	0	---	12:02	212,62	19,43	---	---	---
20.12.25	9,76	906	92,81	11:49	212,67	19,39	23:09	203,84	28,21
21.12.25	24,00	2.200	91,67	---	---	---	7:13	203,49	28,56
22.12.25	24,00	2.199	91,63	---	---	---	6:16	203,45	28,61
23.12.25	10,27	934	90,93	23:54	213,07	18,99	1:21	203,45	28,61
24.12.25	1,91	175	91,42	1:42	213,13	18,93	5:39	205,88	26,18
25.12.25	0,00	0	---	10:16	212,79	19,26	---	---	---
26.12.25	15,00	1.386	92,40	8:46	212,73	19,32	22:21	203,84	28,21
27.12.25	24,00	2.207	91,96	---	---	---	8:00	203,54	28,52
28.12.25	14,39	1.335	92,79	23:53	212,42	19,63	4:36	203,51	28,55
29.12.25	1,59	145	90,99	9:00	212,76	19,29	20:29	206,14	25,92
30.12.25	0,37	33	88,26	12:16	212,87	19,19	---	---	---
31.12.25	19,13	1.765	92,28	3:18	212,73	19,32	23:47	203,86	28,20
Σ	269,09	24.526							
Mittelwert	8,68	791	91,14		212,45	19,60		203,92	28,13
Minimum	0,00	0	86,30		210,39	18,93		203,09	25,92
Maximum	24,00	2.207	92,81		213,13	21,67		206,14	28,96

Meßpunkthöhe (MP): 232,05 m üNN