

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB02
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.12.25	24,00	1.722	71,75	---	---	---	7:59	197,60	17,50
02.12.25	24,00	1.712	71,33	---	---	---	23:58	197,62	17,47
03.12.25	24,00	1.722	71,75	---	---	---	8:24	197,60	17,49
04.12.25	24,00	1.724	71,83	---	---	---	13:48	197,60	17,49
05.12.25	24,00	1.722	71,75	---	---	---	22:08	197,60	17,50
06.12.25	24,00	1.732	72,17	---	---	---	2:01	197,59	17,50
07.12.25	24,00	1.736	72,33	---	---	---	3:10	197,60	17,50
08.12.25	7,81	565	72,31	8:48	198,49	16,60	6:37	197,60	17,50
09.12.25	14,53	1.052	72,41	9:26	198,73	16,36	20:13	197,64	17,45
10.12.25	24,00	1.727	71,96	---	---	---	5:55	197,62	17,47
11.12.25	24,00	1.724	71,83	---	---	---	3:38	197,61	17,48
12.12.25	24,00	1.725	71,88	---	---	---	5:02	197,60	17,50
13.12.25	24,00	1.726	71,92	---	---	---	19:58	197,59	17,50
14.12.25	24,00	1.740	72,50	---	---	---	7:29	197,57	17,52
15.12.25	24,00	1.727	71,96	---	---	---	0:09	197,62	17,47
16.12.25	24,00	1.728	72,00	---	---	---	14:01	191,00	24,09
17.12.25	24,00	1.730	72,08	---	---	---	5:48	197,60	17,50
18.12.25	24,00	1.735	72,29	---	---	---	4:57	197,60	17,49
19.12.25	24,00	1.739	72,46	---	---	---	4:28	197,62	17,47
20.12.25	24,00	1.744	72,67	---	---	---	0:36	197,63	17,47
21.12.25	24,00	1.740	72,50	---	---	---	23:42	197,63	17,46
22.12.25	24,00	1.738	72,42	---	---	---	19:40	197,62	17,47
23.12.25	24,00	1.724	71,83	---	---	---	22:48	197,60	17,49
24.12.25	24,00	1.739	72,46	---	---	---	4:14	197,59	17,50
25.12.25	24,00	1.751	72,96	---	---	---	5:58	197,60	17,50
26.12.25	24,00	1.750	72,92	---	---	---	6:22	197,58	17,51
27.12.25	24,00	1.746	72,75	---	---	---	0:59	197,61	17,48
28.12.25	24,00	1.749	72,88	---	---	---	6:48	197,57	17,52
29.12.25	24,00	1.737	72,38	---	---	---	0:32	197,63	17,47
30.12.25	24,00	1.730	72,08	---	---	---	8:13	197,62	17,47
31.12.25	24,00	1.742	72,58	---	---	---	4:31	197,62	17,47
Σ	718,34	51.878							
Mittelwert	23,17	1.673	72,22		198,61	16,48		197,39	17,70
Minimum	7,81	565	71,33		198,49	16,36		191,00	17,45
Maximum	24,00	1.751	72,96		198,73	16,60		197,64	24,09

Meßpunkthöhe (MP): 215,09 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB05
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.12.25	24,00	502	20,92	---	---	---	8:26	195,65	13,93
02.12.25	24,00	500	20,83	---	---	---	1:58	195,67	13,92
03.12.25	24,00	503	20,96	---	---	---	21:54	195,66	13,92
04.12.25	24,00	503	20,96	---	---	---	1:41	195,67	13,91
05.12.25	24,00	502	20,92	---	---	---	21:51	195,63	13,95
06.12.25	24,00	504	21,00	---	---	---	1:28	195,62	13,96
07.12.25	24,00	503	20,96	---	---	---	3:08	195,62	13,96
08.12.25	7,83	165	21,08	8:48	196,07	13,51	3:40	195,62	13,96
09.12.25	14,38	304	21,14	9:35	196,34	13,24	20:09	195,70	13,89
10.12.25	24,00	504	21,00	---	---	---	20:49	195,64	13,95
11.12.25	24,00	501	20,88	---	---	---	0:54	195,63	13,95
12.12.25	24,00	501	20,88	---	---	---	5:00	195,61	13,97
13.12.25	24,00	502	20,92	---	---	---	19:54	195,61	13,98
14.12.25	24,00	505	21,04	---	---	---	1:48	195,61	13,98
15.12.25	24,00	502	20,92	---	---	---	0:03	195,64	13,95
16.12.25	24,00	502	20,92	---	---	---	14:01	186,00	23,58
17.12.25	24,00	503	20,96	---	---	---	4:30	195,62	13,96
18.12.25	22,94	481	20,97	15:31	196,07	13,51	0:28	195,62	13,96
19.12.25	24,00	504	21,00	---	---	---	4:20	195,63	13,95
20.12.25	24,00	505	21,04	---	---	---	0:00	195,64	13,95
21.12.25	24,00	505	21,04	---	---	---	0:17	195,68	13,90
22.12.25	24,00	505	21,04	---	---	---	23:29	195,67	13,91
23.12.25	24,00	501	20,88	---	---	---	22:26	195,66	13,92
24.12.25	24,00	504	21,00	---	---	---	10:02	195,62	13,96
25.12.25	24,00	505	21,04	---	---	---	6:03	195,62	13,96
26.12.25	24,00	506	21,08	---	---	---	3:09	195,61	13,97
27.12.25	24,00	506	21,08	---	---	---	0:53	195,66	13,92
28.12.25	24,00	507	21,13	---	---	---	6:06	195,64	13,94
29.12.25	24,00	503	20,96	---	---	---	21:43	195,64	13,94
30.12.25	24,00	502	20,92	---	---	---	8:45	195,64	13,95
31.12.25	24,00	503	20,96	---	---	---	0:02	195,64	13,95
Σ	717,15	15.043							
Mittelwert	23,13	485	20,98		196,16	13,42		195,33	14,25
Minimum	7,83	165	20,83		196,07	13,24		186,00	13,89
Maximum	24,00	507	21,14		196,34	13,51		195,70	23,58

Meßpunkthöhe (MP): 209,58 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB06
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.12.25	24,00	659	27,46	---	---	---	7:46	194,34	12,66
02.12.25	24,00	655	27,29	---	---	---	2:13	194,34	12,66
03.12.25	24,00	663	27,63	---	---	---	8:11	194,34	12,66
04.12.25	24,00	665	27,71	---	---	---	6:57	194,34	12,65
05.12.25	24,00	659	27,46	---	---	---	21:36	194,34	12,66
06.12.25	24,00	666	27,75	---	---	---	5:57	194,31	12,69
07.12.25	24,00	668	27,83	---	---	---	3:17	194,30	12,69
08.12.25	7,82	218	27,89	8:48	195,00	11,99	3:39	194,29	12,70
09.12.25	9,95	275	27,64	9:32	195,37	11,63	19:55	194,40	12,60
10.12.25	24,00	663	27,63	---	---	---	20:44	194,34	12,65
11.12.25	24,00	658	27,42	---	---	---	3:29	194,33	12,66
12.12.25	24,00	658	27,42	---	---	---	4:59	194,30	12,69
13.12.25	24,00	658	27,42	---	---	---	19:57	194,31	12,68
14.12.25	24,00	671	27,96	---	---	---	8:04	194,26	12,73
15.12.25	24,00	659	27,46	---	---	---	19:44	194,34	12,66
16.12.25	24,00	663	27,63	---	---	---	14:01	184,00	22,99
17.12.25	24,00	662	27,58	---	---	---	4:25	194,30	12,69
18.12.25	24,00	667	27,79	---	---	---	4:49	194,29	12,70
19.12.25	24,00	670	27,92	---	---	---	4:17	194,31	12,69
20.12.25	24,00	674	28,08	---	---	---	4:48	194,31	12,69
21.12.25	24,00	674	28,08	---	---	---	3:44	194,34	12,65
22.12.25	24,00	674	28,08	---	---	---	4:09	194,35	12,64
23.12.25	24,00	663	27,63	---	---	---	1:14	194,34	12,66
24.12.25	24,00	672	28,00	---	---	---	4:40	194,30	12,69
25.12.25	24,00	674	28,08	---	---	---	5:45	194,30	12,69
26.12.25	24,00	678	28,25	---	---	---	6:15	194,26	12,73
27.12.25	24,00	679	28,29	---	---	---	7:17	194,33	12,66
28.12.25	24,00	681	28,38	---	---	---	6:07	194,29	12,70
29.12.25	24,00	671	27,96	---	---	---	1:54	194,34	12,65
30.12.25	24,00	664	27,67	---	---	---	8:55	194,31	12,69
31.12.25	24,00	675	28,13	---	---	---	4:09	194,31	12,68
Σ	713,77	19.836							
Mittelwert	23,02	640	27,79		195,18	11,81		193,98	13,01
Minimum	7,82	218	27,29		195,00	11,63		184,00	12,60
Maximum	24,00	681	28,38		195,37	11,99		194,40	22,99

Meßpunkthöhe (MP): 206,99 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB07
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb h	Menge m³	Leistung m³/h	Zeitpunkt Uhr			Zeitpunkt Uhr		
					m üNN	m uMP		m üNN	m uMP
01.12.25	24,00	1.270	52,92	---	---	---	7:49	193,12	9,55
02.12.25	24,00	1.268	52,83	---	---	---	2:03	193,13	9,54
03.12.25	24,00	1.271	52,96	---	---	---	8:24	193,13	9,54
04.12.25	24,00	1.273	53,04	---	---	---	7:01	193,13	9,54
05.12.25	24,00	1.271	52,96	---	---	---	21:44	193,11	9,56
06.12.25	24,00	1.272	53,00	---	---	---	1:15	193,10	9,57
07.12.25	24,00	1.273	53,04	---	---	---	3:11	193,10	9,57
08.12.25	7,82	415	53,07	8:48	194,00	8,67	3:39	193,10	9,57
09.12.25	14,32	767	53,55	9:33	194,40	8,27	20:13	193,19	9,48
10.12.25	24,00	1.279	53,29	---	---	---	20:46	193,12	9,55
11.12.25	24,00	1.276	53,17	---	---	---	17:56	193,10	9,57
12.12.25	24,00	1.277	53,21	---	---	---	5:06	193,09	9,58
13.12.25	24,00	1.277	53,21	---	---	---	21:08	193,08	9,59
14.12.25	24,00	1.281	53,38	---	---	---	7:46	193,07	9,60
15.12.25	24,00	1.277	53,21	---	---	---	19:38	193,10	9,57
16.12.25	24,00	1.277	53,21	---	---	---	14:01	182,00	20,67
17.12.25	24,00	1.278	53,25	---	---	---	5:42	193,09	9,58
18.12.25	24,00	1.279	53,29	---	---	---	4:49	193,08	9,59
19.12.25	24,00	1.280	53,33	---	---	---	0:18	193,10	9,57
20.12.25	24,00	1.282	53,42	---	---	---	0:15	193,10	9,57
21.12.25	24,00	1.281	53,38	---	---	---	3:43	193,12	9,55
22.12.25	24,00	1.282	53,42	---	---	---	0:46	193,13	9,54
23.12.25	24,00	1.278	53,25	---	---	---	23:05	193,10	9,57
24.12.25	24,00	1.281	53,38	---	---	---	4:17	193,09	9,58
25.12.25	24,00	1.282	53,42	---	---	---	21:46	193,07	9,60
26.12.25	24,00	1.284	53,50	---	---	---	6:16	193,06	9,61
27.12.25	24,00	1.283	53,46	---	---	---	0:52	193,10	9,57
28.12.25	24,00	1.284	53,50	---	---	---	5:58	193,09	9,58
29.12.25	24,00	1.281	53,38	---	---	---	20:42	193,10	9,57
30.12.25	24,00	1.278	53,25	---	---	---	8:28	193,10	9,57
31.12.25	24,00	1.282	53,42	---	---	---	0:08	193,10	9,57
Σ	718,14	38.239							
Mittelwert	23,17	1.234	53,25		194,20	8,47		192,74	9,93
Minimum	7,82	415	52,83		194,00	8,27		182,00	9,48
Maximum	24,00	1.284	53,55		194,40	8,67		193,19	20,67

Meßpunkthöhe (MP): 202,67 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB08
Monatsbericht vom Dezember 2025
gedruckt am: 03.01.2026, 06:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.12.25	24,00	1.146	47,75	---	---	---	7:45	193,68	11,61
02.12.25	24,00	1.142	47,58	---	---	---	1:57	193,69	11,60
03.12.25	24,00	1.148	47,83	---	---	---	8:18	193,69	11,60
04.12.25	24,00	1.148	47,83	---	---	---	7:03	193,70	11,59
05.12.25	24,00	1.148	47,83	---	---	---	22:07	193,68	11,62
06.12.25	24,00	1.150	47,92	---	---	---	1:13	193,68	11,62
07.12.25	24,00	1.150	47,92	---	---	---	3:11	193,66	11,63
08.12.25	7,82	375	47,95	8:48	194,55	10,74	3:39	193,66	11,63
09.12.25	14,31	691	48,27	9:24	194,97	10,32	20:23	193,78	11,51
10.12.25	24,00	1.152	48,00	---	---	---	20:56	193,71	11,58
11.12.25	24,00	1.148	47,83	---	---	---	3:31	193,70	11,59
12.12.25	24,00	1.147	47,79	---	---	---	4:57	193,68	11,61
13.12.25	24,00	1.147	47,79	---	---	---	21:38	193,67	11,62
14.12.25	24,00	1.154	48,08	---	---	---	2:19	193,66	11,63
15.12.25	24,00	1.146	47,75	---	---	---	0:26	193,69	11,60
16.12.25	24,00	1.148	47,83	---	---	---	14:01	183,00	22,29
17.12.25	24,00	1.148	47,83	---	---	---	4:29	193,67	11,62
18.12.25	24,00	1.149	47,88	---	---	---	5:29	193,66	11,63
19.12.25	24,00	1.151	47,96	---	---	---	4:15	193,68	11,62
20.12.25	24,00	1.154	48,08	---	---	---	4:50	193,68	11,62
21.12.25	24,00	1.154	48,08	---	---	---	3:51	193,70	11,59
22.12.25	24,00	1.154	48,08	---	---	---	0:38	193,71	11,59
23.12.25	24,00	1.148	47,83	---	---	---	21:57	193,68	11,61
24.12.25	24,00	1.153	48,04	---	---	---	7:49	193,66	11,63
25.12.25	24,00	1.155	48,13	---	---	---	5:47	193,66	11,63
26.12.25	24,00	1.156	48,17	---	---	---	6:16	193,65	11,65
27.12.25	24,00	1.156	48,17	---	---	---	0:58	193,68	11,61
28.12.25	24,00	1.158	48,25	---	---	---	6:17	193,67	11,62
29.12.25	24,00	1.152	48,00	---	---	---	22:45	193,69	11,60
30.12.25	24,00	1.149	47,88	---	---	---	8:16	193,68	11,62
31.12.25	24,00	1.154	48,08	---	---	---	0:12	193,68	11,61
Σ	718,14	34.431							
Mittelwert	23,17	1.111	47,94		194,76	10,53		193,34	11,95
Minimum	7,82	375	47,58		194,55	10,32		183,00	11,51
Maximum	24,00	1.158	48,27		194,97	10,74		193,78	22,29

Meßpunkthöhe (MP): 205,29 m üNN