

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	24,00	1.196	49,83	---	---	---	11:11	192,28	17,48
02.02.26	24,00	1.193	49,71	---	---	---	22:54	192,23	17,53
03.02.26	24,00	1.189	49,54	---	---	---	23:55	191,78	17,99
04.02.26	24,00	1.186	49,42	---	---	---	7:32	191,65	18,11
05.02.26	24,00	1.189	49,54	---	---	---	1:41	191,94	17,82
06.02.26	24,00	1.188	49,50	---	---	---	22:12	192,00	17,77
07.02.26	24,00	1.189	49,54	---	---	---	23:24	191,95	17,81
08.02.26	24,00	1.197	49,88	---	---	---	0:00	192,03	17,73
09.02.26	24,00	1.201	50,04	---	---	---	0:00	193,31	16,45
10.02.26	24,00	1.185	49,38	---	---	---	23:50	192,74	17,02
11.02.26	24,00	1.178	49,08	---	---	---	23:16	192,09	17,67
12.02.26	24,00	1.170	48,75	---	---	---	20:52	191,83	17,93
13.02.26	21,90	1.069	48,81	21:43	193,99	15,77	15:03	191,83	17,93
14.02.26	24,00	1.192	49,67	---	---	---	1:07	192,64	17,13
15.02.26	24,00	1.204	50,17	---	---	---	0:00	193,03	16,74
16.02.26	24,00	1.198	49,92	---	---	---	22:07	193,33	16,43
17.02.26	22,51	1.120	49,76	12:52	194,86	14,91	11:00	193,19	16,58
18.02.26	24,00	1.203	50,13	---	---	---	23:40	193,44	16,32
19.02.26	23,88	1.194	50,00	---	---	---	22:54	193,44	16,32
20.02.26	24,00	1.186	49,42	---	---	---	22:09	192,85	16,91
21.02.26	24,00	1.179	49,13	---	---	---	23:53	192,36	17,41
22.02.26	24,00	1.167	48,63	---	---	---	22:25	192,01	17,75
23.02.26	24,00	1.191	49,63	---	---	---	3:11	191,97	17,80
24.02.26	10,06	507	50,40	18:08	195,34	14,42	0:00	193,25	16,51
25.02.26	24,00	1.209	50,38	---	---	---	4:08	193,47	16,29
26.02.26	24,00	1.209	50,38	---	---	---	0:04	193,58	16,19
27.02.26	24,00	1.204	50,17	---	---	---	0:05	193,61	16,15
28.02.26	24,00	1.215	50,63	---	---	---	0:00	193,61	16,15
Σ	654,35	32.508							
Mittelwert	23,37	1.161	49,68		194,73	15,03		192,62	17,14
Minimum	10,06	507	48,63		193,99	14,42		191,65	16,15
Maximum	24,00	1.215	50,63		195,34	15,77		193,61	18,11

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	23,86	5.610	235,11	---	---	---	0:32	190,98	16,84
02.02.26	24,00	5.636	234,83	---	---	---	3:52	190,98	16,84
03.02.26	24,00	5.596	233,17	---	---	---	0:13	190,98	16,84
04.02.26	24,00	5.577	232,38	---	---	---	15:11	190,97	16,85
05.02.26	24,00	5.619	234,13	---	---	---	0:00	190,98	16,84
06.02.26	24,00	5.620	234,17	---	---	---	0:08	190,98	16,84
07.02.26	23,58	5.523	234,19	---	---	---	0:00	190,98	16,84
08.02.26	4,39	1.013	230,91	23:58	200,33	7,49	2:24	190,99	16,84
09.02.26	0,98	218	223,59	6:00	200,60	7,22	---	---	---
10.02.26	9,90	2.280	230,21	8:05	199,70	8,12	23:56	191,48	16,35
11.02.26	24,00	5.541	230,88	---	---	---	14:08	190,97	16,85
12.02.26	24,00	5.500	229,17	---	---	---	0:25	190,97	16,85
13.02.26	17,69	4.063	229,62	23:54	198,18	9,64	12:51	190,97	16,85
14.02.26	0,47	102	219,09	20:09	199,11	8,72	---	---	---
15.02.26	0,00	0	---	23:54	199,48	8,34	---	---	---
16.02.26	0,70	156	223,30	11:24	199,63	8,19	---	---	---
17.02.26	4,43	1.002	226,21	23:06	200,15	7,67	9:31	192,69	15,13
18.02.26	1,09	243	222,60	6:01	200,55	7,27	---	---	---
19.02.26	0,00	0	---	10:06	199,51	8,31	---	---	---
20.02.26	8,29	1.870	225,65	7:36	199,43	8,39	23:58	191,38	16,45
21.02.26	15,44	3.501	226,81	9:25	198,69	9,13	17:22	190,98	16,84
22.02.26	24,00	5.460	227,50	---	---	---	5:55	190,97	16,85
23.02.26	3,15	717	227,90	23:04	199,59	8,23	1:44	190,97	16,85
24.02.26	5,71	1.297	227,23	8:54	200,28	7,54	20:03	192,21	15,61
25.02.26	0,41	90	221,46	12:55	200,28	7,54	---	---	---
26.02.26	0,55	121	220,45	11:49	200,24	7,58	---	---	---
27.02.26	0,73	162	220,99	5:33	200,13	7,69	---	---	---
28.02.26	0,00	0	---	9:40	200,56	7,26	---	---	---
Σ	313,36	72.517							
Mittelwert	11,19	2.590	231,42		199,80	8,02		191,19	16,63
Minimum	0,00	0	219,09		198,18	7,22		190,97	15,13
Maximum	24,00	5.636	235,11		200,60	9,64		192,69	16,85

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	0,00	0	---	---	---	---	---	---	---
02.02.26	0,00	0	---	---	---	---	---	---	---
03.02.26	0,00	0	---	10:43	191,39	21,45	---	---	---
04.02.26	0,00	0	---	23:52	190,93	21,91	---	---	---
05.02.26	0,00	0	---	19:30	191,13	21,71	---	---	---
06.02.26	0,00	0	---	22:43	191,17	21,66	---	---	---
07.02.26	0,00	0	---	23:42	192,00	20,84	---	---	---
08.02.26	0,00	0	---	23:57	195,32	17,51	---	---	---
09.02.26	13,51	1.948	144,19	5:59	195,61	17,22	16:51	190,30	22,53
10.02.26	17,75	2.525	142,22	19:50	192,49	20,34	10:41	188,80	24,03
11.02.26	6,63	910	137,15	0:00	191,91	20,93	21:50	186,86	25,98
12.02.26	12,68	1.731	136,52	6:40	191,04	21,80	19:55	186,53	26,30
13.02.26	14,84	2.063	139,05	8:28	190,84	22,00	17:34	186,61	26,22
14.02.26	24,00	3.457	144,04	---	---	---	7:32	189,52	23,31
15.02.26	24,00	3.487	145,29	---	---	---	0:00	190,36	22,47
16.02.26	24,00	3.477	144,88	---	---	---	19:29	190,15	22,69
17.02.26	11,98	1.715	143,21	23:02	195,05	17,79	10:50	189,54	23,30
18.02.26	17,33	2.506	144,64	5:48	195,46	17,38	21:31	190,15	22,69
19.02.26	24,00	3.467	144,46	---	---	---	0:18	190,55	22,29
20.02.26	24,00	3.415	142,29	---	---	---	23:57	188,02	24,82
21.02.26	24,00	3.384	141,00	---	---	---	23:57	187,03	25,81
22.02.26	24,00	3.336	139,00	---	---	---	22:21	186,64	26,19
23.02.26	15,58	2.210	141,83	11:45	194,30	18,54	2:11	186,60	26,24
24.02.26	17,29	2.455	141,98	8:56	195,17	17,67	20:58	188,50	24,34
25.02.26	13,14	1.876	142,81	12:48	195,15	17,68	0:08	190,09	22,75
26.02.26	13,60	1.943	142,84	11:50	195,09	17,74	21:45	190,33	22,50
27.02.26	16,11	2.299	142,69	---	---	---	21:28	190,27	22,56
28.02.26	11,41	1.636	143,32	9:30	195,43	17,41	18:28	190,91	21,92
Σ	349,86	49.840							
Mittelwert	12,49	1.780	142,46		193,30	19,53		188,89	23,94
Minimum	0,00	0	136,52		190,84	17,22		186,53	21,92
Maximum	24,00	3.487	145,29		195,61	22,00		190,91	26,30

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	23,81	4.565	191,76	---	---	---	0:00	177,02	33,10
02.02.26	24,00	4.596	191,50	---	---	---	---	---	---
03.02.26	24,00	4.562	190,08	---	---	---	---	---	---
04.02.26	24,00	4.541	189,21	---	---	---	---	---	---
05.02.26	24,00	4.572	190,50	---	---	---	---	---	---
06.02.26	24,00	4.572	190,50	---	---	---	---	---	---
07.02.26	23,53	4.483	190,55	---	---	---	23:16	180,07	30,04
08.02.26	4,05	760	187,56	23:33	194,97	15,14	2:27	177,02	33,10
09.02.26	0,81	146	180,99	5:22	195,32	14,79	---	---	---
10.02.26	9,79	1.832	187,12	8:14	194,41	15,71	22:15	177,00	33,11
11.02.26	24,00	4.503	187,63	---	---	---	0:00	177,00	33,11
12.02.26	24,00	4.470	186,25	---	---	---	0:00	177,02	33,10
13.02.26	17,69	3.302	186,68	23:58	192,72	17,40	0:00	177,02	33,10
14.02.26	0,41	73	178,78	17:47	193,91	16,21	---	---	---
15.02.26	0,00	0	---	17:29	194,35	15,77	---	---	---
16.02.26	0,59	105	179,06	10:42	194,55	15,57	---	---	---
17.02.26	4,80	883	183,78	23:01	194,49	15,63	10:47	178,26	31,86
18.02.26	0,87	156	179,42	6:01	195,08	15,03	---	---	---
19.02.26	0,00	0	---	6:04	194,18	15,93	---	---	---
20.02.26	7,84	1.443	184,04	7:13	194,07	16,04	23:57	177,92	32,20
21.02.26	14,81	2.747	185,47	9:26	193,49	16,62	18:32	177,00	33,11
22.02.26	24,00	4.465	186,04	---	---	---	0:38	177,00	33,11
23.02.26	3,14	585	186,29	23:07	193,91	16,21	0:00	177,00	33,11
24.02.26	4,52	823	181,92	8:59	194,84	15,28	19:59	178,73	31,39
25.02.26	0,30	52	174,79	12:54	194,59	15,52	---	---	---
26.02.26	0,56	100	180,18	11:48	194,49	15,63	---	---	---
27.02.26	0,91	164	179,73	5:33	194,35	15,77	---	---	---
28.02.26	0,00	0	---	8:12	194,90	15,22	---	---	---
Σ	310,42	58.500							
Mittelwert	11,09	2.089	188,45		194,36	15,75		177,54	32,57
Minimum	0,00	0	174,79		192,72	14,79		177,00	30,04
Maximum	24,00	4.596	191,76		195,32	17,40		180,07	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	20,73	2.509	121,06	4:25	192,73	22,05	0:00	183,26	31,51
02.02.26	22,76	2.765	121,51	---	---	---	0:00	183,86	30,92
03.02.26	24,00	2.908	121,17	---	---	---	23:55	183,17	31,60
04.02.26	22,74	2.748	120,83	7:56	192,45	22,32	6:33	183,05	31,72
05.02.26	23,71	2.871	121,11	---	---	---	0:40	183,29	31,48
06.02.26	23,41	2.835	121,13	---	---	---	4:19	183,40	31,37
07.02.26	23,68	2.876	121,47	---	---	---	0:00	183,71	31,07
08.02.26	17,75	2.134	120,25	9:40	194,46	20,32	2:13	184,04	30,73
09.02.26	17,79	2.125	119,45	---	---	---	21:57	184,64	30,14
10.02.26	16,78	1.988	118,45	8:22	194,32	20,46	23:55	183,43	31,34
11.02.26	24,00	2.862	119,25	---	---	---	23:09	183,19	31,59
12.02.26	24,00	2.859	119,13	---	---	---	20:48	183,05	31,72
13.02.26	23,66	2.824	119,38	---	---	---	0:44	183,16	31,62
14.02.26	11,60	1.376	118,63	17:38	194,11	20,67	0:00	184,07	30,70
15.02.26	7,82	935	119,51	10:51	194,67	20,11	1:27	184,70	30,08
16.02.26	12,10	1.442	119,19	11:04	194,76	20,01	20:40	184,58	30,20
17.02.26	16,73	1.989	118,86	13:13	194,03	20,75	10:55	184,10	30,67
18.02.26	15,63	1.859	118,96	---	---	---	0:00	184,36	30,41
19.02.26	15,81	1.881	118,99	---	---	---	18:20	184,50	30,27
20.02.26	9,42	1.110	117,88	17:12	193,51	21,26	14:11	184,42	30,35
21.02.26	0,00	0	---	9:36	194,00	20,78	---	---	---
22.02.26	0,00	0	---	7:30	193,23	21,54	---	---	---
23.02.26	20,90	2.513	120,23	3:03	193,10	21,68	5:46	183,98	30,79
24.02.26	21,22	2.532	119,32	9:43	194,58	20,20	22:41	183,54	31,24
25.02.26	22,30	2.683	120,30	---	---	---	0:39	183,69	31,08
26.02.26	24,00	2.890	120,42	---	---	---	22:52	184,00	30,78
27.02.26	24,00	2.878	119,92	---	---	---	22:53	183,92	30,85
28.02.26	22,97	2.772	120,70	---	---	---	0:00	183,97	30,81
Σ	509,49	61.164							
Mittelwert	18,20	2.184	120,05		193,84	20,93		183,81	30,96
Minimum	0,00	0	117,88		192,45	20,01		183,05	30,08
Maximum	24,00	2.908	121,51		194,76	22,32		184,70	31,72

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	20,76	1.178	56,74	4:25	194,68	18,60	0:00	189,56	23,72
02.02.26	22,78	1.297	56,93	---	---	---	23:38	190,75	22,53
03.02.26	24,00	1.357	56,54	---	---	---	23:40	190,18	23,10
04.02.26	22,76	1.279	56,21	7:55	194,92	18,36	15:56	189,94	23,34
05.02.26	23,72	1.330	56,07	---	---	---	0:21	189,96	23,32
06.02.26	23,43	1.318	56,24	---	---	---	4:51	189,98	23,30
07.02.26	23,69	1.345	56,77	---	---	---	0:00	190,70	22,58
08.02.26	17,90	977	54,59	9:35	194,92	18,36	21:52	189,51	23,77
09.02.26	18,02	962	53,39	---	---	---	22:02	189,28	24,00
10.02.26	16,88	889	52,68	8:25	194,22	19,06	13:47	189,01	24,27
11.02.26	24,00	1.299	54,13	---	---	---	0:00	189,25	24,03
12.02.26	24,00	1.311	54,63	---	---	---	16:30	189,98	23,30
13.02.26	23,68	1.291	54,52	---	---	---	23:57	189,48	23,80
14.02.26	13,75	730	53,10	17:38	194,15	19,13	0:55	189,38	23,90
15.02.26	7,93	424	53,48	10:10	194,93	18,35	1:30	189,38	23,90
16.02.26	12,23	650	53,15	11:08	194,68	18,60	20:47	189,28	24,00
17.02.26	16,59	875	52,73	13:11	194,48	18,80	21:10	188,91	24,37
18.02.26	15,84	843	53,21	---	---	---	1:47	188,84	24,44
19.02.26	16,06	848	52,80	---	---	---	18:24	189,03	24,25
20.02.26	9,56	503	52,63	23:00	193,92	19,36	10:03	189,03	24,25
21.02.26	0,00	0	---	22:05	194,93	18,35	---	---	---
22.02.26	0,00	0	---	7:10	195,40	17,88	---	---	---
23.02.26	20,91	1.112	53,17	2:59	195,30	17,98	22:54	188,65	24,63
24.02.26	21,23	1.112	52,37	9:44	195,00	18,28	22:51	188,46	24,82
25.02.26	22,34	1.186	53,08	---	---	---	0:49	188,43	24,85
26.02.26	24,00	1.268	52,83	---	---	---	2:44	188,56	24,72
27.02.26	24,00	1.258	52,42	---	---	---	23:59	188,46	24,82
28.02.26	23,00	1.223	53,18	---	---	---	0:00	188,46	24,82
Σ	513,05	27.865							
Mittelwert	18,32	995	54,31		194,73	18,55		189,32	23,96
Minimum	0,00	0	52,37		193,92	17,88		188,43	22,53
Maximum	24,00	1.357	56,93		195,40	19,36		190,75	24,85

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	0,84	91	108,19	23:42	201,94	14,86	---	---	---
02.02.26	0,00	0	---	5:56	202,16	14,64	---	---	---
03.02.26	0,00	0	---	2:49	201,83	14,97	---	---	---
04.02.26	0,00	0	---	7:51	201,43	15,37	---	---	---
05.02.26	0,00	0	---	3:04	201,19	15,61	---	---	---
06.02.26	0,00	0	---	23:32	201,90	14,90	---	---	---
07.02.26	0,00	0	---	23:42	202,15	14,65	---	---	---
08.02.26	21,53	2.330	108,23	0:14	202,16	14,64	21:57	193,77	23,03
09.02.26	24,00	2.567	106,96	---	---	---	22:14	193,59	23,21
10.02.26	21,32	2.253	105,65	---	---	---	13:54	193,52	23,28
11.02.26	5,83	623	106,95	23:53	201,40	15,40	11:31	194,65	22,15
12.02.26	1,43	147	102,94	9:09	201,74	15,06	15:22	195,49	21,31
13.02.26	6,63	711	107,28	9:50	201,77	15,03	23:59	194,12	22,68
14.02.26	24,00	2.565	106,88	---	---	---	23:53	193,61	23,19
15.02.26	22,95	2.470	107,62	9:54	200,41	16,39	1:41	193,58	23,22
16.02.26	24,00	2.569	107,04	---	---	---	20:58	193,55	23,25
17.02.26	22,68	2.408	106,15	12:57	200,36	16,44	21:25	193,32	23,48
18.02.26	24,00	2.556	106,50	---	---	---	1:51	193,26	23,54
19.02.26	24,00	2.551	106,29	---	---	---	21:55	193,38	23,42
20.02.26	24,00	2.529	105,38	---	---	---	10:21	193,37	23,43
21.02.26	19,87	2.102	105,78	20:58	200,84	15,96	0:38	193,60	23,20
22.02.26	9,14	966	105,64	7:05	201,35	15,45	23:39	195,03	21,77
23.02.26	21,34	2.281	106,89	3:04	201,32	15,48	22:53	193,28	23,52
24.02.26	21,15	2.240	105,93	9:53	200,88	15,92	7:01	193,12	23,68
25.02.26	24,00	2.562	106,75	---	---	---	4:36	193,01	23,79
26.02.26	24,00	2.554	106,42	---	---	---	9:02	193,12	23,68
27.02.26	24,00	2.541	105,88	---	---	---	19:22	193,08	23,72
28.02.26	24,00	2.564	106,83	---	---	---	6:51	192,99	23,81
Σ	414,71	44.180							
Mittelwert	14,81	1.578	106,53		201,46	15,34		193,64	23,16
Minimum	0,00	0	102,94		200,36	14,64		192,99	21,31
Maximum	24,00	2.569	108,23		202,16	16,44		195,49	23,81

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	0,87	158	180,97	22:57	198,13	23,02	---	---	---
02.02.26	0,00	0	---	6:24	198,38	22,77	---	---	---
03.02.26	0,00	0	---	4:50	197,89	23,26	---	---	---
04.02.26	0,00	0	---	0:00	197,24	23,91	---	---	---
05.02.26	0,00	0	---	2:54	196,88	24,27	---	---	---
06.02.26	0,00	0	---	23:34	198,08	23,07	---	---	---
07.02.26	0,00	0	---	23:51	198,40	22,75	---	---	---
08.02.26	21,51	3.971	184,59	0:56	198,42	22,73	21:57	179,87	41,28
09.02.26	24,00	4.323	180,13	---	---	---	8:21	179,50	41,65
10.02.26	21,39	3.773	176,37	---	---	---	7:46	179,59	41,56
11.02.26	6,03	1.069	177,42	23:40	197,48	23,67	11:32	181,36	39,79
12.02.26	1,45	243	168,13	8:19	197,92	23,23	15:24	183,19	37,96
13.02.26	6,64	1.205	181,61	8:16	197,98	23,17	19:38	181,24	39,91
14.02.26	24,00	4.329	180,38	---	---	---	23:53	179,92	41,23
15.02.26	22,97	4.181	182,01	9:54	195,80	25,35	8:53	179,42	41,73
16.02.26	24,00	4.331	180,46	---	---	---	20:59	179,72	41,43
17.02.26	22,70	4.042	178,07	12:57	195,80	25,35	11:40	179,08	42,07
18.02.26	24,00	4.299	179,13	---	---	---	1:53	179,20	41,95
19.02.26	24,00	4.283	178,46	---	---	---	22:53	179,64	41,51
20.02.26	24,00	4.211	175,46	---	---	---	10:22	179,57	41,58
21.02.26	19,96	3.522	176,49	20:55	196,42	24,73	0:36	179,72	41,43
22.02.26	9,36	1.641	175,28	7:05	197,16	23,99	23:43	181,92	39,23
23.02.26	21,34	3.854	180,56	3:06	197,16	23,99	17:19	179,10	42,05
24.02.26	21,23	3.778	177,99	9:52	196,40	24,75	7:15	177,72	43,43
25.02.26	24,00	4.328	180,33	---	---	---	4:22	178,65	42,50
26.02.26	24,00	4.299	179,13	---	---	---	7:55	179,06	42,09
27.02.26	24,00	4.257	177,38	---	---	---	19:22	179,16	41,99
28.02.26	24,00	4.323	180,13	---	---	---	6:56	178,55	42,60
Σ	415,44	74.420							
Mittelwert	14,84	2.658	179,14		197,39	23,76		179,77	41,38
Minimum	0,00	0	168,13		195,80	22,73		177,72	37,96
Maximum	24,00	4.331	184,59		198,42	25,35		183,19	43,43

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	0,00	0	---	9:39	188,02	39,51	---	---	---
02.02.26	0,00	0	---	16:12	188,02	39,51	---	---	---
03.02.26	0,00	0	---	---	---	---	---	---	---
04.02.26	0,00	0	---	11:27	188,02	39,51	---	---	---
05.02.26	0,00	0	---	6:58	188,02	39,51	---	---	---
06.02.26	0,00	0	---	2:33	188,02	39,51	---	---	---
07.02.26	0,00	0	---	11:08	188,02	39,51	---	---	---
08.02.26	0,00	0	---	3:19	188,02	39,51	---	---	---
09.02.26	0,00	0	---	5:21	188,02	39,51	---	---	---
10.02.26	0,00	0	---	17:35	188,02	39,51	---	---	---
11.02.26	0,00	0	---	1:10	188,02	39,51	---	---	---
12.02.26	0,00	0	---	0:32	188,02	39,51	---	---	---
13.02.26	0,00	0	---	23:57	188,02	39,51	---	---	---
14.02.26	0,00	0	---	6:16	188,02	39,51	---	---	---
15.02.26	0,00	0	---	5:59	188,02	39,51	---	---	---
16.02.26	0,00	0	---	7:56	188,02	39,51	---	---	---
17.02.26	0,00	0	---	11:17	188,02	39,51	---	---	---
18.02.26	0,00	0	---	3:22	188,02	39,51	---	---	---
19.02.26	0,00	0	---	1:40	188,02	39,51	---	---	---
20.02.26	0,00	0	---	0:00	188,02	39,51	---	---	---
21.02.26	0,00	0	---	6:04	188,02	39,51	---	---	---
22.02.26	0,00	0	---	0:36	188,02	39,51	---	---	---
23.02.26	0,00	0	---	2:56	188,02	39,51	---	---	---
24.02.26	0,00	0	---	11:59	188,02	39,51	---	---	---
25.02.26	0,00	0	---	3:29	188,02	39,51	---	---	---
26.02.26	0,00	0	---	0:13	188,02	39,51	---	---	---
27.02.26	0,00	0	---	12:11	188,02	39,51	---	---	---
28.02.26	0,00	0	---	14:41	188,02	39,51	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,02	39,51		---	---
Minimum	0,00	0	---		188,02	39,51		---	---
Maximum	0,00	0	---		188,02	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	1,00	73	72,96	23:30	199,15	36,31	---	---	---
02.02.26	0,00	0	---	7:06	199,26	36,21	---	---	---
03.02.26	0,00	0	---	5:15	199,08	36,38	---	---	---
04.02.26	0,00	0	---	0:13	198,81	36,66	---	---	---
05.02.26	0,00	0	---	0:10	198,61	36,86	---	---	---
06.02.26	0,00	0	---	23:48	199,18	36,28	---	---	---
07.02.26	0,00	0	---	23:14	199,37	36,09	---	---	---
08.02.26	21,58	1.336	61,90	1:53	199,39	36,08	14:49	193,46	42,00
09.02.26	24,00	1.427	59,46	---	---	---	16:50	192,95	42,52
10.02.26	21,56	1.301	60,35	---	---	---	21:58	192,91	42,55
11.02.26	10,17	665	65,41	23:40	198,74	36,73	11:32	193,10	42,36
12.02.26	1,50	108	72,04	13:50	199,06	36,40	15:24	193,85	41,61
13.02.26	6,76	457	67,60	9:34	199,14	36,33	23:55	193,57	41,89
14.02.26	24,00	1.497	62,38	---	---	---	5:40	193,05	42,41
15.02.26	23,03	1.414	61,40	---	---	---	8:52	193,10	42,36
16.02.26	24,00	1.461	60,88	---	---	---	13:35	192,89	42,57
17.02.26	22,76	1.396	61,33	12:53	197,61	37,85	22:29	192,91	42,55
18.02.26	24,00	1.467	61,13	---	---	---	3:00	192,89	42,57
19.02.26	24,00	1.472	61,33	---	---	---	21:43	193,09	42,37
20.02.26	24,00	1.509	62,88	---	---	---	23:55	192,59	42,87
21.02.26	20,19	1.286	63,69	20:54	197,89	37,58	17:12	192,45	43,01
22.02.26	10,30	750	72,82	7:03	198,38	37,08	15:07	193,21	42,25
23.02.26	21,45	1.398	65,16	3:00	198,42	37,04	21:03	192,87	42,59
24.02.26	20,27	1.274	62,86	9:57	197,86	37,60	7:00	193,00	42,46
25.02.26	24,00	1.429	59,54	---	---	---	9:21	192,84	42,62
26.02.26	24,00	1.479	61,63	---	---	---	8:44	192,78	42,68
27.02.26	24,00	1.511	62,96	---	---	---	22:43	192,88	42,58
28.02.26	24,00	1.503	62,63	---	---	---	3:27	192,85	42,62
Σ	420,57	26.213							
Mittelwert	15,02	936	62,33		198,74	36,72		193,01	42,45
Minimum	0,00	0	59,46		197,61	36,08		192,45	41,61
Maximum	24,00	1.511	72,96		199,39	37,85		193,85	43,01

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom Februar 2026
gedruckt am: 03.03.2026, 14:43 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
				1) Ruhe			2) Betrieb		
	Betrieb	Menge	Leistung	Zeitpunkt Uhr			Zeitpunkt Uhr		
	h	m³	m³/h		m üNN	m uMP		m üNN	m uMP
01.02.26	0,00	0	---	22:57	197,03	47,79	---	---	---
02.02.26	0,00	0	---	7:07	197,16	47,66	---	---	---
03.02.26	0,00	0	---	6:01	197,16	47,66	---	---	---
04.02.26	0,00	0	---	9:53	197,06	47,77	---	---	---
05.02.26	0,00	0	---	20:47	197,06	47,76	---	---	---
06.02.26	0,00	0	---	18:18	197,13	47,69	---	---	---
07.02.26	0,00	0	---	19:38	197,22	47,61	---	---	---
08.02.26	21,58	3.405	157,78	1:59	197,24	47,58	22:56	192,68	52,14
09.02.26	24,00	3.695	153,96	---	---	---	22:23	192,57	52,25
10.02.26	18,90	2.877	152,20	23:56	196,29	48,53	17:55	192,44	52,38
11.02.26	7,46	1.178	157,86	13:30	196,65	48,17	21:25	193,18	51,65
12.02.26	14,31	2.268	158,52	6:44	196,67	48,15	15:23	193,10	51,72
13.02.26	15,72	2.465	156,80	8:22	196,53	48,29	23:34	192,73	52,10
14.02.26	24,00	3.617	150,71	---	---	---	23:58	192,41	52,41
15.02.26	24,00	3.644	151,83	---	---	---	5:48	192,32	52,50
16.02.26	24,00	3.638	151,58	---	---	---	21:14	192,46	52,36
17.02.26	22,89	3.462	151,22	12:54	195,33	49,49	23:24	192,28	52,55
18.02.26	24,00	3.585	149,38	---	---	---	1:20	192,22	52,60
19.02.26	24,00	3.570	148,75	---	---	---	22:11	192,26	52,56
20.02.26	24,00	3.540	147,50	---	---	---	3:59	192,16	52,66
21.02.26	24,00	3.590	149,58	---	---	---	9:29	192,29	52,53
22.02.26	24,00	3.622	150,92	---	---	---	0:00	192,35	52,47
23.02.26	16,89	2.563	151,74	5:48	195,80	49,03	21:02	192,47	52,36
24.02.26	16,21	2.508	154,71	10:05	196,00	48,83	22:34	192,21	52,62
25.02.26	14,30	2.165	151,41	12:46	195,81	49,01	23:57	192,38	52,44
26.02.26	14,82	2.263	152,75	8:05	195,49	49,33	21:44	192,37	52,45
27.02.26	17,85	2.698	151,13	---	---	---	21:44	192,35	52,47
28.02.26	13,15	1.993	151,58	8:02	195,75	49,07	18:49	192,54	52,29
Σ	410,08	62.346							
Mittelwert	14,65	2.227	152,03		196,52	48,30		192,46	52,36
Minimum	0,00	0	147,50		195,33	47,58		192,16	51,65
Maximum	24,00	3.695	158,52		197,24	49,49		193,18	52,66

Meßpunkthöhe (MP): 244,82 m üNN