

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.26	24,00	1.216	50,67	---	---	---	0:42	193,75	16,01
02.03.26	24,00	1.208	50,33	---	---	---	23:47	193,04	16,72
03.03.26	24,00	1.179	49,13	---	---	---	23:33	192,36	17,41
04.03.26	24,00	1.181	49,21	---	---	---	22:18	192,23	17,54
05.03.26	24,00	1.171	48,79	---	---	---	22:12	192,10	17,66
06.03.26	24,00	1.185	49,38	---	---	---	0:34	192,10	17,66
07.03.26	24,00	1.202	50,08	---	---	---	0:08	193,13	16,64
08.03.26	24,00	1.209	50,38	---	---	---	1:10	193,47	16,29
09.03.26	24,00	1.203	50,13	---	---	---	16:49	193,58	16,19
10.03.26	24,00	1.193	49,71	---	---	---	11:18	193,34	16,42
11.03.26	21,44	1.070	49,90	12:17	195,51	14,25	0:03	193,51	16,25
12.03.26	24,00	1.186	49,42	---	---	---	22:11	192,71	17,05
13.03.26	24,00	1.182	49,25	---	---	---	23:14	192,58	17,19
14.03.26	21,39	1.058	49,47	9:20	194,32	15,45	22:27	192,45	17,32
15.03.26	24,00	1.186	49,42	---	---	---	8:51	192,34	17,42
16.03.26	24,00	1.175	48,96	---	---	---	11:58	192,36	17,41
17.03.26	22,26	1.101	49,45	11:48	194,31	15,45	21:36	192,52	17,24
18.03.26	24,00	1.178	49,08	---	---	---	23:56	192,52	17,24
19.03.26	21,78	1.080	49,58	11:11	194,76	15,00	0:23	192,50	17,26
20.03.26	24,00	1.196	49,83	---	---	---	0:00	192,83	16,93
21.03.26	24,00	1.211	50,46	---	---	---	1:04	193,11	16,65
22.03.26	24,00	1.215	50,63	---	---	---	0:00	193,29	16,47
23.03.26	24,00	1.210	50,42	---	---	---	21:53	193,33	16,43
24.03.26	21,08	1.060	50,30	11:40	195,04	14,72	18:00	193,17	16,59
25.03.26	22,95	1.197	52,16	19:55	195,41	14,36	0:00	193,45	16,31
26.03.26	24,00	1.230	51,25	---	---	---	11:47	193,85	15,91
27.03.26	24,00	1.223	50,96	---	---	---	23:07	193,74	16,03
28.03.26	24,00	1.209	50,38	---	---	---	22:17	193,55	16,21
29.03.26	23,00	1.172	50,96	---	---	---	0:36	193,58	16,19
30.03.26	24,00	1.205	50,21	---	---	---	23:44	193,50	16,26
31.03.26	24,00	1.192	49,67	---	---	---	13:05	193,19	16,58
Σ	729,90	36.483							
Mittelwert	23,55	1.177	49,98		194,89	14,87		193,00	16,76
Minimum	21,08	1.058	48,79		194,31	14,25		192,10	15,91
Maximum	24,00	1.230	52,16		195,51	15,45		193,85	17,66

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.26	0,26	56	219,13	9:05	200,60	7,22	---	---	---
02.03.26	7,70	1.788	232,29	4:24	200,53	7,29	21:36	191,12	16,71
03.03.26	23,47	5.392	229,70	---	---	---	14:15	190,97	16,85
04.03.26	24,00	5.541	230,88	---	---	---	13:06	190,97	16,85
05.03.26	24,00	5.492	228,83	---	---	---	12:05	190,97	16,85
06.03.26	7,82	1.812	231,63	23:51	198,96	8,86	0:00	190,98	16,84
07.03.26	0,00	0	---	23:06	199,53	8,29	---	---	---
08.03.26	0,13	26	207,54	14:40	199,67	8,15	---	---	---
09.03.26	0,50	110	220,00	5:51	199,75	8,07	---	---	---
10.03.26	2,87	639	222,37	5:57	199,63	8,19	10:58	192,12	15,70
11.03.26	1,71	377	220,93	12:22	200,42	7,40	---	---	---
12.03.26	22,87	5.304	231,94	0:56	199,53	8,29	22:11	191,14	16,68
13.03.26	24,00	5.553	231,38	---	---	---	3:51	190,98	16,84
14.03.26	24,00	5.561	231,71	---	---	---	18:41	190,97	16,85
15.03.26	24,00	5.584	232,67	---	---	---	2:00	190,97	16,85
16.03.26	18,24	4.182	229,26	21:16	197,92	9,91	1:27	190,97	16,85
17.03.26	12,82	2.919	227,65	8:31	198,64	9,18	21:24	191,06	16,76
18.03.26	15,34	3.491	227,58	6:45	198,38	9,44	23:51	191,12	16,71
19.03.26	10,41	2.378	228,34	11:04	199,50	8,32	17:44	191,35	16,47
20.03.26	0,56	122	216,46	7:59	198,97	8,85	---	---	---
21.03.26	0,00	0	---	8:55	199,62	8,20	---	---	---
22.03.26	0,00	0	---	7:12	199,53	8,29	---	---	---
23.03.26	0,43	95	219,79	7:23	200,04	7,78	---	---	---
24.03.26	6,60	1.521	230,58	23:58	200,14	7,68	14:15	191,64	16,18
25.03.26	5,04	1.233	244,89	14:57	201,47	6,35	19:55	193,75	14,07
26.03.26	0,23	51	220,41	6:16	201,03	6,79	---	---	---
27.03.26	0,00	0	---	6:06	200,99	6,83	---	---	---
28.03.26	0,21	46	220,51	5:58	199,57	8,25	---	---	---
29.03.26	0,00	0	---	10:37	200,22	7,60	---	---	---
30.03.26	0,76	168	220,89	7:33	199,62	8,20	---	---	---
31.03.26	3,97	892	224,53	5:07	199,62	8,20	12:00	191,63	16,19
Σ	261,94	60.333							
Mittelwert	8,45	1.946	230,33		199,75	8,07		191,34	16,48
Minimum	0,00	0	207,54		197,92	6,35		190,97	14,07
Maximum	24,00	5.584	244,89		201,47	9,91		193,75	16,85

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.26	10,40	1.482	142,51	9:03	195,46	17,38	0:15	191,05	21,78
02.03.26	13,01	1.841	141,54	4:22	195,38	17,45	21:26	187,93	24,91
03.03.26	10,71	1.460	136,26	12:20	191,60	21,23	19:19	187,01	25,82
04.03.26	8,93	1.219	136,43	8:35	191,17	21,66	21:49	186,89	25,95
05.03.26	12,05	1.641	136,22	6:34	190,99	21,84	19:40	186,78	26,05
06.03.26	17,68	2.513	142,16	6:46	191,10	21,74	7:53	188,43	24,40
07.03.26	24,00	3.474	144,75	---	---	---	1:11	190,27	22,56
08.03.26	24,00	3.487	145,29	---	---	---	9:04	190,74	22,09
09.03.26	24,00	3.469	144,54	---	---	---	15:03	190,18	22,66
10.03.26	23,68	3.386	143,00	---	---	---	10:58	188,86	23,97
11.03.26	22,15	3.187	143,91	12:20	195,31	17,53	15:35	189,70	23,13
12.03.26	1,65	226	136,95	2:06	193,52	19,32	0:01	190,73	22,11
13.03.26	0,78	102	130,72	12:02	191,55	21,28	---	---	---
14.03.26	0,41	53	129,18	8:36	191,42	21,42	---	---	---
15.03.26	0,00	0	---	11:01	191,43	21,40	---	---	---
16.03.26	10,35	1.451	140,19	9:25	191,39	21,45	14:44	188,04	24,80
17.03.26	23,81	3.375	141,78	---	---	---	11:46	187,96	24,88
18.03.26	24,00	3.396	141,50	---	---	---	19:26	188,11	24,72
19.03.26	22,00	3.142	142,85	11:03	194,36	18,48	0:00	188,33	24,51
20.03.26	23,56	3.376	143,32	---	---	---	20:58	189,15	23,68
21.03.26	22,61	3.278	144,99	---	---	---	0:35	189,17	23,67
22.03.26	22,93	3.337	145,56	---	---	---	21:06	189,73	23,10
23.03.26	21,05	3.038	144,29	3:45	194,57	18,26	16:47	189,54	23,30
24.03.26	17,53	2.504	142,81	23:57	195,03	17,80	17:03	188,86	23,97
25.03.26	2,66	391	146,95	15:07	196,58	16,26	23:08	191,69	21,14
26.03.26	16,70	2.446	146,47	6:09	196,04	16,79	10:06	190,87	21,97
27.03.26	18,82	2.738	145,46	6:08	195,98	16,86	21:54	190,27	22,56
28.03.26	24,00	3.472	144,67	---	---	---	14:01	189,78	23,06
29.03.26	21,36	3.120	146,08	10:36	195,09	17,74	0:17	190,10	22,73
30.03.26	24,00	3.459	144,13	---	---	---	23:26	189,57	23,27
31.03.26	23,29	3.326	142,80	---	---	---	11:29	188,51	24,32
Σ	512,10	73.389							
Mittelwert	16,52	2.367	143,31		193,58	19,26		189,22	23,61
Minimum	0,00	0	129,18		190,99	16,26		186,78	21,14
Maximum	24,00	3.487	146,95		196,58	21,84		191,69	26,05

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.26	0,31	57	182,24	9:03	194,85	15,26	---	---	---
02.03.26	7,86	1.490	189,49	4:24	194,76	15,36	21:58	177,00	33,11
03.03.26	23,53	4.395	186,79	---	---	---	0:37	177,00	33,11
04.03.26	24,00	4.510	187,92	---	---	---	---	---	---
05.03.26	24,00	4.463	185,96	---	---	---	---	---	---
06.03.26	8,07	1.523	188,76	23:08	193,52	16,59	0:00	177,00	33,11
07.03.26	0,00	0	---	22:31	194,32	15,80	---	---	---
08.03.26	0,19	33	175,74	14:33	194,56	15,55	---	---	---
09.03.26	1,29	238	184,58	5:49	194,62	15,49	---	---	---
10.03.26	3,00	544	181,13	5:36	194,29	15,83	10:59	178,06	32,06
11.03.26	1,94	352	181,13	12:22	195,08	15,03	---	---	---
12.03.26	22,91	4.323	188,66	0:36	194,10	16,01	8:56	177,00	33,11
13.03.26	24,00	4.513	188,04	---	---	---	10:29	177,00	33,11
14.03.26	24,00	4.517	188,21	---	---	---	7:00	177,00	33,11
15.03.26	24,00	4.542	189,25	---	---	---	0:32	177,00	33,11
16.03.26	16,64	3.092	185,84	21:20	192,47	17,64	0:02	177,00	33,11
17.03.26	3,50	637	182,03	8:19	193,26	16,85	12:02	177,02	33,10
18.03.26	1,83	326	178,20	6:51	192,93	17,19	---	---	---
19.03.26	1,94	349	179,49	11:13	194,13	15,98	14:14	179,28	30,84
20.03.26	12,12	2.279	188,08	8:41	193,28	16,84	20:54	177,81	32,30
21.03.26	5,55	1.045	188,36	8:57	193,94	16,18	0:25	177,86	32,26
22.03.26	4,88	926	189,76	13:34	193,87	16,24	20:54	178,48	31,63
23.03.26	9,11	1.720	188,77	7:25	194,44	15,68	16:30	178,29	31,83
24.03.26	7,27	1.358	186,78	23:59	194,73	15,39	16:33	178,07	32,04
25.03.26	0,00	0	---	14:27	196,51	13,60	---	---	---
26.03.26	1,78	338	190,21	6:18	195,75	14,36	9:59	179,81	30,30
27.03.26	5,17	981	189,85	5:57	195,66	14,45	21:52	179,17	30,94
28.03.26	9,72	1.844	189,77	5:48	194,06	16,06	13:56	178,53	31,58
29.03.26	4,20	798	190,14	10:38	194,61	15,51	21:42	178,99	31,13
30.03.26	10,85	2.045	188,46	7:17	194,12	16,00	23:19	178,51	31,60
31.03.26	10,30	1.916	185,99	8:09	193,87	16,24	12:59	178,03	32,09
Σ	293,96	55.154							
Mittelwert	9,48	1.779	187,62		194,31	15,80		177,90	32,21
Minimum	0,00	0	175,74		192,47	13,60		177,00	30,30
Maximum	24,00	4.542	190,21		196,51	17,64		179,81	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.26	24,00	2.903	120,96	---	---	---	0:37	184,20	30,58
02.03.26	24,00	2.887	120,29	---	---	---	22:54	183,46	31,31
03.03.26	23,80	2.824	118,66	---	---	---	19:57	182,99	31,79
04.03.26	23,13	2.764	119,48	---	---	---	0:26	183,05	31,72
05.03.26	24,00	2.852	118,83	---	---	---	22:20	183,08	31,69
06.03.26	17,18	2.042	118,86	8:48	193,72	21,05	0:29	183,11	31,66
07.03.26	9,27	1.097	118,37	7:38	194,47	20,30	0:57	184,45	30,32
08.03.26	7,98	950	118,99	8:44	194,81	19,97	1:01	185,04	29,74
09.03.26	13,13	1.559	118,70	5:38	194,81	19,97	13:06	184,68	30,09
10.03.26	17,26	2.040	118,18	---	---	---	18:28	184,18	30,60
11.03.26	11,77	1.391	118,18	12:42	194,97	19,80	18:02	184,64	30,14
12.03.26	23,48	2.795	119,01	---	---	---	21:59	183,08	31,69
13.03.26	22,52	2.679	118,97	---	---	---	0:49	183,07	31,71
14.03.26	23,71	2.827	119,22	---	---	---	2:25	183,14	31,63
15.03.26	22,56	2.705	119,89	---	---	---	1:27	183,33	31,45
16.03.26	24,00	2.851	118,79	---	---	---	11:55	183,22	31,56
17.03.26	23,14	2.759	119,23	---	---	---	21:39	183,58	31,19
18.03.26	24,00	2.858	119,08	---	---	---	19:39	183,49	31,28
19.03.26	21,04	2.525	119,98	11:58	194,52	20,26	0:23	183,51	31,27
20.03.26	24,00	2.880	120,00	---	---	---	21:01	183,52	31,25
21.03.26	24,00	2.915	121,46	---	---	---	0:38	183,54	31,24
22.03.26	24,00	2.926	121,92	---	---	---	21:12	184,07	30,70
23.03.26	24,00	2.911	121,29	---	---	---	20:35	183,97	30,81
24.03.26	16,13	1.944	120,52	23:58	194,55	20,23	1:30	184,00	30,78
25.03.26	10,65	1.338	125,69	17:17	196,56	18,21	1:28	185,43	29,34
26.03.26	24,00	2.970	123,75	---	---	---	11:38	185,24	29,54
27.03.26	23,17	2.838	122,49	---	---	---	21:59	184,62	30,15
28.03.26	24,00	2.902	120,92	---	---	---	14:06	184,10	30,67
29.03.26	23,00	2.817	122,48	---	---	---	0:23	184,35	30,43
30.03.26	24,00	2.892	120,50	---	---	---	23:28	183,92	30,85
31.03.26	23,78	2.846	119,66	---	---	---	17:45	183,66	31,11
Σ	644,72	77.487							
Mittelwert	20,80	2.500	120,19		194,80	19,97		183,86	30,91
Minimum	7,98	950	118,18		193,72	18,21		182,99	29,34
Maximum	24,00	2.970	125,69		196,56	21,05		185,43	31,79

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.26	24,00	1.277	53,21	---	---	---	1:50	188,60	24,68
02.03.26	24,00	1.274	53,08	---	---	---	1:09	188,63	24,65
03.03.26	23,82	1.272	53,41	---	---	---	13:35	189,28	24,00
04.03.26	23,16	1.265	54,61	---	---	---	0:21	189,91	23,37
05.03.26	24,00	1.292	53,83	---	---	---	19:57	190,16	23,12
06.03.26	17,31	922	53,26	7:02	195,56	17,72	21:07	189,36	23,92
07.03.26	9,41	499	53,00	7:36	194,55	18,73	1:05	189,28	24,00
08.03.26	8,09	428	52,91	8:35	195,15	18,13	0:57	189,70	23,58
09.03.26	13,35	701	52,50	4:12	194,80	18,48	19:57	189,38	23,90
10.03.26	17,45	904	51,79	---	---	---	18:32	188,91	24,37
11.03.26	11,93	621	52,06	12:33	195,27	18,01	18:05	189,43	23,85
12.03.26	23,52	1.249	53,11	---	---	---	20:25	188,93	24,35
13.03.26	22,58	1.207	53,47	---	---	---	0:20	188,93	24,35
14.03.26	23,72	1.273	53,66	---	---	---	10:06	189,20	24,08
15.03.26	22,61	1.233	54,53	---	---	---	0:48	189,70	23,58
16.03.26	24,00	1.273	53,04	---	---	---	17:05	188,98	24,30
17.03.26	23,14	1.221	52,76	---	---	---	21:35	188,82	24,46
18.03.26	24,00	1.256	52,33	---	---	---	23:56	188,75	24,53
19.03.26	21,06	1.117	53,04	11:52	195,22	18,06	0:00	188,75	24,53
20.03.26	24,00	1.277	53,21	---	---	---	21:48	189,22	24,06
21.03.26	24,00	1.305	54,38	---	---	---	0:55	189,24	24,04
22.03.26	24,00	1.312	54,67	---	---	---	0:00	189,60	23,68
23.03.26	24,00	1.302	54,25	---	---	---	2:27	189,65	23,63
24.03.26	22,52	1.213	53,86	23:59	195,48	17,80	9:05	189,23	24,05
25.03.26	10,72	632	58,98	14:16	197,52	15,76	1:24	191,16	22,12
26.03.26	24,00	1.355	56,46	---	---	---	11:33	190,80	22,48
27.03.26	23,18	1.284	55,39	---	---	---	23:06	190,22	23,06
28.03.26	24,00	1.293	53,88	---	---	---	14:49	189,81	23,47
29.03.26	23,00	1.269	55,17	---	---	---	0:54	189,94	23,34
30.03.26	24,00	1.284	53,50	---	---	---	23:59	189,65	23,63
31.03.26	23,71	1.252	52,81	---	---	---	18:31	189,38	23,90
Σ	652,28	35.062							
Mittelwert	21,04	1.131	53,75		195,44	17,84		189,44	23,84
Minimum	8,09	428	51,79		194,55	15,76		188,60	22,12
Maximum	24,00	1.355	58,98		197,52	18,73		191,16	24,68

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.26	24,00	2.565	106,88	---	---	---	2:40	193,11	23,69
02.03.26	16,85	1.792	106,37	23:59	200,86	15,94	13:38	193,15	23,65
03.03.26	2,84	297	104,58	9:11	201,14	15,66	11:48	194,40	22,40
04.03.26	0,00	0	---	15:07	201,55	15,25	---	---	---
05.03.26	0,00	0	---	23:51	201,43	15,37	---	---	---
06.03.26	17,04	1.812	106,32	6:53	201,84	14,96	22:24	193,68	23,12
07.03.26	23,68	2.533	106,97	---	---	---	1:11	193,62	23,18
08.03.26	22,64	2.429	107,29	8:14	200,58	16,22	1:19	193,67	23,13
09.03.26	23,33	2.484	106,46	---	---	---	20:10	193,55	23,25
10.03.26	23,65	2.492	105,36	---	---	---	18:45	193,37	23,43
11.03.26	22,14	2.351	106,17	12:20	200,76	16,04	0:00	193,39	23,41
12.03.26	12,90	1.360	105,42	8:03	201,02	15,78	0:00	193,58	23,22
13.03.26	10,11	1.068	105,64	8:53	201,38	15,42	0:12	194,10	22,70
14.03.26	9,49	1.009	106,36	23:21	201,14	15,66	9:54	194,30	22,50
15.03.26	6,47	693	107,10	9:33	201,70	15,10	0:30	194,98	21,82
16.03.26	11,87	1.248	105,12	4:47	201,26	15,54	23:06	194,09	22,71
17.03.26	12,26	1.290	105,22	8:54	199,84	16,96	20:39	193,62	23,18
18.03.26	15,16	1.589	104,79	6:45	199,50	17,30	23:37	193,67	23,13
19.03.26	10,29	1.080	104,98	11:03	200,95	15,85	6:42	193,96	22,84
20.03.26	0,52	53	101,44	7:58	200,13	16,67	---	---	---
21.03.26	0,00	0	---	8:53	200,64	16,16	---	---	---
22.03.26	0,00	0	---	18:07	200,51	16,29	---	---	---
23.03.26	0,40	41	102,22	7:24	201,08	15,72	---	---	---
24.03.26	8,85	969	109,54	23:59	201,46	15,34	9:04	193,51	23,29
25.03.26	5,00	592	118,39	14:36	202,71	14,09	19:37	196,15	20,65
26.03.26	0,20	21	104,13	0:44	202,05	14,75	---	---	---
27.03.26	0,00	0	---	6:07	201,98	14,82	---	---	---
28.03.26	0,18	19	104,75	0:59	200,22	16,58	---	---	---
29.03.26	0,00	0	---	10:36	201,24	15,56	---	---	---
30.03.26	0,70	72	102,29	7:45	200,30	16,50	---	---	---
31.03.26	3,20	327	102,13	5:07	200,50	16,30	11:32	194,06	22,74
Σ	283,79	30.186							
Mittelwert	9,15	974	106,37		201,03	15,77		193,90	22,90
Minimum	0,00	0	101,44		199,50	14,09		193,11	20,65
Maximum	24,00	2.565	118,39		202,71	17,30		196,15	23,69

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.26	24,00	4.325	180,21	---	---	---	3:17	179,02	42,13
02.03.26	16,87	3.017	178,84	23:43	196,56	24,59	13:47	178,85	42,30
03.03.26	2,90	501	172,86	23:48	197,14	24,01	11:50	180,07	41,08
04.03.26	0,00	0	---	15:42	197,66	23,49	---	---	---
05.03.26	0,00	0	---	23:54	197,56	23,59	---	---	---
06.03.26	17,03	3.055	179,42	6:48	197,91	23,24	21:26	180,07	41,08
07.03.26	23,69	4.280	180,65	---	---	---	5:56	179,52	41,63
08.03.26	22,67	4.112	181,40	8:15	196,04	25,11	6:57	179,52	41,63
09.03.26	23,35	4.178	178,90	---	---	---	3:01	179,50	41,65
10.03.26	23,76	4.187	176,25	---	---	---	11:05	178,70	42,45
11.03.26	22,16	3.946	178,08	12:20	196,22	24,93	10:29	179,14	42,01
12.03.26	13,04	2.291	175,75	8:07	196,85	24,30	0:25	179,90	41,25
13.03.26	10,28	1.809	175,93	8:59	197,36	23,79	0:13	180,60	40,55
14.03.26	9,68	1.724	178,01	23:27	197,12	24,03	9:56	180,86	40,29
15.03.26	6,62	1.189	179,52	9:50	197,75	23,40	0:32	181,70	39,45
16.03.26	16,33	2.979	182,47	4:50	197,26	23,89	23:16	178,91	42,24
17.03.26	23,84	4.476	187,74	---	---	---	21:30	178,60	42,55
18.03.26	24,00	4.405	183,54	---	---	---	19:37	178,38	42,77
19.03.26	22,04	4.166	188,99	11:01	196,54	24,61	0:00	178,38	42,77
20.03.26	23,61	4.573	193,71	---	---	---	0:00	178,85	42,30
21.03.26	22,72	4.496	197,90	---	---	---	5:14	179,06	42,09
22.03.26	23,03	4.622	200,69	---	---	---	0:25	179,25	41,90
23.03.26	21,20	4.184	197,32	3:41	196,64	24,51	2:25	179,35	41,80
24.03.26	14,14	2.651	187,53	23:53	197,22	23,93	3:51	180,00	41,15
25.03.26	2,71	545	201,33	14:45	198,68	22,47	23:11	181,44	39,71
26.03.26	16,98	3.369	198,38	3:09	197,96	23,19	10:50	180,42	40,73
27.03.26	18,97	3.694	194,75	6:04	197,84	23,31	23:49	180,35	40,80
28.03.26	24,00	4.717	196,54	---	---	---	9:53	179,42	41,73
29.03.26	21,41	4.352	203,31	10:33	197,02	24,13	3:23	179,48	41,67
30.03.26	24,00	4.644	193,50	---	---	---	2:28	179,66	41,49
31.03.26	23,31	4.375	187,70	---	---	---	7:53	179,72	41,43
Σ	538,33	100.862							
Mittelwert	17,37	3.254	187,36		197,23	23,92		179,61	41,54
Minimum	0,00	0	172,86		196,04	22,47		178,38	39,45
Maximum	24,00	4.717	203,31		198,68	25,11		181,70	42,77

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.26	0,00	0	---	7:26	188,02	39,51	---	---	---
02.03.26	0,00	0	---	---	---	---	---	---	---
03.03.26	0,00	0	---	19:08	188,02	39,51	---	---	---
04.03.26	0,00	0	---	4:57	188,02	39,51	---	---	---
05.03.26	0,00	0	---	11:29	188,02	39,51	---	---	---
06.03.26	0,00	0	---	1:38	188,02	39,51	---	---	---
07.03.26	0,00	0	---	2:48	188,02	39,51	---	---	---
08.03.26	0,00	0	---	---	---	---	---	---	---
09.03.26	0,00	0	---	13:20	188,02	39,51	---	---	---
10.03.26	0,00	0	---	16:00	188,02	39,51	---	---	---
11.03.26	0,00	0	---	2:20	188,02	39,51	---	---	---
12.03.26	0,00	0	---	---	---	---	---	---	---
13.03.26	0,00	0	---	0:39	188,02	39,51	---	---	---
14.03.26	0,00	0	---	4:39	188,02	39,51	---	---	---
15.03.26	0,00	0	---	2:37	188,02	39,51	---	---	---
16.03.26	0,00	0	---	23:41	188,02	39,51	---	---	---
17.03.26	0,00	0	---	5:42	188,02	39,51	---	---	---
18.03.26	0,00	0	---	15:58	188,02	39,51	---	---	---
19.03.26	0,00	0	---	12:42	188,02	39,51	---	---	---
20.03.26	0,00	0	---	1:06	188,02	39,51	---	---	---
21.03.26	0,00	0	---	---	---	---	---	---	---
22.03.26	0,00	0	---	3:32	188,02	39,51	---	---	---
23.03.26	0,00	0	---	4:56	188,02	39,51	---	---	---
24.03.26	0,00	0	---	4:17	188,02	39,51	---	---	---
25.03.26	0,00	0	---	5:27	188,02	39,51	---	---	---
26.03.26	0,00	0	---	9:26	188,02	39,51	---	---	---
27.03.26	0,00	0	---	1:20	188,02	39,51	---	---	---
28.03.26	0,00	0	---	0:37	188,02	39,51	---	---	---
29.03.26	0,00	0	---	---	---	---	---	---	---
30.03.26	0,00	0	---	3:20	188,02	39,51	---	---	---
31.03.26	0,00	0	---	10:26	188,02	39,51	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,02	39,51		---	---
Minimum	0,00	0	---		188,02	39,51		---	---
Maximum	0,00	0	---		188,02	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.03.26	24,00	1.498	62,42	---	---	---	10:32	192,85	42,61
02.03.26	24,00	1.480	61,67	---	---	---	14:49	192,85	42,61
03.03.26	17,60	1.034	58,75	23:54	198,55	36,92	12:30	192,81	42,65
04.03.26	7,57	448	59,18	16:04	198,93	36,53	23:59	194,28	41,18
05.03.26	17,82	1.045	58,64	23:55	198,81	36,65	15:20	193,88	41,58
06.03.26	17,09	1.086	63,53	6:46	198,98	36,48	17:41	193,24	42,22
07.03.26	23,75	1.422	59,87	---	---	---	8:58	192,84	42,62
08.03.26	22,73	1.350	59,40	8:12	197,68	37,78	17:06	193,05	42,41
09.03.26	23,41	1.413	60,36	---	---	---	14:33	193,03	42,43
10.03.26	24,00	1.461	60,88	---	---	---	17:11	192,72	42,75
11.03.26	22,22	1.350	60,77	12:15	197,71	37,75	6:11	192,81	42,65
12.03.26	14,29	968	67,74	8:01	198,24	37,22	23:59	193,05	42,41
13.03.26	10,91	752	68,90	8:59	198,61	36,86	0:12	192,99	42,47
14.03.26	10,39	709	68,25	23:22	198,52	36,94	9:17	193,49	41,97
15.03.26	7,20	522	72,46	9:54	198,87	36,60	0:32	193,58	41,88
16.03.26	12,57	860	68,41	4:45	198,64	36,83	23:06	193,41	42,06
17.03.26	12,02	784	65,24	8:48	198,15	37,32	11:53	192,88	42,58
18.03.26	17,30	1.134	65,53	6:44	197,96	37,50	19:23	192,80	42,66
19.03.26	12,07	804	66,64	11:15	198,15	37,31	21:04	193,02	42,45
20.03.26	9,93	623	62,73	7:58	198,09	37,37	17:15	193,38	42,08
21.03.26	9,38	582	62,01	7:25	198,22	37,24	16:03	193,35	42,12
22.03.26	4,09	277	67,74	14:06	198,35	37,11	15:53	193,19	42,27
23.03.26	5,88	404	68,76	8:12	198,55	36,92	19:48	193,15	42,31
24.03.26	22,38	1.383	61,78	16:36	198,07	37,39	8:14	192,80	42,66
25.03.26	24,00	1.385	57,71	---	---	---	1:28	194,03	41,43
26.03.26	24,00	1.415	58,96	---	---	---	9:19	193,55	41,91
27.03.26	24,00	1.469	61,21	---	---	---	23:39	193,53	41,93
28.03.26	9,46	602	63,67	23:29	198,35	37,12	6:22	193,06	42,40
29.03.26	0,00	0	---	11:30	198,57	36,89	---	---	---
30.03.26	15,41	978	63,45	6:47	198,57	36,89	13:59	193,14	42,32
31.03.26	24,00	1.481	61,71	---	---	---	11:28	192,64	42,82
Σ	493,47	30.719							
Mittelwert	15,92	991	62,25		198,39	37,07		193,18	42,28
Minimum	0,00	0	57,71		197,68	36,48		192,64	41,18
Maximum	24,00	1.498	72,46		198,98	37,78		194,28	42,82

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom März 2026
gedruckt am: 05.04.2026, 09:13 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.03.26	12,23	1.885	154,09	4:27	195,74	49,09	0:22	192,60	52,23
02.03.26	11,23	1.738	154,70	21:52	196,09	48,74	16:10	192,57	52,26
03.03.26	13,71	2.146	156,50	6:09	196,14	48,68	12:26	192,58	52,24
04.03.26	10,93	1.714	156,77	8:43	196,40	48,42	21:50	193,15	51,68
05.03.26	14,18	2.223	156,74	---	---	---	19:49	193,00	51,82
06.03.26	17,92	2.752	153,53	6:41	196,50	48,32	22:35	192,36	52,46
07.03.26	24,00	3.628	151,17	---	---	---	15:28	192,27	52,55
08.03.26	24,00	3.639	151,63	---	---	---	2:30	192,38	52,44
09.03.26	24,00	3.597	149,88	---	---	---	21:47	192,34	52,48
10.03.26	23,48	3.507	149,38	---	---	---	23:58	192,19	52,63
11.03.26	22,27	3.365	151,08	12:16	195,61	49,21	3:54	192,15	52,68
12.03.26	2,07	316	152,58	13:41	196,26	48,56	0:25	192,35	52,47
13.03.26	1,16	186	160,81	9:51	196,58	48,24	---	---	---
14.03.26	0,66	107	161,24	23:21	196,59	48,23	---	---	---
15.03.26	0,00	0	---	9:29	196,74	48,08	---	---	---
16.03.26	3,38	537	159,01	4:22	196,71	48,11	15:50	193,21	51,61
17.03.26	2,65	407	153,58	8:50	196,49	48,33	12:02	193,08	51,75
18.03.26	2,02	323	159,81	6:25	196,40	48,42	---	---	---
19.03.26	2,13	339	158,95	12:00	196,58	48,25	14:16	193,63	51,19
20.03.26	12,49	1.957	156,70	1:03	196,46	48,36	20:41	192,94	51,88
21.03.26	5,82	921	158,12	12:03	196,58	48,25	0:18	192,92	51,90
22.03.26	5,07	810	159,75	13:53	196,68	48,14	21:03	193,31	51,51
23.03.26	9,44	1.492	158,11	9:38	196,76	48,06	20:27	193,19	51,63
24.03.26	10,58	1.688	159,57	23:57	196,64	48,19	11:04	192,70	52,13
25.03.26	0,00	0	---	18:27	197,51	47,31	---	---	---
26.03.26	1,84	301	163,81	0:00	197,42	47,41	10:00	194,01	50,81
27.03.26	5,36	864	161,10	6:08	197,19	47,63	21:53	193,60	51,23
28.03.26	10,15	1.624	159,99	5:47	196,73	48,09	13:57	193,28	51,54
29.03.26	4,41	707	160,49	11:42	196,84	47,99	21:45	193,58	51,24
30.03.26	11,24	1.780	158,32	7:08	196,88	47,94	23:21	193,18	51,65
31.03.26	10,19	1.596	156,64	8:51	196,61	48,22	17:38	193,05	51,78
Σ	298,63	46.149							
Mittelwert	9,63	1.489	154,54		196,58	48,24		192,91	51,91
Minimum	0,00	0	149,38		195,61	47,31		192,15	50,81
Maximum	24,00	3.639	163,81		197,51	49,21		194,01	52,68

Meßpunkthöhe (MP): 244,82 m üNN